

ARMIDALE, Australia

WMO: 957730

Lat: 30.5272S

Lon: 151.6158E

Elev: 1080

StdP: 89.01

Time Zone: 10.00 (AUS)

Period: 97-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	-1.4	-0.2	-7.3	2.3	9.3	-5.5	2.7	8.2	12.8	10.0	11.6	8.3	3.1	270	0.573

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	11.1	30.1	17.6	28.5	17.3	26.8	16.8	20.2	25.4	19.4	24.6	18.6	23.6	5.7	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.9	15.6	21.8	17.9	14.7	20.8	17.1	14.0	20.3	63.3	25.4	60.1	24.6	57.4	23.7	24.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(4) 11.1	9.7	8.6	(e) -4.1	(f) 32.9	(g) 0.9	(h) 2.0	(i) -4.8	(j) 34.3	(k) -5.3	(l) 35.5	(m) -5.8	(n) 36.6	(o) -6.5	(p) 38.1		
(5)			DB -4.7	21.4	1.1	1.2	-5.6	22.3	-6.2	22.9	-6.9	23.6	-7.7	24.4		
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	13.4	19.6	19.0	17.0	13.7	9.9	7.5	6.7	7.8	11.1	13.9	16.2	18.3
	DBStd	5.27	2.91	2.76	2.35	2.39	2.38	2.36	2.31	2.62	3.06	3.21	3.36	3.01
	HDD10.0	326	0	0	0	3	31	81	105	78	22	6	1	0
	HDD18.3	1986	20	22	54	138	262	326	360	327	217	142	81	38
	CDD10.0	1549	297	251	218	114	28	4	3	9	55	125	187	257
	CDD18.3	168	58	40	14	0	0	0	0	0	1	3	17	36
	CDH23.3	1534	516	338	97	6	0	0	0	1	6	44	186	340
	CDH26.7	381	149	94	10	0	0	0	0	0	0	5	43	79
Wind	WSAvg	4.5	4.8	4.7	4.5	4.1	4.0	4.4	4.5	4.6	4.7	4.6	4.6	4.7
Precipitation	PrecAvg	764	117	75	60	47	54	37	45	44	45	67	81	89
	PrecMax	935	216	167	197	167	198	112	108	109	137	158	186	202
	PrecMin	460	13	6	2	3	8	2	0	1	5	23	10	25
	PrecStd	136	61	48	48	42	46	24	31	29	28	30	44	45
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.4	32.2	28.0	24.1	20.0	16.4	16.3	19.5	24.3	26.9	30.3	31.1
		MCWB	18.5	18.0	16.8	14.2	12.2	10.3	10.3	10.8	13.1	13.7	17.1	17.2
	2%	DB	30.1	29.4	25.8	22.2	18.0	14.6	14.4	16.9	21.7	24.4	27.7	28.9
		MCWB	17.9	17.9	16.5	13.7	11.2	9.9	9.3	9.4	11.8	13.7	15.9	16.9
	5%	DB	28.3	27.2	24.1	20.7	16.6	13.4	13.0	15.1	19.5	22.7	25.4	27.0
		MCWB	17.7	17.8	16.3	13.4	10.4	9.3	8.3	8.3	11.2	13.4	15.2	16.5
	10%	DB	26.3	25.2	22.6	19.1	15.1	12.1	11.7	13.6	17.7	20.9	23.1	25.2
		MCWB	17.3	17.4	16.1	13.0	10.1	8.9	7.6	7.8	10.4	12.9	14.9	16.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.5	21.7	20.4	16.9	14.5	12.6	13.4	12.9	14.7	17.3	19.0	20.2
		MCDB	26.4	27.5	23.0	20.0	17.2	14.2	14.6	17.5	21.2	21.8	26.5	26.1
	2%	WB	20.2	20.2	18.6	15.6	12.8	11.4	10.9	10.9	13.5	15.9	17.8	19.1
		MCDB	25.6	25.4	22.4	19.0	15.4	13.0	12.7	14.2	18.5	20.7	24.0	25.2
	5%	WB	19.4	19.3	17.7	14.7	11.8	10.4	9.4	9.8	12.5	14.8	16.9	18.2
		MCDB	24.6	24.1	21.5	18.4	14.7	12.2	11.5	13.2	17.3	19.9	22.4	23.5
	10%	WB	18.6	18.4	17.0	13.9	11.0	9.5	8.4	8.7	11.5	13.9	16.0	17.4
		MCDB	23.5	22.9	20.6	17.6	13.9	11.3	10.6	12.3	16.0	18.7	20.8	22.3
Mean Daily Temperature Range	5% DB	MDBR	11.1	10.4	10.1	10.3	10.2	8.7	9.3	10.7	11.4	11.5	11.1	11.3
		MCDBR	14.5	13.9	12.6	12.5	12.2	10.6	11.3	12.8	13.6	14.0	14.6	14.5
		MCWBR	5.0	5.1	5.2	5.4	6.2	6.3	6.5	6.9	6.7	6.2	5.9	5.5
	5% WB	MCDBR	11.2	10.9	10.0	10.1	9.4	7.8	8.3	9.9	10.9	11.6	11.5	11.3
	MCWBR	4.9	4.8	5.2	5.2	5.5	5.3	5.7	6.1	6.1	6.2	5.5	5.4	
Clear-Sky Solar Irradiance	taub	0.327	0.320	0.299	0.284	0.265	0.260	0.256	0.271	0.298	0.318	0.333	0.330	
	taud	2.573	2.618	2.682	2.683	2.694	2.704	2.697	2.613	2.525	2.498	2.507	2.545	
	Ebn at Noon	1013	1002	993	961	937	919	939	961	977	992	1001	1013	
	Edh at Noon	107	99	87	78	69	64	68	82	100	110	113	110	
All-Sky Solar Radiation	RadAvg	6.88	6.18	5.25	4.38	3.48	2.83	3.21	4.16	5.38	6.16	6.49	6.89	
	RadStd	0.47	0.55	0.41	0.27	0.23	0.22	0.25	0.33	0.42	0.55	0.66	0.61	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (13 neighbors)	+0.50	N/A	N/A	N/A	N/A	N/A	N/A	-66	+158	+86

Nomenclature: See separate page