

TAREE, Australia

WMO: 957840

Lat: 31.890S

Lon: 152.512E

Elev: 30

StdP: 14.68

Time Zone: 10.00 (AUS)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	38.9	41.0	27.6	21.6	60.0	30.5	24.6	57.6	20.8	60.0	18.7	60.0	2.9	270	0.404

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	17.3	93.1	71.8	89.2	71.3	85.9	71.0	76.1	86.2	74.7	83.3	73.5	81.1	12.2	70

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
73.6	125.2	79.1	72.0	118.6	77.4	71.4	116.1	76.8	39.6	86.6	38.3	83.5	37.2	81.1	82.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 20.6	18.2	16.1	DB	32.5	101.6	2.6	4.5	30.6	104.9	29.1	107.5	27.7	110.0	25.8	113.3	(4)
(5)			WB	31.7	79.6	2.4	1.9	30.0	81.0	28.6	82.1	27.3	83.2	25.6	84.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	64.7	74.4	73.5	70.8	65.8	60.0	56.3	54.5	56.0	60.9	64.6	68.6	71.7	(6)	
	DBStd	7.97	4.43	4.14	3.52	3.26	3.60	3.46	3.23	3.69	4.63	4.77	5.11	4.64	(7)	
	HDD50	6	0	0	0	0	0	2	3	1	0	0	0	0	(8)	
	HDD65	1285	0	0	1	27	159	262	326	281	141	66	18	4	(9)	
	CDD50	5373	757	659	645	474	311	189	142	187	327	451	559	672	(10)	
	CDD65	1179	292	239	181	52	5	0	0	2	18	53	127	210	(11)	
	CDH74	8427	2179	1576	958	279	43	2	5	36	314	566	976	1493	(12)	
	CDH80	2682	790	498	220	42	3	0	0	4	100	183	344	498	(13)	
(14) Wind	WSAvg	7.0	8.1	7.4	6.6	6.1	6.3	6.4	6.2	6.7	6.9	7.4	7.7	8.0	(14)	
(15) Precipitation	PrecAvg	46.9	4.9	4.9	7.1	4.5	4.5	3.9	2.1	2.0	2.0	3.2	3.9	3.7	(15)	
	PrecMax	94.9	13.7	14.3	28.0	17.6	14.0	13.5	8.5	8.7	6.7	12.6	11.9	12.3	(16)	
	PrecMin	21.9	0.7	0.7	0.2	0.0	0.2	0.1	0.0	0.0	0.0	0.2	0.4	0.4	(17)	
	PrecStd	14.5	3.0	3.3	6.5	4.3	3.9	2.8	1.9	2.1	1.7	2.9	2.6	2.6	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	98.5	97.0	90.1	84.5	78.6	72.0	73.8	78.5	90.7	91.8	94.6	96.8	(19)	
		MCWB	75.1	75.6	73.2	67.5	62.1	59.2	57.9	59.8	62.0	64.7	70.6	70.1	(20)	
	2%	DB	91.7	89.5	84.6	80.3	74.8	68.6	69.9	73.3	82.0	84.9	88.0	89.8	(21)	
		MCWB	74.7	74.0	71.7	66.9	62.0	57.9	55.6	56.6	62.1	65.1	70.1	72.6	(22)	
	5%	DB	87.7	85.6	82.2	77.0	71.7	66.4	66.5	69.8	76.9	79.9	83.8	85.2	(23)	
		MCWB	73.0	73.1	70.9	66.1	60.6	57.1	54.6	55.9	60.5	64.7	69.0	70.9	(24)	
	10%	DB	84.2	82.3	79.0	74.8	69.4	64.4	64.1	66.5	72.8	75.6	79.2	81.1	(25)	
		MCWB	71.7	71.5	69.4	64.7	59.9	56.7	54.0	55.0	59.3	63.4	67.9	69.5	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	78.5	78.7	75.7	70.9	66.8	63.7	62.5	63.5	67.2	71.1	76.2	76.2	(27)	
		MCDB	91.8	91.3	85.0	77.5	72.9	67.2	68.3	72.3	78.3	80.2	87.9	87.1	(28)	
	2%	WB	76.0	76.1	73.7	69.1	64.7	61.6	59.6	60.5	64.8	68.9	72.9	74.3	(29)	
		MCDB	86.5	84.8	81.2	75.3	70.6	65.1	64.4	66.9	73.8	77.6	82.6	83.9	(30)	
	5%	WB	74.6	74.6	72.2	67.6	63.0	60.0	57.6	58.7	63.0	67.0	70.8	72.7	(31)	
		MCDB	83.1	81.7	78.7	73.7	68.7	63.7	62.8	65.8	71.9	74.8	79.0	81.3	(32)	
	10%	WB	73.4	72.9	70.9	66.3	61.3	58.7	55.9	56.9	61.3	65.4	69.2	71.3	(33)	
		MCDB	80.4	79.5	76.8	72.4	66.8	62.4	61.1	64.1	70.2	72.8	76.3	78.5	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	17.3	16.4	16.7	17.7	19.4	17.6	20.6	22.4	23.0	20.8	18.3	18.0	(35)	
		MCDBR	24.6	22.6	21.9	23.0	23.5	21.2	26.0	28.8	31.0	29.9	27.2	25.6	(36)	
	5% WB	MCWBR	10.3	9.2	10.1	11.3	12.3	12.1	14.2	14.9	14.2	13.6	11.8	10.9	(37)	
		MCWBR	19.7	19.4	18.6	19.7	19.1	15.9	19.8	23.6	26.1	23.3	21.8	20.7	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.396	0.382	0.358	0.339	0.315	0.308	0.300	0.311	0.351	0.364	0.388	0.391	(40)	
		taud	2.452	2.516	2.574	2.598	2.616	2.630	2.634	2.588	2.467	2.469	2.447	2.459	(41)	
	Ebn at Noon		299	298	294	284	275	270	278	289	291	299	300	302	(42)	
		Edh at Noon	38	35	31	27	23	22	23	27	33	36	38	38	(43)	
(44) All-Sky Solar Radiation	RadAvg		2065	1827	1544	1270	1019	831	956	1249	1618	1821	1935	2056	(44)	
	RadStd		139	147	135	84	74	61	75	84	99	148	193	164	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.90	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (14 neighbors)		+0.79	N/A	N/A	N/A	N/A	N/A	N/A	-124	+288	+157

Nomenclature: See separate page