

CAPE BORDA, Australia

WMO: 958050

Lat: 35.7550S

Lon: 136.5958E

Elev: 519

StdP: 14.42

Time Zone: 9.50 (AUA)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	43.6	45.1	32.2	27.1	64.2	34.5	29.8	57.9	39.6	52.7	34.1	54.1	10.1	110	0.638

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	15.4	88.1	63.8	84.0	62.8	80.4	62.0	68.3	77.8	66.1	76.8	64.5	74.6	11.6	70

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.7	96.8	70.8	63.0	87.8	68.4	61.1	81.9	67.0	32.9	77.3	31.1	76.7	29.8	74.5	95.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 31.5	28.0	24.6	DB	40.5	94.9	1.6	3.8	39.4	97.7	38.4	99.9	37.5	102.1	36.4	104.9	(4)
(5)			WB	38.4	76.8	1.1	6.5	37.5	81.4	36.9	85.2	36.2	88.8	35.4	93.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	58.9	65.9	66.2	63.6	60.3	57.0	54.2	53.0	53.1	54.3	56.5	60.1	62.8
	DBStd	6.72	6.23	6.03	5.63	4.25	3.49	2.98	3.05	3.22	3.68	4.85	6.36	6.16
	HDD50	25	0	0	0	0	1	4	8	8	3	1	0	0
	HDD65	2560	58	47	95	154	248	325	372	370	320	271	181	119
	CDD50	3264	492	454	422	309	219	129	101	104	133	202	302	397
	CDD65	326	85	81	53	13	1	0	0	0	1	8	33	51
	CDH74	2708	830	687	346	31	0	0	0	0	0	31	271	512
	CDH80	869	314	222	79	1	0	0	0	0	0	2	74	177
Wind	WSAvg	13.3	13.9	13.1	12.3	11.4	12.3	13.6	14.5	14.0	14.2	13.6	13.4	13.4
Precipitation	PrecAvg	23.7	0.6	0.6	1.1	1.6	3.1	3.8	3.9	3.3	2.2	1.6	1.0	0.7
	PrecMax	33.6	2.4	3.0	4.6	6.2	6.6	7.6	8.5	5.7	5.7	3.7	2.6	2.7
	PrecMin	16.6	0.0	0.0	0.0	0.2	0.7	0.7	1.8	1.3	0.7	0.1	0.1	0.1
	PrecStd	3.9	0.6	0.7	1.0	1.4	1.3	1.5	1.5	1.2	1.1	1.0	0.7	0.6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	93.1	91.2	87.4	77.7	69.9	62.3	61.4	63.8	69.2	77.9	87.4	91.3
		MCWB	64.9	64.6	64.6	61.1	58.2	56.9	55.3	54.9	56.0	57.6	62.7	63.6
	2%	DB	88.0	86.5	81.8	73.6	66.0	60.8	59.8	61.2	65.7	72.6	80.8	84.7
		MCWB	64.1	63.9	62.7	59.0	58.5	55.9	54.2	54.1	55.6	56.0	60.0	61.1
	5%	DB	83.0	82.3	77.9	70.2	63.9	59.7	58.7	59.6	63.1	69.0	76.1	79.6
		MCWB	63.4	63.8	61.5	58.6	58.0	54.9	53.6	53.7	54.6	55.7	58.4	60.4
	10%	DB	78.3	78.1	73.9	67.5	62.3	58.7	57.7	58.1	60.6	65.4	71.7	74.7
		MCWB	62.4	62.6	61.1	58.3	57.1	54.1	52.9	53.1	54.2	55.1	57.8	59.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	71.1	71.7	69.8	64.6	61.8	59.0	57.6	57.5	59.1	61.5	65.7	70.3
		MCDB	80.9	82.5	77.6	69.7	64.6	60.6	59.5	60.4	63.9	68.8	78.9	74.2
	2%	WB	67.7	68.0	66.1	62.6	60.3	57.3	55.8	56.0	57.4	59.0	62.8	65.3
		MCDB	80.5	77.1	74.7	67.4	63.2	59.6	58.4	59.1	62.5	65.9	74.7	74.3
	5%	WB	65.5	65.8	64.1	61.3	59.2	56.1	54.7	54.8	56.1	57.5	60.9	63.1
		MCDB	77.7	76.7	72.3	66.6	62.5	58.8	57.7	58.2	60.9	64.7	71.2	73.9
	10%	WB	63.5	64.0	62.4	59.9	58.1	55.0	53.7	53.7	54.9	56.4	59.1	61.1
		MCDB	75.1	74.3	70.3	65.6	61.6	58.0	56.9	57.3	59.4	63.3	68.5	71.9
Mean Daily Temperature Range	5% DB	MDBR	16.2	15.4	13.2	11.0	8.2	6.9	6.8	7.8	9.5	12.0	14.3	15.4
		MCDBR	24.1	21.6	17.9	14.3	9.1	7.1	6.7	8.7	12.1	17.5	21.0	24.2
		MCWBR	9.7	9.8	9.2	7.8	6.3	5.7	5.6	6.2	7.3	8.3	9.0	10.3
	5% WB	MCDBR	19.9	17.4	15.3	11.4	7.7	6.3	6.3	8.0	10.5	14.0	17.7	19.0
		MCWBR	10.4	9.9	9.9	8.1	6.4	5.9	5.9	6.6	7.6	8.4	9.2	10.8
Clear-Sky Solar Irradiance	taub	0.337	0.333	0.322	0.317	0.308	0.300	0.299	0.305	0.330	0.342	0.334	0.331	
	taud	2.584	2.610	2.632	2.634	2.635	2.647	2.645	2.620	2.534	2.501	2.552	2.588	
	Ebn at Noon	317	311	303	286	271	265	272	286	295	305	316	320	
	Edh at Noon	33	31	28	25	22	20	21	25	30	34	34	33	
All-Sky Solar Radiation	RadAvg	2343	2011	1605	1144	795	647	708	995	1396	1794	2142	2312	
	RadStd	104	84	69	68	39	35	35	62	96	116	118	119	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	-1.26	+2.05	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (13 neighbors)	+0.65	N/A	N/A	N/A	N/A	N/A	N/A	-160	+268	+119	

Nomenclature: See separate page