

CAPE BORDA, Australia

WMO: 958050

Lat: 35.7550S

Lon: 136.5958E

Elev: 158

StdP: 99.44

Time Zone: 9.50 (AUA)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.4	7.3	0.1	3.9	17.9	1.4	4.3	14.4	17.7	11.5	15.2	12.3	4.5	110	0.638

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	8.5	31.2	17.7	28.9	17.1	26.9	16.7	20.2	25.4	19.0	24.9	18.0	23.6	5.2	70

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.7	13.8	21.5	17.2	12.5	20.2	16.1	11.7	19.5	58.6	25.2	54.5	24.9	51.5	23.6	35.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
14.1	12.5	11.0	4.7	34.9	0.9	2.1	4.1	36.5	3.6	37.7	3.1	38.9	2.4	40.5		
			3.5	24.9	0.6	3.6	3.1	27.4	2.7	29.5	2.3	31.6	1.9	34.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	14.9	18.8	19.0	17.6	15.7	13.9	12.3	11.7	11.7	12.4	13.6	15.6	17.1
	DBStd	3.74	3.46	3.35	3.13	2.36	1.94	1.65	1.69	1.79	2.05	2.69	3.53	3.42
	HDD10.0	14	0	0	0	0	1	2	4	4	2	1	0	0
	HDD18.3	1422	32	26	53	86	138	181	207	206	178	151	101	66
	CDD10.0	1813	273	252	234	172	122	72	56	58	74	112	168	221
	CDD18.3	181	47	45	29	7	1	0	0	0	1	4	18	28
	CDH23.3	1504	461	382	192	17	0	0	0	0	0	17	151	284
	CDH26.7	483	174	123	44	1	0	0	0	0	0	1	41	98
Wind	WSAvg	6.0	6.2	5.9	5.5	5.1	5.5	6.1	6.5	6.3	6.3	6.1	6.0	6.0
Precipitation	PrecAvg	603	16	14	27	41	78	96	100	85	57	40	25	19
	PrecMax	854	62	77	117	158	167	194	215	145	144	94	65	68
	PrecMin	421	0	0	1	6	17	19	46	34	17	3	3	2
	PrecStd	98	14	17	25	35	33	39	38	30	29	26	17	15
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	34.0	32.9	30.8	25.4	21.1	16.8	16.4	17.7	20.7	25.5	30.8	33.0
		MCWB	18.3	18.1	18.1	16.1	14.6	13.8	12.9	12.7	13.3	14.2	17.0	17.6
	2%	DB	31.1	30.3	27.6	23.1	18.9	16.0	15.4	16.2	18.7	22.6	27.1	29.3
		MCWB	17.8	17.7	17.1	15.0	14.7	13.3	12.3	12.3	13.1	13.3	15.5	16.2
	5%	DB	28.4	27.9	25.5	21.2	17.7	15.4	14.8	15.3	17.3	20.6	24.5	26.4
		MCWB	17.4	17.7	16.4	14.8	14.4	12.7	12.0	12.1	12.6	13.2	14.7	15.8
	10%	DB	25.7	25.6	23.3	19.7	16.8	14.8	14.3	14.5	15.9	18.6	22.1	23.7
		MCWB	16.9	17.0	16.2	14.6	13.9	12.3	11.6	11.7	12.3	12.8	14.4	15.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.7	22.0	21.0	18.1	16.5	15.0	14.2	14.2	15.1	16.4	18.7	21.3
		MCDB	27.2	28.0	25.3	20.9	18.1	15.9	15.3	15.8	17.7	20.5	26.0	23.4
	2%	WB	19.8	20.0	19.0	17.0	15.7	14.1	13.2	13.3	14.1	15.0	17.1	18.5
		MCDB	26.9	25.1	23.7	19.7	17.3	15.3	14.6	15.1	16.9	18.8	23.7	23.5
	5%	WB	18.6	18.8	17.9	16.3	15.1	13.4	12.6	12.7	13.4	14.2	16.1	17.3
		MCDB	25.4	24.8	22.4	19.2	17.0	14.9	14.3	14.6	16.0	18.2	21.8	23.3
	10%	WB	17.5	17.8	16.9	15.5	14.5	12.8	12.1	12.1	12.7	13.5	15.1	16.2
		MCDB	24.0	23.5	21.3	18.7	16.5	14.4	13.9	14.1	15.2	17.4	20.3	22.2
Mean Daily Temperature Range	5% DB	MDBR	9.0	8.5	7.3	6.1	4.5	3.8	3.8	4.4	5.3	6.7	7.9	8.6
		MCDBR	13.4	12.0	10.0	7.9	5.0	3.9	3.7	4.8	6.7	9.7	11.7	13.5
		MCWBR	5.4	5.4	5.1	4.3	3.5	3.1	3.1	3.5	4.0	4.6	5.0	5.7
	5% WB	MCDBR	11.1	9.7	8.5	6.3	4.3	3.5	3.5	4.4	5.8	7.8	9.8	10.6
MCWBR		5.8	5.5	5.5	4.5	3.6	3.3	3.3	3.7	4.2	4.7	5.1	6.0	
Clear-Sky Solar Irradiance	taub	0.337	0.333	0.322	0.317	0.308	0.300	0.299	0.305	0.330	0.342	0.334	0.331	
	taud	2.584	2.610	2.632	2.634	2.635	2.647	2.645	2.620	2.534	2.501	2.552	2.588	
	Ebn at Noon	998	981	956	903	855	836	858	902	930	960	995	1009	
	Edh at Noon	104	98	89	78	69	64	67	78	96	108	107	105	
All-Sky Solar Radiation	RadAvg	7.38	6.34	5.06	3.61	2.50	2.04	2.23	3.14	4.40	5.66	6.75	7.29	
	RadStd	0.33	0.26	0.22	0.21	0.12	0.11	0.11	0.20	0.30	0.37	0.37	0.38	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	-0.70	+1.14	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (13 neighbors)	+0.36	N/A	N/A	N/A	N/A	N/A	N/A	-89	+149	+66

Nomenclature: See separate page