

STENHOUSE BAY, Australia

WMO: 958060

Lat: 35.279S

Lon: 136.939E

Elev: 144

StdP: 14.62

Time Zone: 9.50 (AUA)

Period: 98-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	44.1	46.1	35.6	30.7	60.8	37.6	33.2	55.9	31.6	52.9	29.4	53.3	8.1	0	0.611

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	12.8	90.4	64.8	83.8	64.2	79.3	64.8	69.5	78.5	68.2	76.8	67.1	75.5	17.7	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
67.0	99.8	72.4	65.3	94.1	72.0	63.9	89.5	71.2	33.7	78.6	32.6	77.0	31.7	75.3	83.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 28.4	25.6	23.5	DB	40.5	103.9	1.3	5.3	39.6	107.7	38.8	110.8	38.0	113.8	37.0	117.7	(4)
(5)			WB	39.0	72.7	1.5	2.8	37.9	74.7	37.1	76.3	36.2	77.9	35.1	79.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	61.3	68.7	68.7	66.9	63.4	59.3	55.4	53.9	54.6	56.9	59.8	63.0	65.6
	DBStd	6.75	5.29	4.83	4.96	4.20	3.23	2.80	2.55	2.87	3.90	4.88	5.40	5.27
	HDD50	4	0	0	0	0	0	1	2	1	0	0	0	0
	HDD65	1835	10	8	26	78	180	288	343	324	247	180	101	50
	CDD50	4131	580	523	524	401	289	163	124	142	207	304	390	484
	CDD65	486	125	111	85	29	4	0	0	0	4	19	41	68
	CDH74	2667	689	495	412	149	15	0	0	0	21	169	292	425
	CDH80	1037	279	186	159	50	1	0	0	0	2	52	128	180
Wind	WSAvg	13.2	14.3	14.2	13.6	11.9	11.8	12.1	13.0	13.0	13.4	13.6	13.9	13.6
Precipitation	PrecAvg	19.9	0.6	0.6	0.7	1.3	2.2	3.1	3.1	2.8	2.2	1.4	0.9	0.8
	PrecMax	28.9	1.4	2.9	3.0	2.7	4.7	5.9	5.2	4.2	4.9	3.5	3.4	2.7
	PrecMin	12.8	0.1	0.0	0.0	0.0	0.6	1.2	1.7	0.8	0.7	0.0	0.1	0.1
	PrecStd	4.1	0.4	0.7	0.7	0.7	1.0	1.1	0.9	1.1	1.0	0.8	0.7	0.6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	99.7	96.8	94.4	87.5	75.9	66.1	64.7	70.2	76.7	86.3	93.4	96.1
		MCWB	65.7	67.4	66.1	62.6	59.5	57.4	55.5	55.7	57.8	60.8	63.0	65.1
	2%	DB	86.6	84.6	83.2	77.8	70.2	63.3	61.9	65.1	71.7	78.6	81.9	84.0
		MCWB	66.4	66.5	64.6	61.6	59.4	56.1	54.7	55.1	57.1	58.7	62.5	63.4
	5%	DB	80.3	78.8	77.4	71.7	66.7	61.5	60.2	61.9	67.3	72.0	74.8	77.3
		MCWB	67.0	67.2	65.8	62.2	58.9	55.5	54.0	54.4	56.0	57.9	62.1	64.0
	10%	DB	76.2	75.4	73.5	68.9	64.3	60.0	58.7	59.8	63.5	66.7	70.4	73.2
		MCWB	66.1	66.3	65.1	61.2	58.0	54.8	53.1	53.7	55.8	57.9	61.5	63.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	71.2	72.1	71.2	66.1	63.6	59.7	58.1	58.5	61.1	63.4	67.3	68.7
		MCDB	82.7	81.9	79.0	74.0	67.7	62.6	60.8	63.1	70.0	75.5	79.8	78.8
	2%	WB	69.3	69.4	68.7	64.7	61.6	58.1	56.4	56.9	59.1	61.2	65.2	66.7
		MCDB	79.4	78.4	75.4	70.9	65.8	60.9	59.7	61.5	66.5	70.8	76.3	76.0
	5%	WB	68.0	68.1	67.0	63.4	60.2	56.9	55.2	55.6	57.7	59.7	63.5	65.3
		MCDB	77.3	76.1	74.4	69.2	64.4	59.9	58.5	60.1	64.0	67.8	72.0	74.4
	10%	WB	66.6	66.9	65.4	62.2	59.0	55.8	54.1	54.5	56.4	58.5	62.0	63.9
		MCDB	75.2	74.7	72.9	67.9	63.2	59.1	57.6	58.8	62.2	65.5	69.2	72.5
Mean Daily Temperature Range	5% DB	MDBR	12.8	11.8	11.2	10.6	9.8	9.1	9.4	10.4	12.0	12.7	12.5	12.7
		MCDBR	22.0	18.9	19.8	17.5	14.6	11.3	11.7	15.0	20.2	24.2	22.2	22.1
		MCWBR	7.2	7.0	7.8	8.1	7.9	7.0	7.3	8.0	9.2	9.2	7.9	7.7
	5% WB	MCDBR	17.0	15.1	15.6	13.4	11.7	9.4	10.1	12.5	15.7	17.7	17.8	17.0
		MCWBR	7.3	7.1	7.5	7.4	7.4	6.6	7.4	7.9	8.6	8.5	7.7	7.6
Clear-Sky Solar Irradiance	taub	0.343	0.340	0.326	0.319	0.310	0.303	0.300	0.310	0.333	0.342	0.341	0.335	
	taud	2.574	2.598	2.626	2.633	2.638	2.639	2.644	2.604	2.530	2.504	2.538	2.582	
	Ebn at Noon	315	309	302	286	272	265	272	285	295	305	314	319	
	Edh at Noon	33	31	29	25	22	21	22	25	31	34	35	34	
All-Sky Solar Radiation	RadAvg	2366	2047	1644	1188	826	681	743	1026	1417	1819	2164	2318	
	RadStd	111	91	64	70	37	37	33	64	104	116	117	104	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.41	N/A	N/A	+1.98	N/A	N/A	N/A	-184	+218	N/A
(47) Regional (24 neighbors)		+0.76	N/A	N/A	N/A	N/A	N/A	N/A	-176	+290	+126

Nomenclature: See separate page