

DARTMOOR, AustraliaWMO: **958220**Lat: **37.9222S**Lon: **141.2614E**Elev: **169**StdP: **14.61**Time Zone: **10.00 (AUS)**Period: **09-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	33.9	36.5	32.5	27.1	44.7	34.9	29.9	45.4	22.0	54.4	20.0	54.7	1.2	60	0.522

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	24.1	94.9	65.8	90.0	65.4	85.1	64.5	69.4	83.6	67.7	81.8	66.2	80.2	11.0	330

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.8	95.9	71.3	64.0	89.7	69.8	62.3	84.4	68.1	33.6	83.5	32.2	81.1	31.0	80.4	75.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 20.5	18.3	16.4	DB	29.8	106.3	1.1	4.3	29.0	109.4	28.3	111.9	27.7	114.3	26.9	117.5	(4)
(5)			WB	29.7	73.4	1.2	1.7	28.8	74.6	28.1	75.6	27.5	76.5	26.6	77.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	57.1	66.1	66.4	63.2	58.3	53.2	49.3	48.9	49.8	52.0	55.7	59.7	62.7	(6)	
	DBStd	8.45	7.40	6.52	6.66	5.40	4.48	3.57	3.53	3.87	4.59	6.08	7.36	6.97	(7)	
	HDD50	215	0	0	0	1	15	54	63	50	24	7	1	0	(8)	
	HDD65	3284	71	54	118	212	368	470	498	471	390	298	202	132	(9)	
	CDD50	2799	500	460	409	251	114	34	30	45	85	185	291	395	(10)	
	CDD65	392	106	94	62	12	2	0	0	0	1	11	42	62	(11)	
	CDH74	4861	1367	984	651	169	5	0	0	0	6	203	610	866	(12)	
	CDH80	2267	740	468	274	42	0	0	0	0	0	64	264	415	(13)	
(14) Wind	WSAvg	7.3	8.4	8.2	7.4	5.9	6.2	5.6	7.2	7.6	7.4	7.9	7.8	8.2	(14)	
(15) Precipitation	PrecAvg	28.6	1.4	1.2	1.4	2.1	2.6	3.9	3.6	3.7	3.1	2.3	1.7	1.7	(15)	
	PrecMax	36.7	5.2	2.8	2.7	4.6	6.3	6.9	6.1	6.6	5.5	4.7	4.6	5.3	(16)	
	PrecMin	18.1	0.2	0.2	0.2	0.3	0.6	1.1	1.7	1.1	1.1	0.7	0.6	0.5	(17)	
	PrecStd	4.5	1.3	0.7	0.7	1.1	1.3	1.4	1.1	1.5	1.0	1.2	0.9	1.1	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	105.2	98.8	94.6	86.1	72.2	61.9	61.4	68.1	74.4	87.2	93.0	99.1	(19)	
		MCWB	66.7	67.9	65.8	62.8	57.5	55.5	55.1	57.0	59.9	63.5	65.8	65.0	(20)	
	2%	DB	95.7	92.1	87.7	78.4	67.3	59.0	58.4	63.2	69.5	79.9	87.7	91.0	(21)	
		MCWB	66.3	66.5	64.9	60.5	57.1	54.5	54.1	54.9	57.1	62.1	64.2	64.8	(22)	
	5%	DB	88.5	86.0	81.0	73.9	63.9	57.4	56.6	59.3	65.1	73.3	81.7	83.7	(23)	
		MCWB	65.6	66.1	63.6	59.8	56.7	53.9	52.8	53.2	55.7	59.1	63.5	64.1	(24)	
	10%	DB	80.7	79.4	75.4	68.4	61.0	55.8	55.2	56.8	61.3	68.3	74.6	77.1	(25)	
		MCWB	64.2	64.7	62.9	58.6	56.3	52.9	51.9	51.9	54.3	57.7	62.1	62.6	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	71.5	72.4	69.1	65.4	61.2	58.1	57.4	58.7	61.1	66.5	69.3	71.3	(27)	
		MCDB	88.7	84.5	82.7	76.2	65.4	59.3	59.2	65.6	70.3	78.2	83.4	78.6	(28)	
	2%	WB	69.1	69.0	66.9	62.9	59.5	55.9	55.6	56.3	58.5	62.5	67.0	67.5	(29)	
		MCDB	85.0	83.2	80.3	71.9	63.8	57.5	57.6	61.0	66.1	76.3	81.2	79.9	(30)	
	5%	WB	67.1	67.1	65.3	61.5	58.2	54.7	54.0	54.4	56.7	60.5	64.8	65.4	(31)	
		MCDB	82.6	81.3	77.1	69.2	62.0	56.3	55.6	58.1	63.1	71.4	78.4	78.9	(32)	
	10%	WB	65.1	65.4	63.7	60.0	56.7	53.4	52.6	52.9	55.1	58.4	62.5	63.4	(33)	
		MCDB	79.4	77.5	73.1	66.3	60.2	55.1	54.4	56.2	60.8	66.5	73.5	76.3	(34)	
(35) Mean Daily Temperature Range	MDBR		24.1	21.9	20.0	18.6	13.8	13.0	12.3	13.9	15.9	20.0	21.5	23.1	(35)	
	5% DB	MCDBR	38.2	34.2	30.9	29.1	18.4	15.0	13.1	17.5	22.7	31.3	34.7	36.2	(36)	
		MCWBR	12.2	11.6	11.6	13.5	11.1	11.6	9.6	11.0	12.4	15.4	13.7	13.0	(37)	
	5% WB	MCDBR	29.4	27.1	24.5	21.7	15.0	12.6	11.9	15.9	19.4	26.9	29.3	28.4	(38)	
		MCWBR	11.9	11.5	11.0	11.2	10.6	10.7	9.7	10.8	11.8	14.5	13.3	12.3	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.342	0.338	0.326	0.316	0.308	0.302	0.303	0.317	0.340	0.340	0.338	0.338	(40)	
	taud		2.514	2.537	2.571	2.584	2.585	2.591	2.585	2.535	2.457	2.463	2.497	2.516	(41)	
	Ebn at Noon		314	308	299	283	266	258	265	278	289	304	313	317	(42)	
	Edh at Noon		35	33	30	25	22	20	22	26	32	35	36	36	(43)	
(44) All-Sky Solar Radiation	RadAvg		2291	1968	1541	1072	716	576	627	900	1276	1701	2015	2247	(44)	
	RadStd		128	101	74	71	38	40	35	47	95	131	130	144	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (23 neighbors)		+0.70	N/A	N/A	+1.62	N/A	N/A	N/A	-173	+238	+70

Nomenclature: See separate page