

DARTMOOR, AustraliaWMO: **958220**Lat: **37.9222S**Lon: **141.2614E**Elev: **52**StdP: **100.71**Time Zone: **10.00 (AUS)**Period: **09-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	1.1	2.5	0.3	3.9	7.0	1.6	4.3	7.4	9.8	12.4	8.9	12.6	0.5	60	0.522

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	13.4	34.9	18.8	32.2	18.6	29.5	18.1	20.8	28.7	19.8	27.7	19.0	26.8	4.9	330

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.8	13.7	21.8	17.8	12.8	21.0	16.8	12.1	20.0	60.3	28.6	57.0	27.3	54.2	26.9	24.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.2	8.2	7.3	-1.2	41.3	0.6	2.4	-1.7	43.0	-2.0	44.4	-2.4	45.7	-2.9	47.5		
(5)			-1.3	23.0	0.7	0.9	-1.8	23.7	-2.1	24.2	-2.5	24.7	-3.0	25.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	13.9	19.0	19.1	17.3	14.6	11.8	9.6	9.4	9.9	11.1	13.2	15.4	17.1		
	DBStd	4.69	4.11	3.62	3.70	3.00	2.49	1.99	1.96	2.15	2.55	3.38	4.09	3.87		
	HDD10.0	119	0	0	0	1	8	30	35	28	13	4	1	0		
	HDD18.3	1824	39	30	66	118	204	261	277	262	217	166	112	73		
	CDD10.0	1555	278	256	227	139	63	19	17	25	47	103	162	219		
	CDD18.3	218	59	52	34	7	1	0	0	0	1	6	23	34		
	CDH23.3	2701	759	547	362	94	3	0	0	0	3	113	339	481		
(13)	CDH26.7	1259	411	260	152	23	0	0	0	0	0	36	147	231		
(14)	Wind	WSAvg	3.3	3.8	3.7	3.3	2.6	2.8	2.5	3.2	3.4	3.3	3.5	3.7		
(15) Precipitation	PrecAvg	727	36	30	36	53	67	98	92	93	80	59	42	43		
	PrecMax	933	133	70	68	116	161	175	155	167	139	120	116	134		
	PrecMin	459	5	4	4	8	15	28	43	27	28	19	14	12		
	PrecStd	114	32	18	17	28	33	36	28	39	25	30	24	27		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	40.7	37.1	34.8	30.0	22.4	16.6	16.3	20.0	23.6	30.7	33.9	37.3		
		MCWB	19.3	20.0	18.8	17.1	14.2	13.1	12.8	13.9	15.5	17.5	18.8	18.4		
	2%	DB	35.4	33.4	31.0	25.8	19.6	15.0	14.6	17.3	20.8	26.6	30.9	32.8		
		MCWB	19.0	19.2	18.3	15.8	13.9	12.5	12.3	12.7	14.0	16.7	17.9	18.2		
	5%	DB	31.4	30.0	27.2	23.3	17.7	14.1	13.7	15.2	18.4	22.9	27.6	28.7		
		MCWB	18.7	18.9	17.6	15.5	13.7	12.2	11.6	11.8	13.2	15.1	17.5	17.9		
	10%	DB	27.1	26.3	24.1	20.2	16.1	13.2	12.9	13.8	16.3	20.2	23.7	25.0		
		MCWB	17.9	18.2	17.2	14.8	13.5	11.6	11.1	11.0	12.4	14.3	16.7	17.0		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.9	22.5	20.6	18.6	16.2	14.5	14.1	14.8	16.2	19.1	20.7	21.9		
		MCDB	31.5	29.2	28.2	24.6	18.6	15.2	15.1	18.7	21.3	25.7	28.6	25.9		
	2%	WB	20.6	20.5	19.4	17.2	15.3	13.3	13.1	13.5	14.7	16.9	19.4	19.7		
		MCDB	29.4	28.4	26.8	22.1	17.7	14.1	14.2	16.1	18.9	24.6	27.3	26.6		
	5%	WB	19.5	19.5	18.5	16.4	14.5	12.6	12.2	12.5	13.7	15.8	18.2	18.6		
		MCDB	28.1	27.4	25.0	20.7	16.7	13.5	13.1	14.5	17.3	21.9	25.8	26.0		
	10%	WB	18.4	18.5	17.6	15.6	13.7	11.9	11.4	11.6	12.8	14.7	16.9	17.4		
		MCDB	26.3	25.3	22.8	19.1	15.7	12.9	12.5	13.4	16.0	19.2	23.1	24.6		
(35) Mean Daily Temperature Range	5% DB	MDBR	13.4	12.1	11.1	10.3	7.7	7.2	6.9	7.7	8.9	11.1	11.9	12.9		
		MCDBR	21.2	19.0	17.2	16.2	10.2	8.3	7.3	9.7	12.6	17.4	19.3	20.1		
		MCWBR	6.8	6.4	6.4	7.5	6.1	6.5	5.3	6.1	6.9	8.5	7.6	7.2		
	5% WB	MCDBR	16.4	15.1	13.6	12.0	8.3	7.0	6.6	8.8	10.8	14.9	16.3	15.8		
		MCWBR	6.6	6.4	6.1	6.2	5.9	5.9	5.4	6.0	6.6	8.1	7.4	6.8		
(40) Clear-Sky Solar Irradiance	taub		0.342	0.338	0.326	0.316	0.308	0.302	0.303	0.317	0.340	0.340	0.338	0.338		
	taud		2.514	2.537	2.571	2.584	2.585	2.591	2.585	2.535	2.457	2.463	2.497	2.516		
	Ebn at Noon		991	971	943	891	837	813	835	876	912	958	988	999		
	Edh at Noon		111	104	93	80	69	64	68	83	102	111	112	112		
(44) All-Sky Solar Radiation	RadAvg		7.22	6.21	4.86	3.38	2.26	1.82	1.98	2.84	4.02	5.36	6.35	7.08		
	RadStd		0.40	0.32	0.23	0.22	0.12	0.13	0.11	0.15	0.30	0.41	0.41	0.45		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (23 neighbors)		+0.39	N/A	N/A	+0.90	N/A	N/A	-96	+132	+39

Nomenclature: See separate page