

EDENHOPE, Australia

WMO: 958320

Lat: 37.0222S

Lon: 141.2658E

Elev: 155

StdP: 99.48

Time Zone: 10.00 (AUS)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 7	(b) 1.5	(c) 2.5	(d) -2.0	(e) 3.3	(f) 24.1	(g) -0.3	(h) 3.7	(i) 17.1	(j) 11.9	(k) 10.9	(l) 10.2	(m) 11.7	(n) 1.2	(o) 80	(p) 0.528

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 1	(b) 15.5	(c) 37.2	(d) 18.5	(e) 34.6	(f) 18.0	(g) 32.2	(h) 17.6	(i) 20.5	(j) 29.7	(k) 19.5	(l) 29.2	(m) 18.7	(n) 28.5	(o) 5.3	(p) 340

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.3	13.4	21.9	16.8	12.2	21.0	15.6	11.3	20.7	59.4	29.6	56.3	29.5	53.6	28.6	24.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 10.0	(b) 8.5	(c) 7.5	(e) -0.6	(f) 41.5	(g) 1.0	(h) 2.1	(i) -1.3	(j) 43.0	(k) -1.8	(l) 44.2	(m) -2.4	(n) 45.4	(o) -3.1	(p) 46.9		
(4) 10.0	(5) 8.5	(6) 7.5	(7) -0.6	(8) 41.5	(9) 1.0	(10) 2.1	(11) -1.3	(12) 43.0	(13) -1.8	(14) 44.2	(15) -2.4	(16) 45.4	(17) -3.1	(18) 46.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	14.6	20.9	20.7	18.5	15.0	11.9	9.4	9.1	9.7	11.4	13.8	16.5	18.6		
	DBStd	5.50	4.53	4.21	4.35	3.46	2.67	2.01	1.96	2.30	2.82	3.89	4.38	4.54		
	HDD10.0	141	0	0	0	1	10	35	42	33	14	6	1	0		
	HDD18.3	1727	19	20	52	112	201	269	287	267	210	151	88	52		
	CDD10.0	1817	339	298	264	151	68	16	13	24	54	124	197	267		
	CDD18.3	360	100	85	57	12	1	0	0	0	1	11	34	60		
	CDH23.3	5043	1473	1062	714	131	3	0	0	1	8	174	514	964		
(14) Wind	WSAvg	3.6	4.0	3.9	3.5	3.1	3.3	2.9	3.6	3.6	3.6	3.8	3.8	3.9		
	PrecAvg	607	28	19	27	42	61	70	82	77	69	58	41	30		
	PrecMax	910	152	58	89	146	155	147	218	154	127	163	118	136		
	PrecMin	345	3	0	1	0	7	13	29	27	21	5	6	0		
	PrecStd	122	25	16	20	33	32	34	35	32	31	33	27	24		
	DB	41.5	37.7	37.2	30.6	22.8	17.0	16.7	20.9	24.5	31.7	35.0	39.3			
	MCWB	19.8	19.4	18.1	16.7	14.2	11.9	11.8	13.0	15.0	16.5	18.3	18.2			
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	2% DB	38.0	35.1	33.2	26.9	20.1	15.3	14.7	18.1	21.5	27.9	32.2	35.8			
	2% MCWB	18.4	18.5	18.0	15.2	13.3	11.5	10.9	11.8	13.4	15.5	17.3	17.4			
	5% DB	34.6	32.8	30.4	24.1	18.1	14.1	13.5	15.7	19.0	24.6	29.4	32.1			
	5% MCWB	18.2	18.3	16.9	14.4	13.0	11.2	10.5	11.0	12.4	14.5	16.6	16.7			
	10% DB	31.2	29.9	27.2	21.6	16.3	13.1	12.5	13.9	16.9	21.7	25.8	28.8			
	10% MCWB	17.2	17.4	16.4	13.8	12.6	10.6	10.0	10.4	11.6	13.6	15.7	15.9			
	WB	21.7	21.3	20.2	17.7	15.8	13.2	13.0	13.7	15.6	18.6	20.3	20.7			
(28) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	MCDB	30.4	31.8	28.4	26.7	19.4	15.0	14.5	18.4	22.2	26.7	29.6	29.7			
	2% WB	20.7	20.0	19.0	16.6	14.7	12.3	12.0	12.5	14.2	16.5	18.9	19.0			
	2% MCDB	29.9	29.5	28.3	22.6	17.8	14.2	13.5	16.3	19.4	23.3	28.3	28.0			
	5% WB	19.6	19.2	18.2	15.6	13.9	11.7	11.2	11.6	13.1	15.3	17.7	17.9			
	5% MCDB	29.9	28.9	27.0	21.2	16.7	13.5	12.7	14.8	17.7	22.6	25.7	28.6			
	10% WB	18.5	18.4	17.3	14.7	13.0	11.0	10.5	10.8	12.1	14.2	16.5	16.9			
	10% MCDB	29.5	27.7	25.5	19.8	15.7	12.6	12.0	13.4	16.1	20.8	24.3	27.5			
(35) Mean Daily Temperature Range	MDBR	15.5	14.4	13.2	11.1	8.2	7.8	7.1	8.2	9.7	12.2	13.7	15.0			
	5% DB	20.3	18.3	17.4	15.2	10.3	8.9	7.8	10.9	13.0	17.2	18.9	20.4			
	5% MCWBR	6.1	5.7	5.8	6.3	5.6	5.9	5.2	6.2	6.7	7.4	6.8	6.3			
	5% WB	15.9	15.0	14.1	11.5	8.4	7.6	6.8	9.2	11.1	14.4	15.8	16.0			
	5% MCWBR	6.2	5.6	5.8	5.6	5.1	5.4	4.9	5.8	6.2	7.1	6.4	5.9			
(40) Clear-Sky Solar Irradiance	taub	0.336	0.331	0.316	0.308	0.301	0.298	0.295	0.306	0.326	0.334	0.334	0.333			
	taud	2.502	2.528	2.568	2.573	2.571	2.570	2.575	2.527	2.461	2.443	2.479	2.498			
	Ebn at Noon	998	980	957	905	851	823	849	892	929	965	994	1005			
	Edh at Noon	113	105	94	81	71	66	70	84	102	113	115	114			
(44) All-Sky Solar Radiation	RadAvg	7.51	6.59	5.18	3.63	2.43	1.97	2.13	3.00	4.15	5.51	6.56	7.32			
	RadStd	0.42	0.32	0.23	0.22	0.12	0.15	0.12	0.16	0.32	0.43	0.44	0.41			

Historical Trends

		Heating		Cooling		Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46) Station Only	DBAvg	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A
(47) Regional (26 neighbors)		+0.39	N/A	N/A	+0.90	N/A	N/A	-96	+132	+39

Nomenclature: See separate page