

TATURA, Australia

WMO: 958360

Lat: 36.4378S

Lon: 145.2672E

Elev: 374

StdP: 14.50

Time Zone: 10.00 (AUS)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	31.2	33.2	28.4	22.7	48.0	30.4	24.8	47.1	26.4	53.3	21.5	52.6	1.9	170	0.524

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	26.7	97.6	66.5	93.2	65.4	89.4	64.7	70.8	83.6	69.0	83.0	67.4	82.4	10.5	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
67.4	102.1	74.5	64.8	93.2	73.6	62.6	86.2	72.2	34.8	82.7	33.3	82.2	32.0	82.6	77.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
25.7	20.9	18.1	DB	27.4	105.4	2.0	3.4	25.9	107.8	24.8	109.8	23.6	111.8	22.2	114.3	
			WB	26.8	74.3	2.1	2.4	25.3	76.0	24.1	77.4	22.9	78.7	21.3	80.5	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	59.0	72.6	71.2	66.9	59.7	52.5	48.2	47.2	48.2	52.1	57.9	64.3	68.3	(6)
	DBStd	10.70	7.22	6.41	6.40	5.81	4.56	3.88	3.83	3.99	5.19	6.20	7.09	7.05	(7)
	HDD50	330	0	0	0	3	24	79	104	84	32	4	0	0	(8)
	HDD65	2989	13	16	51	178	389	505	553	521	388	236	97	42	(9)
	CDD50	3620	700	593	525	293	100	24	16	28	95	250	428	568	(10)
	CDD65	805	248	189	111	17	0	0	0	0	2	17	75	146	(11)
	CDH74	9998	3150	2072	1210	176	1	0	0	0	30	329	1088	1942	(12)
	CDH80	4479	1640	932	461	27	0	0	0	0	6	96	433	884	(13)
(14) Wind	WSAvg	8.5	10.4	9.6	8.7	7.0	7.0	7.0	7.5	7.9	8.4	9.2	9.7	10.0	(14)
(15) Precipitation	PrecAvg	18.8	1.5	0.9	1.3	1.4	2.0	1.8	2.0	1.9	1.9	1.6	1.3	1.3	(15)
	PrecMax	33.6	5.8	6.5	4.7	4.6	4.8	5.6	4.2	4.4	4.4	5.9	3.5	4.6	(16)
	PrecMin	7.1	0.0	0.0	0.0	0.0	0.2	0.1	0.3	0.2	0.4	0.0	0.1	0.0	(17)
	PrecStd	5.6	1.3	1.4	1.1	1.1	1.3	1.2	0.9	1.0	1.1	1.3	0.9	1.2	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	105.2	101.3	95.7	83.5	71.8	63.0	61.7	67.2	77.8	88.6	94.8	100.7	(19)
		MCWB	67.4	69.0	66.2	62.6	57.3	54.5	53.3	55.1	56.7	60.6	63.6	65.3	(20)
	2%	DB	99.2	94.0	89.4	78.7	67.8	60.0	58.4	62.6	71.6	82.4	89.7	94.6	(21)
		MCWB	67.0	67.1	65.0	61.0	56.8	52.9	51.8	53.0	56.1	59.6	62.6	64.8	(22)
	5%	DB	93.9	89.7	85.1	75.3	64.5	57.9	56.4	59.7	67.2	77.1	85.1	89.2	(23)
		MCWB	65.9	66.1	63.7	59.6	55.7	51.8	50.8	51.4	55.1	58.3	62.0	63.5	(24)
	10%	DB	89.1	85.6	80.8	72.0	61.9	56.1	54.4	57.1	63.7	72.5	80.4	84.6	(25)
		MCWB	65.2	64.5	62.6	58.8	54.5	51.0	49.7	50.6	53.4	56.8	61.1	62.5	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	73.3	74.4	70.0	65.3	61.2	57.2	55.6	56.7	61.5	64.9	69.2	71.4	(27)
		MCDB	89.2	89.5	82.7	76.0	64.9	59.3	58.8	63.3	68.8	77.6	83.1	79.9	(28)
	2%	WB	70.8	70.7	67.7	63.0	58.2	54.5	53.1	54.5	58.5	62.1	66.4	68.5	(29)
		MCDB	85.9	82.5	80.5	73.4	64.5	57.8	56.2	60.2	67.4	73.9	79.9	80.4	(30)
	5%	WB	68.8	68.7	65.9	61.5	56.6	53.1	51.7	52.7	56.2	60.3	64.4	66.5	(31)
		MCDB	85.9	81.5	80.4	71.6	62.6	56.3	54.9	58.3	65.0	71.8	78.1	82.0	(32)
	10%	WB	67.0	66.8	64.3	59.9	55.2	51.7	50.3	51.0	54.2	58.4	62.6	64.7	(33)
		MCDB	84.8	81.1	78.1	69.8	61.2	55.1	53.7	56.3	62.3	70.8	75.8	81.4	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	26.7	24.8	23.8	22.8	19.8	16.5	15.4	18.1	21.6	24.7	25.4	26.3	(35)
		MCDBR	34.4	31.0	29.7	27.2	23.0	19.4	17.2	22.4	27.5	32.8	32.6	33.4	(36)
	5% WB	MCWBR	10.0	9.6	9.8	12.1	13.2	12.8	11.5	13.8	14.3	13.6	11.0	10.4	(37)
		MCWBR	27.2	24.4	24.0	22.2	19.9	14.5	14.3	19.1	22.5	25.1	24.8	25.2	(38)
(40) Clear-Sky Solar Irradiance	taub		0.345	0.344	0.322	0.312	0.301	0.292	0.290	0.300	0.326	0.329	0.344	0.336	(40)
		taud	2.478	2.495	2.552	2.551	2.557	2.582	2.585	2.534	2.447	2.463	2.461	2.499	(41)
	Ebn at Noon		314	307	302	286	271	265	273	286	295	308	312	318	(42)
		Edh at Noon	37	35	30	27	23	21	22	27	33	36	37	36	(43)
(44) All-Sky Solar Radiation	RadAvg		2454	2170	1774	1265	862	659	713	1011	1432	1894	2202	2449	(44)
	RadStd		128	115	80	59	55	75	39	76	121	149	110	109	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		+0.88	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (32 neighbors)		+0.88	N/A	N/A	+1.66	N/A	N/A	-34	-209	+313	+131

Nomenclature: See separate page