

WESTMERE, Australia

WMO: 958400

Lat: 37.7067S

Lon: 142.9378E

Elev: 744

StdP: 14.30

Time Zone: 10.00 (AUS)

Period: 07-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	31.9	34.0	29.1	23.8	52.1	31.7	26.8	46.0	29.5	52.1	26.8	51.6	2.6	20	0.589

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	29.2	96.7	65.0	91.6	63.8	87.1	63.0	68.6	82.9	66.9	81.8	65.3	80.6	14.6	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.1	95.4	71.1	62.8	87.9	69.5	60.9	82.0	68.0	33.3	83.5	31.8	81.6	30.6	80.8	75.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 24.4	21.8	19.5	DB	28.1	105.7	2.0	4.2	26.7	108.7	25.6	111.1	24.5	113.4	23.0	116.5	(4)
(5)			WB	27.9	71.8	2.0	2.5	26.5	73.6	25.3	75.0	24.2	76.4	22.7	78.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	55.9	66.7	66.2	62.6	57.1	51.9	47.4	46.8	47.3	49.7	53.6	58.8	62.8		
	DBStd	9.19	7.63	6.72	7.03	5.40	4.49	3.34	3.26	3.69	4.50	6.31	7.28	7.25		
	HDD50	426	0	0	1	6	29	90	107	101	60	27	5	0		
	HDD65	3725	67	62	134	244	406	527	564	549	461	360	218	133		
	CDD50	2561	518	453	391	219	88	14	8	17	49	138	269	397		
	CDD65	385	121	95	59	7	0	0	0	0	6	32	65			
	CDH74	6412	1984	1319	869	139	1	0	0	5	213	645	1237			
	CDH80	3009	1073	615	371	27	0	0	0	0	61	259	603			
(14) Wind	WSAvg	9.4	9.9	9.9	9.4	8.4	9.3	8.5	10.6	10.0	9.3	9.0	8.9	9.4		
(15) Precipitation	PrecAvg	21.1	1.4	1.5	1.0	1.5	1.6	2.0	2.1	2.4	2.2	2.0	1.9	1.5		
	PrecMax	30.3	5.2	3.9	2.0	3.7	3.6	3.7	3.4	5.5	5.4	3.8	3.5	4.3		
	PrecMin	14.0	0.0	0.1	0.2	0.1	0.2	0.7	0.9	0.8	0.9	0.2	0.7	0.0		
	PrecStd	4.1	1.2	0.9	0.6	0.9	0.8	0.7	0.6	1.1	1.0	1.1	0.8	1.0		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	105.6	98.6	97.7	83.7	70.7	59.6	59.0	64.7	72.6	86.7	93.2	101.0		
		MCWB	66.6	64.6	64.4	60.6	56.7	52.8	53.5	55.6	58.7	61.1	63.9	64.3		
	2%	DB	97.8	92.6	89.1	77.7	66.3	57.4	56.3	60.1	66.8	80.2	87.1	93.4		
		MCWB	65.1	65.0	64.1	58.6	55.7	52.2	51.3	52.7	56.7	59.9	62.7	62.8		
	5%	DB	91.7	87.8	83.3	73.7	63.0	55.8	54.5	57.1	62.7	74.0	82.1	86.8		
		MCWB	63.9	64.0	62.3	57.4	55.1	51.6	50.2	51.2	54.9	58.6	61.8	61.7		
	10%	DB	85.0	82.4	78.1	69.6	60.1	54.2	52.8	54.5	59.3	68.2	75.7	80.5		
		MCWB	63.0	63.3	61.2	56.4	53.9	50.8	49.1	50.0	53.0	56.9	60.5	61.2		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	71.1	71.1	67.3	63.5	59.6	54.9	54.6	56.4	60.0	64.7	68.4	70.0		
		MCDB	87.3	87.1	81.4	76.6	64.0	56.8	57.4	63.5	69.3	76.3	83.6	80.7		
	2%	WB	68.5	68.2	65.5	61.1	57.5	53.4	52.5	53.6	57.5	61.8	66.0	66.6		
		MCDB	85.2	80.3	80.8	69.3	63.5	56.0	55.2	58.3	65.0	74.2	79.1	81.2		
	5%	WB	66.5	66.3	64.1	59.4	55.9	52.3	50.9	52.0	55.4	59.4	63.8	64.4		
		MCDB	83.8	81.1	78.6	68.0	61.3	54.8	53.4	55.6	61.4	71.3	76.3	79.6		
	10%	WB	64.5	64.5	62.5	58.0	54.6	51.2	49.6	50.6	53.5	57.4	61.6	62.3		
		MCDB	82.0	78.9	74.0	66.5	59.4	53.6	52.0	53.9	58.9	67.9	73.5	77.9		
(35) Mean Daily Temperature Range	5% DB	MDBR	29.2	26.1	23.7	21.1	14.8	13.1	12.0	14.0	17.9	23.7	25.2	27.7		
		MCDBR	41.7	36.8	33.7	30.6	19.5	16.1	13.7	18.1	24.2	36.1	38.0	41.0		
		MCWBR	13.0	12.7	12.3	14.0	11.2	11.6	9.8	11.8	15.1	18.0	15.6	14.5		
	5% WB	MCDBR	30.4	29.6	26.8	22.8	15.9	13.9	12.2	16.4	22.2	30.0	29.9	30.8		
		MCWBR	12.0	11.9	11.4	11.3	10.0	10.6	9.3	11.4	14.2	16.5	13.5	13.0		
(40) Clear-Sky Solar Irradiance	taub		0.342	0.335	0.319	0.309	0.299	0.290	0.289	0.301	0.329	0.331	0.336	0.330		
	taud		2.471	2.509	2.551	2.558	2.564	2.580	2.581	2.528	2.431	2.437	2.457	2.501		
	Ebn at Noon		314	309	302	285	269	263	271	284	293	307	314	319		
	Edh at Noon		37	34	30	26	23	20	22	26	33	36	37	36		
(44) All-Sky Solar Radiation	RadAvg		2313	2010	1579	1095	729	579	636	903	1269	1689	2000	2252		
	RadStd		141	101	84	72	36	46	40	55	85	141	133	133		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (38 neighbors)	+0.86	N/A	N/A	+1.58	+0.74	N/A	N/A	-225	+301	+97

Nomenclature: See separate page