

MELBOURNE SCORESBY, AustraliaWMO: **958670**Lat: **37.8711S**Lon: **145.2561E**Elev: **80**StdP: **100.37**Time Zone: **10.00 (AUS)**Period: **98-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	2.3	3.4	0.5	4.0	8.9	1.4	4.2	8.5	9.9	12.5	8.5	12.9	0.3	40	0.459

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	12.1	34.5	19.5	32.1	19.0	29.9	18.6	21.5	29.5	20.5	28.3	19.7	27.3	4.2	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
19.2	14.1	23.8	18.1	13.1	22.8	17.1	12.3	22.3	62.8	29.3	59.3	28.6	56.4	27.3	25.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.1	7.1	6.3	0.1	39.2	0.8	2.7	-0.5	41.2	-1.0	42.8	-1.4	44.3	-2.0	46.2		
(5)			-0.3	23.2	0.9	0.9	-1.0	23.8	-1.5	24.3	-2.0	24.8	-2.7	25.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	14.7	20.2	20.1	18.4	15.0	12.3	10.1	9.8	10.3	12.2	14.0	16.3	18.1
	DBStd	4.89	4.06	3.72	3.69	3.10	2.61	2.15	1.98	2.30	2.85	3.36	3.78	3.97
	HDD10.0	91	0	0	0	1	6	24	27	23	7	2	1	0
	HDD18.3	1609	23	21	45	108	188	246	263	248	185	143	86	53
	CDD10.0	1814	317	284	261	151	77	28	22	33	74	125	189	253
	CDD18.3	291	82	71	47	9	1	0	0	0	2	8	25	47
	CDH23.3	3327	952	749	492	78	1	0	0	0	9	111	321	613
CDH26.7	1384	457	321	188	12	0	0	0	0	1	25	108	272	
Wind	WSAvg	2.7	2.8	2.6	2.6	2.2	2.3	2.3	2.8	2.8	3.0	2.9	2.8	2.8
Precipitation	PrecAvg	893	60	60	63	79	70	84	73	78	90	87	76	72
	PrecMax	1191	114	178	108	201	146	167	139	120	172	167	166	169
	PrecMin	559	13	4	34	26	18	24	30	26	33	27	28	7
	PrecStd	160	27	46	20	40	33	32	27	27	38	37	36	39
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	39.7	36.0	35.2	28.2	22.2	18.0	17.0	20.1	24.4	29.6	32.4	37.1
		MCWB	21.0	19.9	19.3	16.3	14.1	12.8	11.5	13.1	14.9	16.8	18.6	19.3
	2%	DB	34.5	33.1	31.2	25.5	20.0	16.3	15.4	17.8	21.8	26.3	30.0	33.0
		MCWB	19.6	19.3	18.4	16.1	13.9	11.9	10.8	11.6	14.2	15.8	17.8	18.7
	5%	DB	31.7	30.7	28.5	23.5	18.4	15.0	14.3	16.2	19.8	23.7	27.2	29.6
		MCWB	19.3	19.2	18.0	15.5	13.1	11.3	10.2	11.0	13.1	14.9	17.3	18.3
	10%	DB	28.7	28.2	25.8	21.4	17.1	14.0	13.3	14.7	18.0	21.3	24.4	26.7
		MCWB	19.0	18.7	17.5	14.9	12.6	10.7	9.7	10.2	12.2	14.0	16.5	17.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	22.9	22.6	21.1	18.3	15.7	13.6	12.6	13.7	16.2	18.4	21.1	21.7
		MCDB	30.2	30.8	29.7	25.6	19.7	16.5	15.5	18.4	21.8	25.5	27.6	30.4
	2%	WB	21.7	21.2	19.8	17.1	14.5	12.6	11.5	12.4	14.7	16.8	19.4	20.1
		MCDB	30.1	28.6	27.2	22.7	18.4	15.2	14.3	16.8	20.6	23.7	26.2	28.4
	5%	WB	20.6	20.2	19.0	16.2	13.7	11.8	10.7	11.4	13.7	15.7	18.3	19.1
		MCDB	28.7	27.4	25.9	21.3	17.5	14.2	13.4	15.2	18.9	22.0	24.9	27.4
	10%	WB	19.5	19.3	18.0	15.4	13.0	11.1	10.1	10.6	12.6	14.5	17.1	18.1
		MCDB	27.7	26.1	24.5	20.5	16.5	13.6	12.7	14.0	17.4	20.5	23.4	25.5
Mean Daily Temperature Range	5% DB	MDBR	12.1	11.7	10.9	10.0	7.6	6.8	6.4	7.4	8.6	10.4	11.0	11.7
		MCDBR	18.1	16.8	15.9	13.7	9.6	8.5	7.5	9.6	11.5	15.5	16.5	18.2
		MCWBR	5.9	5.7	5.6	6.0	5.1	5.2	4.4	5.0	5.7	6.8	6.6	6.4
	5% WB	MCDBR	14.6	13.7	12.9	11.6	8.4	6.9	6.6	8.6	10.5	13.2	13.3	14.8
		MCWBR	5.9	5.7	5.3	5.6	4.9	4.5	4.3	5.0	5.6	6.5	6.4	6.3
Clear-Sky Solar Irradiance	taub	0.351	0.355	0.333	0.329	0.311	0.303	0.304	0.313	0.339	0.338	0.346	0.340	
	taud	2.505	2.500	2.562	2.546	2.583	2.593	2.580	2.544	2.463	2.490	2.493	2.531	
	Ebn at Noon	981	953	936	876	835	812	834	881	913	960	980	997	
	Edh at Noon	112	108	94	83	70	64	69	82	101	108	113	110	
All-Sky Solar Radiation	RadAvg	7.13	6.22	4.96	3.44	2.25	1.75	1.96	2.77	3.96	5.33	6.30	7.03	
	RadStd	0.44	0.33	0.28	0.20	0.14	0.15	0.10	0.19	0.29	0.43	0.37	0.40	