

DENILIKUIN, Australia

WMO: 958690

Lat: 35.5575S

Lon: 144.9458E

Elev: 311

StdP: 14.53

Time Zone: 10.00 (AUS)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	32.0	34.3	17.7	13.6	85.6	22.5	17.1	80.6	25.0	55.7	23.1	54.0	4.6	280	0.558

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	28.2	102.7	64.5	98.3	64.0	94.3	63.2	71.1	82.7	69.3	82.5	67.5	83.4	13.1	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
69.1	108.3	73.4	65.9	96.6	72.4	62.8	86.6	71.7	35.3	81.7	33.7	82.2	32.1	83.0	80.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.4	23.2	20.4	DB	28.3	109.1	2.4	3.7	26.6	111.8	25.2	114.0	23.9	116.1	22.2	118.8
			WB	27.9	73.9	2.6	2.7	26.1	75.8	24.5	77.4	23.1	78.9	21.2	80.9

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	61.5	76.3	74.6	69.8	62.1	54.3	49.1	48.3	49.9	54.4	60.7	67.5	71.7
	DBStd	11.76	8.04	7.38	7.21	6.19	5.00	4.05	4.01	4.38	5.77	7.15	8.02	7.86
	HDD50	234	0	0	0	1	14	64	83	55	15	2	0	0
	HDD65	2551	5	7	31	127	334	477	519	470	323	176	61	21
	CDD50	4421	815	689	613	363	146	37	29	51	147	333	524	674
	CDD65	1261	355	276	178	39	1	0	0	0	6	42	135	229
	CDH74	17017	5012	3417	2071	445	12	0	0	6	126	735	1954	3239
	CDH80	8580	2882	1773	915	108	0	0	0	0	28	274	934	1666
(14) Wind	WSAvg	10.2	11.7	11.2	10.6	9.0	8.9	8.6	9.0	9.5	10.2	10.9	11.3	11.7
(15) Precipitation	PrecAvg	15.5	1.4	1.0	1.2	1.0	1.5	1.3	1.4	1.5	1.7	1.4	1.2	1.3
	PrecMax	31.7	10.0	4.7	4.2	4.1	3.8	4.0	4.4	4.9	4.3	4.8	5.3	5.1
	PrecMin	6.6	0.0	0.0	0.0	0.0	0.1	0.3	0.0	0.1	0.2	0.0	0.1	0.0
	PrecStd	4.8	1.7	1.1	1.1	0.8	1.1	0.8	0.9	0.9	1.0	1.1	1.0	1.2
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	109.1	106.7	100.2	88.0	75.8	65.7	66.3	72.2	83.3	93.6	99.9	104.5
		MCWB	65.2	66.3	64.4	61.9	56.8	54.5	52.5	54.2	55.9	59.3	62.7	63.1
	2%	DB	103.8	99.7	94.0	82.8	71.2	62.1	61.4	66.8	77.4	87.2	94.5	99.2
		MCWB	65.3	65.5	63.8	59.9	56.2	53.2	51.5	52.2	55.3	58.3	61.8	63.1
	5%	DB	99.0	94.7	89.2	79.1	67.6	59.7	58.8	62.9	72.3	82.0	90.1	94.0
		MCWB	64.8	64.3	63.0	58.7	55.4	51.9	50.8	50.9	54.1	57.4	60.8	62.0
	10%	DB	94.0	90.3	84.9	75.3	64.4	57.6	56.4	59.7	67.4	76.9	85.3	89.4
		MCWB	63.9	63.9	61.9	58.2	54.2	51.2	49.9	49.9	52.8	56.3	59.9	61.5
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	74.1	74.9	70.8	65.3	61.1	57.5	57.1	57.0	61.1	65.6	69.4	74.0
		MCDB	80.7	82.0	78.4	75.5	65.4	61.1	60.2	64.1	66.5	77.4	81.4	78.7
	2%	WB	70.7	71.1	68.3	63.1	58.5	55.4	53.9	54.6	58.2	62.5	67.0	69.2
		MCDB	84.2	84.2	79.2	73.8	65.2	59.8	57.9	61.9	70.2	75.5	79.2	80.5
	5%	WB	68.6	69.4	66.1	61.4	57.0	53.8	52.2	52.6	55.8	60.4	64.9	66.2
		MCDB	86.5	82.4	80.7	72.5	63.7	57.8	56.8	60.3	69.0	73.4	78.5	81.6
	10%	WB	66.7	67.2	64.2	59.8	55.5	52.2	50.7	51.0	54.0	58.1	62.9	64.2
		MCDB	88.5	83.2	80.7	72.3	63.3	56.3	55.2	58.3	65.5	73.7	78.8	83.9
(35) Mean Daily Temperature Range	5% DB	MDBR	28.2	26.2	24.7	23.7	20.5	17.9	17.1	20.1	23.9	26.3	27.2	27.5
		MCDBR	33.1	31.5	28.9	28.2	23.7	21.1	19.8	25.1	30.8	33.1	32.5	32.5
	5% WB	MCWBR	9.3	8.9	9.1	11.2	11.7	12.8	11.8	12.8	13.0	12.0	9.6	9.4
		MCDWR	25.3	23.4	22.9	22.8	18.5	16.9	16.5	21.3	25.7	26.0	24.5	23.4
(40) Clear-Sky Solar Irradiance	taub		0.341	0.341	0.320	0.309	0.298	0.292	0.289	0.298	0.326	0.328	0.344	0.335
		taud	2.492	2.505	2.558	2.555	2.561	2.579	2.583	2.542	2.452	2.469	2.461	2.498
	Ebn at Noon		315	308	304	288	274	267	275	288	296	309	312	318
		Edh at Noon	36	35	30	27	23	21	23	27	33	35	37	36
(44) All-Sky Solar Radiation	RadAvg		2483	2200	1826	1329	930	735	801	1101	1530	1980	2263	2499
	RadStd		126	113	89	58	48	62	36	71	110	132	108	101

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (17 neighbors)		+0.79	N/A	N/A	+1.84	N/A	N/A	N/A	+268	+187

Nomenclature: See separate page