

DENILIQUIN, Australia

WMO: 958690

Lat: 35.5575S

Lon: 144.9458E

Elev: 95

StdP: 100.19

Time Zone: 10.00 (AUS)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	0.0	1.3	-8.0	1.9	29.8	-5.3	2.4	27.0	11.2	13.1	10.3	12.2	2.0	280	0.558

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	15.7	39.3	18.1	36.8	17.8	34.6	17.3	21.7	28.2	20.7	28.1	19.7	28.5	5.8	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.6	15.5	23.0	18.8	13.8	22.4	17.1	12.4	22.1	64.1	27.6	60.4	27.9	56.8	28.3	27.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.3	10.4	9.1	DB	-2.0	42.8	1.3	2.1	-3.0	44.3	-3.8	45.5	-4.5	46.7	-5.5	48.2	(4)
(5)			WB	-2.3	23.3	1.4	1.5	-3.3	24.4	-4.1	25.2	-4.9	26.1	-6.0	27.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	16.4	24.6	23.7	21.0	16.7	12.4	9.5	9.0	9.9	12.4	15.9	19.7	22.1	(6)	
	DBStd	6.54	4.47	4.10	4.00	3.44	2.78	2.25	2.23	2.43	3.21	3.97	4.45	4.37	(7)	
	HDD10.0	130	0	0	0	1	8	36	46	31	8	1	0	0	(8)	
	HDD18.3	1417	3	4	17	71	186	265	288	261	179	98	34	12	(9)	
	CDD10.0	2456	453	383	341	202	81	21	16	28	82	185	291	374	(10)	
	CDD18.3	701	197	153	99	22	1	0	0	0	3	23	75	127	(11)	
	CDH23.3	9454	2784	1898	1151	247	7	0	0	3	70	408	1086	1799	(12)	
	CDH26.7	4767	1601	985	508	60	0	0	0	0	16	152	519	926	(13)	
(14) Wind	WSAvg	4.6	5.2	5.0	4.7	4.0	4.0	3.8	4.0	4.2	4.5	4.9	5.1	5.3	(14)	
(15) Precipitation	PrecAvg	393	35	25	30	26	37	32	36	39	43	36	30	32	(15)	
	PrecMax	804	254	120	107	105	97	102	113	125	108	121	134	129	(16)	
	PrecMin	167	0	0	0	0	3	7	1	2	4	1	2	0	(17)	
	PrecStd	123	43	28	28	21	27	21	24	23	26	28	26	30	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	42.8	41.5	37.9	31.1	24.3	18.7	19.1	22.4	28.5	34.2	37.7	40.3	(19)	
		MCWB	18.4	19.1	18.0	16.6	13.8	12.5	11.4	12.3	13.3	15.2	17.1	17.3	(20)	
	2%	DB	39.9	37.6	34.4	28.2	21.8	16.7	16.3	19.3	25.2	30.7	34.7	37.3	(21)	
		MCWB	18.5	18.6	17.7	15.5	13.5	11.8	10.9	11.2	12.9	14.6	16.5	17.3	(22)	
	5%	DB	37.2	34.8	31.8	26.2	19.8	15.4	14.9	17.2	22.4	27.8	32.3	34.4	(23)	
		MCWB	18.2	18.0	17.2	14.8	13.0	11.1	10.5	10.5	12.3	14.1	16.0	16.7	(24)	
	10%	DB	34.5	32.4	29.4	24.1	18.0	14.2	13.6	15.4	19.7	25.0	29.6	31.9	(25)	
		MCWB	17.7	17.7	16.6	14.6	12.4	10.7	10.0	9.9	11.5	13.5	15.5	16.4	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	23.4	23.9	21.6	18.5	16.2	14.1	13.9	13.9	16.2	18.7	20.8	23.3	(27)	
		MCDB	27.1	27.8	25.8	24.2	18.5	16.2	15.7	17.8	19.2	25.2	27.4	25.9	(28)	
	2%	WB	21.5	21.7	20.2	17.3	14.7	13.0	12.2	12.5	14.6	16.9	19.4	20.7	(29)	
		MCDB	29.0	29.0	26.2	23.2	18.5	15.5	14.4	16.6	21.2	24.1	26.2	26.9	(30)	
	5%	WB	20.3	20.8	18.9	16.3	13.9	12.1	11.2	11.4	13.2	15.8	18.3	19.0	(31)	
		MCDB	30.3	28.0	27.1	22.5	17.6	14.3	13.8	15.7	20.6	23.0	25.8	27.6	(32)	
	10%	WB	19.3	19.6	17.9	15.4	13.0	11.2	10.4	10.6	12.2	14.5	17.2	17.9	(33)	
		MCDB	31.4	28.4	27.1	22.4	17.4	13.5	12.9	14.6	18.6	23.2	26.0	28.8	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	15.7	14.6	13.7	12.2	11.4	10.0	9.5	11.1	13.3	14.6	15.1	15.3	(35)	
		MCDBR	18.4	17.5	16.0	15.6	13.2	11.7	11.0	14.0	17.1	18.4	18.0	18.1	(36)	
	5% WB	MCWBR	5.2	4.9	5.1	6.2	6.5	7.1	6.6	7.1	7.2	6.6	5.4	5.2	(37)	
		MCWBR	14.0	13.0	12.7	12.7	10.3	9.4	9.2	11.8	14.3	14.4	13.6	13.0	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.341	0.341	0.320	0.309	0.298	0.292	0.289	0.298	0.326	0.328	0.344	0.335	(40)	
		taud	2.492	2.505	2.558	2.555	2.561	2.579	2.583	2.542	2.452	2.469	2.461	2.498	(41)	
	Ebn at Noon		994	972	957	909	863	842	866	908	934	974	984	1004	(42)	
		Edh at Noon	114	109	95	84	73	67	71	84	104	111	117	115	(43)	
(44) All-Sky Solar Radiation	RadAvg		7.83	6.93	5.76	4.19	2.93	2.32	2.52	3.47	4.82	6.24	7.13	7.88	(44)	
	RadStd		0.40	0.35	0.28	0.18	0.15	0.20	0.11	0.22	0.35	0.42	0.34	0.32	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (17 neighbors)	+0.44	N/A	N/A	+1.02	N/A	N/A	N/A	N/A	+149	+104

Nomenclature: See separate page