

YARRAM, Australia

WMO: 958900

Lat: 38.5647S

Lon: 146.7478E

Elev: 61

StdP: 14.66

Time Zone: 10.00 (AUS)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	32.3	34.7	31.4	25.8	34.3	33.6	28.2	38.3	31.5	53.5	28.9	52.5	2.7	0	0.571

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	20.8	90.2	67.2	84.9	66.6	80.5	65.9	70.8	80.9	69.2	78.9	67.8	76.4	13.7	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
68.1	103.4	73.0	66.6	98.0	71.9	65.1	93.0	71.0	34.8	79.7	33.4	79.7	32.2	76.4	81.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 27.5	24.7	22.3	DB	28.0	102.9	1.7	5.2	26.8	106.6	25.8	109.6	24.8	112.5	23.6	116.3	(4)
(5)			WB	27.9	76.4	1.8	2.3	26.6	78.0	25.5	79.3	24.5	80.6	23.2	82.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	56.9	65.6	65.5	63.1	58.3	53.4	49.6	49.0	49.6	52.3	55.6	59.1	62.1		
	DBStd	7.82	6.70	5.42	5.54	4.73	4.06	3.67	3.90	3.73	4.49	5.52	5.90	6.15		
	HDD50	212	0	0	0	1	12	52	66	53	21	6	1	0		
	HDD65	3251	72	53	106	209	360	463	496	477	382	300	199	134		
	CDD50	2722	482	433	407	249	118	39	35	41	91	178	274	375		
	CDD65	286	89	66	48	8	1	0	0	0	1	7	22	44		
	CDH74	2906	930	483	404	96	4	0	0	0	14	179	285	511		
	CDH80	1104	432	159	128	21	0	0	0	0	0	49	101	214		
(14) Wind	WSAvg	10.1	10.6	10.3	9.7	8.5	9.7	8.5	10.4	10.5	10.8	10.7	10.9	10.8		
(15) Precipitation	PrecAvg	33.9	2.3	2.4	2.1	3.0	2.3	3.6	3.1	3.3	3.4	3.0	3.1	2.6		
	PrecMax	43.7	6.3	5.6	5.6	7.8	6.3	8.9	7.1	7.2	10.1	5.9	7.9	6.1		
	PrecMin	23.4	0.4	0.2	0.7	1.0	0.7	0.8	0.8	1.1	1.0	0.6	0.7	0.8		
	PrecStd	6.0	1.3	1.3	1.1	1.8	1.3	1.9	1.4	1.4	1.7	1.3	1.8	1.6		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	101.1	91.8	90.1	83.4	73.5	64.1	65.2	67.7	76.1	85.4	89.3	96.2		
		MCWB	68.7	68.7	66.9	62.1	58.7	54.6	53.2	55.1	58.4	63.0	64.9	67.9		
	2%	DB	90.9	84.4	83.4	76.1	68.6	61.3	61.4	63.2	70.2	79.2	82.7	85.8		
		MCWB	68.3	67.9	65.8	61.6	57.6	54.5	52.5	54.1	57.7	61.3	64.7	66.6		
	5%	DB	83.8	79.5	78.2	71.6	65.0	59.4	58.7	60.1	65.6	73.2	75.8	78.9		
		MCWB	68.3	67.5	65.3	61.1	56.5	53.8	51.2	52.0	55.6	59.8	63.2	66.1		
	10%	DB	77.6	75.5	73.7	67.9	61.8	57.6	56.6	57.6	61.9	67.9	70.9	73.8		
		MCWB	65.9	65.7	64.0	60.4	55.2	52.7	50.5	50.8	54.3	58.7	61.9	64.2		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	73.3	72.6	71.5	66.8	61.4	58.8	56.0	57.3	61.1	66.4	69.3	72.2		
		MCDB	88.3	82.2	78.1	75.8	67.9	60.1	61.6	64.0	70.9	76.3	78.6	84.2		
	2%	WB	70.8	70.1	68.8	63.9	58.8	56.2	53.5	55.0	58.7	63.1	66.8	69.2		
		MCDB	82.1	79.3	77.0	70.9	64.2	59.1	58.9	60.9	66.4	74.8	77.3	78.7		
	5%	WB	69.1	68.6	67.1	62.5	57.3	54.6	52.2	53.1	56.7	60.8	64.5	66.8		
		MCDB	79.9	76.4	75.1	68.9	62.7	58.3	57.0	58.4	64.2	71.0	73.0	75.2		
	10%	WB	67.3	67.1	65.5	61.1	55.8	53.1	51.1	51.6	54.8	58.7	62.4	64.9		
		MCDB	77.0	73.5	73.0	66.8	60.9	57.0	55.6	56.3	61.1	67.0	69.7	73.0		
(35) Mean Daily Temperature Range	5% DB	MDBR	20.8	18.9	19.0	18.7	16.9	16.4	15.5	15.9	18.0	20.5	19.9	19.9		
		MCDBR	31.4	26.1	27.3	26.2	23.4	19.2	19.3	20.7	26.3	31.4	30.1	30.8		
		MCWBR	12.9	12.0	13.0	13.9	14.8	13.5	12.3	12.9	15.1	16.4	14.9	14.1		
	5% WB	MCDBR	25.8	20.6	22.3	22.0	20.6	17.6	16.3	18.6	23.0	27.8	25.1	24.7		
		MCWBR	12.0	10.8	11.6	13.1	13.7	13.4	11.4	12.6	14.4	16.1	14.2	12.8		
(40) Clear-Sky Solar Irradiance	taub		0.374	0.366	0.341	0.335	0.317	0.304	0.310	0.317	0.345	0.346	0.351	0.360		
	taud		2.447	2.490	2.556	2.546	2.574	2.598	2.571	2.549	2.466	2.483	2.495	2.478		
	Ebn at Noon		304	298	294	274	261	255	260	277	287	301	309	310		
	Edh at Noon		38	35	30	26	22	20	22	26	32	34	36	37		
(44) All-Sky Solar Radiation	RadAvg		2165	1857	1482	1044	707	569	647	904	1269	1671	1957	2175		
	RadStd		137	103	90	56	35	37	32	30	84	109	115	129		

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (29 neighbors)	+0.90	N/A	N/A	+1.42	N/A	N/A	-29	-238	+311	+110

Nomenclature: See separate page