

ALBURY, Australia

WMO: 958960

Lat: 36.0689S

Lon: 146.9508E

Elev: 540

StdP: 14.41

Time Zone: 10.00 (AUS)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	31.8	33.6	26.8	21.2	63.4	29.7	24.2	51.6	20.6	50.7	18.5	51.3	1.6	330	0.441

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	26.4	99.1	66.8	95.1	66.1	91.5	65.1	71.5	84.8	69.9	84.5	68.5	83.6	10.0	10

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
68.3	105.9	74.1	65.9	97.3	73.9	63.7	90.2	73.2	35.6	83.4	34.2	84.4	33.0	83.0	93.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 19.5	16.8	14.8	DB	28.7	105.2	1.4	3.5	27.7	107.7	26.8	109.8	26.1	111.8	25.0	114.3	(4)
(5)			WB	28.0	75.8	1.5	4.8	26.9	79.3	26.0	82.2	25.2	84.9	24.1	88.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	60.2	76.2	74.7	68.7	60.0	52.7	47.8	46.6	48.4	53.0	58.9	65.8	70.9
	DBStd	11.63	6.79	6.28	6.20	5.33	4.60	3.86	3.53	3.81	4.59	5.68	6.65	6.68
	HDD50	325	0	0	0	2	24	87	114	78	18	2	0	0
	HDD65	2843	4	5	34	165	383	515	569	515	359	205	69	20
	CDD50	4059	811	693	581	301	106	22	10	28	109	277	473	648
	CDD65	1102	350	278	150	14	0	0	0	0	0	15	92	203
	CDH74	13439	4364	3126	1625	207	4	0	0	0	16	301	1205	2591
	CDH80	6269	2334	1522	624	34	0	0	0	0	1	76	473	1205
Wind	WSAvg	5.4	6.7	5.9	5.4	4.0	3.9	3.8	4.5	4.9	5.8	5.9	6.6	7.0
Precipitation	PrecAvg	28.4	2.1	1.5	1.6	1.8	2.4	3.0	3.3	3.4	2.8	2.8	2.0	2.0
	PrecMax	37.9	7.1	4.3	4.8	6.1	6.8	6.7	7.6	6.5	5.2	7.5	3.8	4.8
	PrecMin	16.3	0.3	0.0	0.0	0.2	0.2	0.3	0.8	0.7	0.9	0.3	0.4	0.4
	PrecStd	5.7	2.0	1.3	1.3	1.7	1.8	1.5	1.7	1.6	1.2	1.8	1.1	1.5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	105.9	102.5	96.1	84.3	72.8	63.7	61.3	67.9	76.2	87.6	95.4	101.3
		MCWB	68.8	67.9	65.7	62.5	58.5	54.5	53.2	56.8	58.9	61.0	65.1	64.9
	2%	DB	100.7	96.8	90.5	79.1	68.3	60.7	58.6	63.3	71.5	81.2	90.0	95.7
		MCWB	67.4	67.4	65.3	61.4	57.2	53.1	51.5	53.6	58.8	60.6	63.5	65.1
	5%	DB	95.9	92.8	86.4	75.7	65.1	58.3	56.3	60.4	67.8	76.9	85.5	91.1
		MCWB	66.5	66.4	63.9	59.8	55.8	51.9	50.3	52.0	56.6	59.7	62.7	63.9
	10%	DB	91.7	89.2	82.9	72.5	62.4	56.1	54.2	57.5	64.5	72.6	80.9	86.7
		MCWB	65.8	65.5	62.7	58.5	54.8	51.0	49.2	50.5	54.6	58.3	61.7	63.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	73.1	77.2	71.5	66.3	62.0	57.4	55.7	58.0	62.1	66.5	70.4	71.1
		MCDB	89.0	86.2	81.4	76.7	65.4	60.1	58.4	64.2	70.8	78.1	84.4	83.7
	2%	WB	71.1	71.8	68.7	63.6	59.4	54.9	52.9	55.1	60.1	63.8	67.5	68.8
		MCDB	87.9	82.6	80.5	73.6	65.2	58.1	56.5	61.7	68.3	74.2	80.9	82.5
	5%	WB	69.7	69.9	66.8	61.7	57.4	53.2	51.2	52.9	58.0	61.8	65.6	67.0
		MCDB	87.2	82.8	80.0	71.6	63.2	56.8	54.9	58.9	65.8	72.1	78.1	82.5
	10%	WB	68.3	68.2	65.2	60.1	55.6	51.6	49.9	51.1	55.7	59.8	63.8	65.3
		MCDB	85.5	83.2	78.3	70.0	61.2	55.3	53.3	56.6	63.0	70.3	76.0	81.6
Mean Daily Temperature Range	5% DB	MDBR	26.4	25.0	24.6	23.7	20.0	17.3	16.2	18.7	21.0	23.6	24.7	26.3
		MCDBR	32.6	30.3	29.5	28.6	23.7	21.2	19.7	24.0	26.6	31.5	32.2	32.6
		MCWBR	9.0	9.8	10.6	12.9	13.1	13.6	13.0	14.7	14.6	14.0	11.1	10.2
	5% WB	MCDBR	25.8	23.1	23.5	24.0	19.6	17.3	16.5	20.9	23.0	24.5	24.7	25.6
		MCWBR	8.9	9.9	10.6	11.7	11.7	11.8	11.5	13.3	13.5	12.8	10.5	10.3
Clear-Sky Solar Irradiance	taub	0.364	0.351	0.321	0.315	0.302	0.291	0.288	0.298	0.329	0.329	0.346	0.349	
	taud	2.432	2.494	2.576	2.545	2.556	2.593	2.602	2.555	2.454	2.481	2.471	2.471	
	Ebn at Noon	308	305	303	285	271	266	274	288	295	308	312	314	
	Edh at Noon	38	35	30	27	23	21	22	26	33	35	37	37	
All-Sky Solar Radiation	RadAvg	2418	2107	1761	1274	874	664	717	999	1433	1896	2190	2425	
	RadStd	139	139	105	67	59	75	45	86	145	165	127	105	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
	+0.90	N/A	N/A	+2.38	N/A	N/A	N/A	N/A	N/A	N/A
Regional (27 neighbors)	+0.72	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+198	N/A

Nomenclature: See separate page