

MOUNT BAW BAW, AustraliaWMO: **959010**Lat: **37.838S**Lon: **146.275E**Elev: **5121**StdP: **12.17**Time Zone: **10.00 (AUS)**Period: **02-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	23.9	25.2	0.4	6.8	43.5	7.7	9.9	42.7	26.5	33.8	22.5	33.3	7.1	260	0.676

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	14.5	74.2	56.8	70.8	55.9	67.9	54.6	60.5	67.9	58.7	66.4	56.9	64.5	8.9	10

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
57.9	86.8	63.3	55.9	80.5	61.2	54.0	75.1	59.4	29.3	68.1	27.9	66.6	26.6	64.9	68.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 22.4	19.7	17.9	21.2	79.2	1.2	3.3	20.3	81.5	19.6	83.4	18.9	85.3	18.0	87.6		
(5)			20.4	63.7	1.2	2.2	19.5	65.4	18.8	66.7	18.1	67.9	17.2	69.6	(4)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	42.8	54.9	53.6	50.2	44.5	38.3	34.3	32.1	32.8	36.2	41.3	46.4	49.9	(6)	(7)
	DBStd	10.59	9.14	8.18	8.25	6.84	5.40	4.41	3.49	4.74	5.93	8.16	8.84	9.14	(7)	(8)
	HDD50	3320	56	55	102	188	364	471	554	534	416	289	172	119	(8)	(9)
	HDD65	8133	331	325	464	616	828	921	1019	999	865	733	557	475	(9)	(10)
	CDD50	694	208	155	107	22	1	0	0	0	1	20	65	115	(10)	(11)
	CDD65	32	17	5	4	0	0	0	0	0	0	0	0	6	(11)	(12)
	CDH74	109	68	17	4	0	0	0	0	0	0	0	0	20	(12)	(13)
	CDH80	11	7	3	0	0	0	0	0	0	0	0	0	1	(13)	(14)
	WSAvg	8.5	8.7	7.7	7.6	8.3	9.7	7.6	8.1	8.5	9.2	8.8	9.2	9.1	(14)	(15)
	PrecAvg	45.2	3.0	2.9	2.6	3.5	3.5	4.4	3.9	4.4	4.8	4.2	4.4	3.6	(15)	(16)
(16) Precipitation	PrecMax	56.6	6.0	7.0	5.6	12.0	7.4	10.5	6.3	7.2	10.0	7.0	7.6	7.8	(16)	(17)
	PrecMin	33.7	0.8	0.6	0.9	1.3	1.5	0.7	1.7	2.3	2.4	1.6	2.3	1.6	(17)	(18)
	PrecStd	6.1	1.3	1.8	1.1	2.2	1.3	2.3	1.2	1.3	1.7	1.5	1.5	1.3	(18)	(19)
															(19)	(20)
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	80.8	76.0	73.3	64.0	54.1	47.7	44.0	49.4	55.6	65.5	70.5	77.0	(20)	(21)
		MCWB	59.0	58.5	56.3	51.5	42.8	38.6	36.0	38.1	42.7	48.4	53.3	55.7	(21)	(22)
	2%	DB	75.2	71.4	68.3	59.0	50.1	44.5	40.9	45.8	51.6	60.9	65.9	71.5	(22)	(23)
		MCWB	58.3	57.0	53.8	49.5	43.0	37.5	35.2	37.5	42.2	47.0	51.7	54.4	(23)	(24)
	5%	DB	71.6	68.3	65.0	56.0	47.7	42.6	38.8	42.6	48.5	57.2	62.5	67.2	(24)	(25)
		MCWB	56.8	56.2	53.4	48.3	41.7	36.9	35.4	36.6	41.3	45.9	50.8	52.6	(25)	(26)
	10%	DB	68.4	65.0	61.6	53.4	45.8	40.6	37.1	39.9	45.7	53.8	59.3	63.5	(26)	(27)
		MCWB	55.5	54.4	51.9	46.7	40.3	36.6	34.8	35.8	39.7	44.9	49.7	51.8	(27)	(28)
	0.4%	WB	63.0	63.2	59.3	54.4	48.2	43.5	40.8	41.4	45.9	52.1	58.1	60.0	(28)	(29)
		MCDB	73.1	69.2	65.2	58.7	49.4	44.7	41.3	44.9	50.3	57.9	64.7	65.6	(29)	(30)
(30) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	60.9	60.4	56.8	51.6	45.4	41.4	38.2	39.8	44.3	49.7	54.9	57.1	(30)	(31)
		MCDB	69.4	67.0	63.9	56.7	47.8	42.3	38.9	43.1	48.6	55.4	60.6	64.9	(31)	(32)
	5%	WB	59.2	58.2	55.1	49.5	43.8	39.5	36.7	38.2	42.6	47.9	52.9	55.3	(32)	(33)
		MCDB	67.7	65.0	61.9	53.8	45.9	40.7	37.5	41.1	47.0	54.0	58.8	62.7	(33)	(34)
	10%	WB	57.3	56.2	53.3	48.1	42.2	37.8	35.2	36.4	40.6	46.3	51.1	53.6	(34)	(35)
		MCDB	65.9	62.7	59.7	52.4	44.5	39.2	36.2	38.9	44.7	52.3	57.0	61.2	(35)	(36)
	5% DB	MDBR	14.5	13.2	12.0	9.4	7.0	6.1	5.4	6.7	9.3	11.9	13.0	13.9	(36)	(37)
		MCDBR	16.5	15.7	13.9	11.7	9.8	9.3	7.8	10.5	13.3	15.3	15.3	16.8	(37)	(38)
		MCWBR	11.3	11.1	10.0	8.6	7.8	7.6	6.6	8.0	9.3	10.3	10.7	11.0	(38)	(39)
		MCWBR	15.5	14.2	13.0	10.5	8.4	7.4	6.6	9.5	12.2	14.1	14.3	14.2	(39)	(40)
(40) Clear-Sky Solar Irradiance	taub		0.299	0.298	0.281	0.273	0.257	0.248	0.259	0.255	0.276	0.282	0.288	0.295	(40)	(41)
		taud	2.574	2.593	2.640	2.640	2.676	2.703	2.639	2.672	2.594	2.599	2.607	2.584	(41)	(42)
	Ebn at Noon		328	322	316	299	287	282	283	302	312	324	330	331	(42)	(43)
		Edh at Noon	33	31	27	24	20	18	20	23	28	31	32	33	(43)	(44)
(44) All-Sky Solar Radiation	RadAvg		2223	1918	1552	1089	729	571	633	892	1267	1682	1976	2207	(44)	(45)
	RadStd		150	125	100	69	44	49	36	53	101	138	126	130	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (41 neighbors)		+0.88	N/A	N/A	+1.49	N/A	N/A	-32	-232	+310	+110	

Nomenclature: See separate page