

MOUNT BAW BAW, AustraliaWMO: **959010**Lat: **37.838S**Lon: **146.275E**Elev: **1561**StdP: **83.92**Time Zone: **10.00 (AUS)**Period: **02-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	-4.5	-3.8	-17.5	1.0	6.4	-13.5	1.4	6.0	11.8	1.0	10.1	0.7	3.2	260	0.676

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	8.0	23.4	13.8	21.6	13.3	19.9	12.6	15.8	19.9	14.8	19.1	13.8	18.1	4.0	10

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
14.4	12.4	17.4	13.3	11.5	16.2	12.2	10.7	15.2	50.3	20.0	47.1	19.2	44.0	18.3	20.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10.0	8.8	8.0	-6.0	26.2	0.7	1.8	-6.5	27.5	-6.9	28.6	-7.3	29.6	-7.8	30.9
			-6.4	17.6	0.7	1.2	-6.9	18.5	-7.3	19.3	-7.7	20.0	-8.2	20.9
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	6.0	12.7	12.0	10.1	6.9	3.5	1.3	0.1	0.4	2.3	5.2	8.0	9.9
	DBStd	5.88	5.08	4.55	4.58	3.80	3.00	2.45	1.94	2.63	3.29	4.53	4.91	5.08
	HDD10.0	1844	31	31	57	104	202	262	308	297	231	161	96	66
	HDD18.3	4518	184	181	258	342	460	512	566	555	481	407	309	264
	CDD10.0	386	116	86	59	12	1	0	0	0	1	11	36	64
	CDD18.3	18	9	3	2	0	0	0	0	0	0	0	0	3
	CDH23.3	61	38	9	2	0	0	0	0	0	0	0	0	11
	CDH26.7	6	4	2	0	0	0	0	0	0	0	0	0	1
(14) Wind	WSAvg	3.8	3.9	3.4	3.4	3.7	4.4	3.4	3.6	3.8	4.1	3.9	4.1	4.1
(15) Precipitation	PrecAvg	1147	77	73	67	88	89	111	98	112	123	107	111	92
	PrecMax	1438	153	178	141	305	187	266	160	183	253	178	194	198
	PrecMin	857	21	14	23	33	39	19	43	59	60	40	59	41
	PrecStd	155	32	46	27	55	32	58	30	33	43	37	37	34
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	27.1	24.5	22.9	17.8	12.3	8.7	6.7	9.7	13.1	18.6	21.4	25.0
		MCWB	15.0	14.7	13.5	10.8	6.0	3.6	2.2	3.4	5.9	9.1	11.9	13.2
	2%	DB	24.0	21.9	20.2	15.0	10.1	7.0	4.9	7.7	10.9	16.0	18.9	21.9
		MCWB	14.6	13.9	12.1	9.7	6.1	3.0	1.8	3.0	5.7	8.4	10.9	12.4
	5%	DB	22.0	20.1	18.3	13.4	8.7	5.9	3.8	5.9	9.2	14.0	17.0	19.6
		MCWB	13.8	13.5	11.9	9.1	5.4	2.7	1.9	2.6	5.2	7.7	10.4	11.4
	10%	DB	20.2	18.4	16.5	11.9	7.7	4.8	2.8	4.4	7.6	12.1	15.2	17.5
		MCWB	13.0	12.5	11.1	8.2	4.6	2.6	1.5	2.1	4.3	7.2	9.9	11.0
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	17.2	17.3	15.2	12.4	9.0	6.4	4.9	5.2	7.7	11.1	14.5	15.6
		MCDB	22.8	20.6	18.5	14.8	9.7	7.0	5.2	7.2	10.2	14.4	18.2	18.7
	2%	WB	16.1	15.8	13.8	10.9	7.4	5.2	3.5	4.3	6.8	9.8	12.7	13.9
		MCDB	20.8	19.4	17.7	13.7	8.8	5.7	3.8	6.2	9.2	13.0	15.9	18.3
	5%	WB	15.1	14.5	12.8	9.7	6.5	4.2	2.6	3.4	5.9	8.9	11.6	12.9
		MCDB	19.8	18.3	16.6	12.1	7.7	4.9	3.1	5.1	8.3	12.2	14.9	17.1
	10%	WB	14.1	13.4	11.9	9.0	5.7	3.2	1.8	2.5	4.8	7.9	10.6	12.0
		MCDB	18.8	17.1	15.4	11.3	7.0	4.0	2.3	3.8	7.0	11.3	13.9	16.2
(35) Mean Daily Temperature Range	5% DB	MDBR	8.0	7.3	6.7	5.2	3.9	3.4	3.0	3.7	5.2	6.6	7.2	7.7
		MCDBR	9.1	8.7	7.7	6.5	5.5	5.1	4.3	5.8	7.4	8.5	8.5	9.3
		MCWBR	6.3	6.1	5.6	4.8	4.3	4.2	3.7	4.5	5.2	5.7	5.9	6.1
	5% WB	MCDBR	8.6	7.9	7.2	5.8	4.6	4.1	3.7	5.3	6.8	7.8	7.9	7.9
		MCWBR	6.8	6.4	5.7	4.5	4.0	3.9	3.4	4.5	5.3	6.0	6.1	6.5
(40) Clear-Sky Solar Irradiance	taub	0.299	0.298	0.281	0.273	0.257	0.248	0.259	0.255	0.276	0.282	0.288	0.295	
	taud	2.574	2.593	2.640	2.640	2.676	2.703	2.639	2.672	2.594	2.599	2.607	2.584	
	Ebn at Noon	1035	1014	995	944	906	890	893	953	984	1020	1041	1044	
	Edh at Noon	105	98	86	75	62	56	64	71	89	97	101	105	
(44) All-Sky Solar Radiation	RadAvg	7.01	6.05	4.89	3.43	2.30	1.80	2.00	2.81	3.99	5.30	6.23	6.96	
(45)	RadStd	0.47	0.40	0.31	0.22	0.14	0.16	0.11	0.17	0.32	0.43	0.40	0.41	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (41 neighbors)		+0.49	N/A	N/A	+0.83	N/A	N/A	-18	-129	+172	+61

Nomenclature: See separate page