

THREDBO, Australia

WMO: 959090

Lat: 36.4917S

Lon: 148.2858E

Elev: 1368

StdP: 85.94

Time Zone: 10.00 (AUS)

Period: 97-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	-7.3	-6.5	-20.7	0.7	1.6	-17.9	0.9	1.2	25.5	-1.2	23.9	-1.6	5.8	310	0.916

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	8.1	21.0	12.6	19.3	11.9	17.9	11.1	14.3	18.0	13.4	17.1	12.5	16.2	7.1	330

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
13.1	11.1	15.0	12.0	10.3	14.3	11.0	9.6	13.7	44.4	18.1	41.8	17.1	39.3	16.2	19.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 21.9	19.5	17.3	DB	-9.1	23.4	0.8	1.7	-9.7	24.7	-10.1	25.6	-10.6	26.6	-11.2	27.8	(4)
(5)			WB	-9.7	15.7	0.7	1.0	-10.2	16.5	-10.6	17.1	-11.0	17.7	-11.6	18.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	4.6	12.0	11.0	8.8	5.5	1.8	-0.8	-2.2	-1.8	0.8	3.8	7.2	9.4	(6)	
	DBStd	5.92	4.07	3.65	3.53	3.12	2.95	2.57	2.05	2.47	3.05	3.96	4.21	3.94	(7)	
	HDD10.0	2209	27	28	63	137	253	323	379	367	276	194	103	57	(8)	
	HDD18.3	5018	199	205	294	384	512	573	638	626	526	451	334	276	(9)	
	CDD10.0	236	88	57	27	2	0	0	0	0	0	2	18	40	(10)	
	CDD18.3	2	2	1	0	0	0	0	0	0	0	0	0	0	(11)	
	CDH23.3	7	5	2	0	0	0	0	0	0	0	0	0	0	(12)	
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)	
(14) Wind	WSAvg	7.5	6.6	6.1	6.4	6.7	8.0	7.3	9.4	8.4	8.8	7.9	6.9	7.0	(14)	
(15) Precipitation	PrecAvg	1843	108	87	108	110	159	171	142	186	211	202	156	117	(15)	
	PrecMax	2656	269	272	303	305	342	496	326	381	375	397	346	217	(16)	
	PrecMin	1217	23	7	10	8	11	40	30	47	67	23	35	7	(17)	
	PrecStd	476	62	55	69	70	82	90	82	86	92	100	70	49	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	23.9	22.8	19.8	14.7	10.8	8.0	4.6	6.2	9.7	15.2	19.5	21.6	(19)	
		MCWB	14.1	14.2	11.5	8.4	4.9	1.1	1.5	1.6	4.9	7.9	11.0	11.9	(20)	
	2%	DB	21.7	19.8	17.7	13.1	9.0	5.7	3.0	4.4	7.9	13.0	17.1	19.2	(21)	
		MCWB	13.1	12.3	10.7	7.5	4.3	1.3	0.2	1.1	3.8	7.1	10.2	11.4	(22)	
	5%	DB	19.8	18.2	15.8	11.6	7.6	4.3	1.8	3.2	6.6	11.4	15.4	17.3	(23)	
		MCWB	12.3	11.6	9.9	6.9	3.6	1.2	-0.4	0.5	3.6	6.3	9.1	10.4	(24)	
	10%	DB	18.3	16.7	14.4	10.2	6.2	3.1	0.9	2.1	5.5	10.0	13.8	15.7	(25)	
		MCWB	11.6	11.0	9.4	6.3	2.6	0.6	-0.9	-0.1	3.0	5.9	8.3	9.9	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	15.8	15.8	13.9	10.9	8.1	4.9	3.6	3.7	6.3	9.8	12.7	13.7	(27)	
		MCDB	20.3	19.6	15.6	12.4	8.8	5.0	3.9	4.5	7.7	12.0	16.9	17.1	(28)	
	2%	WB	14.5	14.1	12.3	9.4	5.9	3.4	1.8	2.4	5.4	8.5	11.4	12.5	(29)	
		MCDB	19.0	17.3	15.3	11.7	7.3	4.0	2.0	3.3	6.6	11.0	15.0	16.5	(30)	
	5%	WB	13.7	13.2	11.4	8.2	4.8	2.3	0.7	1.4	4.5	7.5	10.3	11.6	(31)	
		MCDB	17.9	16.2	14.3	10.1	6.1	3.0	1.1	2.4	5.9	10.1	13.9	15.7	(32)	
	10%	WB	12.8	12.2	10.4	7.3	3.9	1.4	-0.2	0.4	3.4	6.5	9.3	10.7	(33)	
		MCDB	17.0	15.3	13.1	9.1	5.2	2.3	0.3	1.3	5.1	9.1	12.7	14.6	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	8.1	7.8	7.3	6.3	5.0	4.1	3.7	4.2	4.9	6.6	7.5	8.1	(35)	
		MCDBR	9.4	8.9	8.8	7.9	7.4	6.3	5.1	5.6	6.2	8.4	8.9	9.4	(36)	
	5% WB	MCWBR	5.3	5.1	5.8	5.7	5.3	4.9	4.4	4.7	5.0	6.0	5.7	5.5	(37)	
		MCWBR	8.3	7.5	7.5	6.1	5.7	4.6	3.9	4.7	5.2	7.3	7.8	8.3	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.361	0.313	0.282	0.273	0.259	0.248	0.245	0.253	0.278	0.289	0.299	0.305	(40)	
		taud	2.382	2.576	2.682	2.663	2.666	2.715	2.727	2.688	2.593	2.586	2.592	2.579	(41)	
	Ebn at Noon	Ebn at Noon	973	1001	998	951	911	900	923	961	986	1015	1030	1035	(42)	
		Edh at Noon	127	101	84	75	64	57	60	71	90	98	103	106	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	7.23	6.16	5.22	3.81	2.70	2.06	2.27	3.14	4.48	5.80	6.58	7.33	(44)	
	RadStd	RadStd	0.52	0.54	0.43	0.29	0.13	0.17	0.13	0.20	0.39	0.47	0.47	0.39	(45)	

Historical Trends

		DBAvg	Heating		Cooling		Degree-Days					
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47) Regional (33 neighbors)		+0.42	N/A	N/A	+0.98	N/A	N/A	N/A	N/A	+121	+57	(47)

Nomenclature: See separate page