

MOUNT MOORNAPA, Australia

WMO: 959130

Lat: 37.7481S

Lon: 147.1428E

Elev: 480

StdP: 95.69

Time Zone: 10.00 (AUS)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	3.0	3.8	-3.2	3.1	13.3	-1.7	3.5	10.5	9.3	10.6	8.0	9.9	3.6	0	0.470

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	11.4	32.9	18.0	30.1	17.7	27.8	17.3	20.9	26.8	19.8	25.7	18.8	24.5	3.2	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.3	14.9	22.7	18.1	13.8	21.4	17.0	12.9	20.6	62.8	26.8	58.8	25.8	55.3	24.4	25.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.5	6.4	5.7	DB	1.7	38.3	0.5	2.8	1.3	40.3	1.0	41.9	0.7	43.5	0.4	45.5	(4)
(5)			WB	0.4	22.7	0.6	1.4	0.0	23.7	-0.3	24.5	-0.6	25.3	-1.0	26.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	13.5	19.0	18.5	16.9	13.9	11.4	9.0	8.5	9.3	11.1	12.9	15.1	16.8	(6)
(7)		DBStd	4.98	4.45	4.08	4.00	3.27	2.71	2.17	2.04	2.52	3.11	3.83	4.22	4.17	(7)
(8)		HDD10.0	197	0	0	0	4	14	44	57	44	20	11	3	1	(8)
(9)		HDD18.3	1974	44	44	76	140	216	279	306	280	217	174	117	82	(9)
(10)		CDD10.0	1479	279	238	216	120	58	14	9	22	54	102	156	211	(10)
(11)		CDD18.3	214	64	48	33	6	0	0	0	0	1	8	20	33	(11)
(12)		CDH23.3	1981	663	409	255	27	0	0	0	0	8	76	194	349	(12)
(13)		CDH26.7	771	299	156	86	6	0	0	0	0	1	18	64	140	(13)
(14)	Wind	WSAvg	2.6	2.3	2.3	2.3	2.4	2.7	2.7	3.1	3.1	2.9	2.8	2.5	2.4	(14)
(15)	Precipitation	PrecAvg	799	57	70	61	69	47	87	54	58	58	79	86	72	(15)
(16)		PrecMax	1073	215	161	188	178	106	320	182	119	122	164	178	183	(16)
(17)		PrecMin	514	5	15	15	20	16	18	8	19	23	16	18	20	(17)
(18)		PrecStd	151	48	45	37	47	23	83	42	23	22	37	39	33	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	38.1	34.9	32.7	26.3	20.9	17.1	16.4	19.6	24.3	29.4	31.8	35.1	(19)
(20)			MCWB	19.2	18.6	17.6	16.0	13.4	12.0	9.7	11.3	13.3	14.9	16.5	18.1	(20)
(21)		2%	DB	33.1	31.1	29.1	23.1	18.6	15.1	14.5	16.9	21.1	25.4	28.3	30.5	(21)
(22)			MCWB	18.4	18.4	17.3	14.8	12.6	10.6	9.2	10.2	12.4	14.1	16.7	17.4	(22)
(23)		5%	DB	29.7	28.2	26.1	20.7	16.9	13.6	13.0	15.0	18.8	22.3	25.2	27.2	(23)
(24)			MCWB	18.4	18.1	16.8	14.4	11.9	9.7	8.6	9.4	11.4	13.6	15.6	17.0	(24)
(25)		10%	DB	26.8	25.5	23.4	18.9	15.5	12.2	11.6	13.5	16.7	19.7	22.4	24.2	(25)
(26)			MCWB	18.1	17.9	16.1	13.6	11.2	8.9	7.9	8.6	10.9	12.8	14.9	16.5	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	22.8	22.1	20.7	17.9	15.1	12.7	11.3	12.8	15.2	17.5	20.2	21.2	(27)
(28)			MCDWB	29.7	27.6	25.8	22.7	18.2	15.7	14.1	16.9	20.3	23.9	25.9	26.8	(28)
(29)		2%	WB	21.0	20.7	19.0	16.2	13.8	11.4	10.1	11.1	13.7	15.7	18.1	19.2	(29)
(30)			MCDWB	27.7	26.1	24.4	20.4	16.7	14.0	12.6	15.1	18.9	21.7	23.5	25.6	(30)
(31)		5%	WB	19.8	19.6	17.9	15.2	12.7	10.4	9.2	10.0	12.4	14.5	16.8	18.2	(31)
(32)			MCDWB	26.4	25.0	23.1	19.1	15.7	12.6	11.9	13.9	17.4	20.2	22.3	24.4	(32)
(33)		10%	WB	18.6	18.5	16.9	14.2	11.7	9.5	8.4	9.0	11.3	13.3	15.6	17.1	(33)
(34)			MCDWB	24.7	23.7	22.1	17.9	14.7	11.6	10.9	12.6	15.7	18.7	21.2	23.2	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	11.4	10.4	9.3	7.6	6.0	5.3	5.7	6.9	8.5	9.8	10.4	11.0	(35)
(36)			MCDBR	15.9	14.8	13.4	10.3	7.6	6.8	7.4	9.0	11.8	13.9	14.6	15.7	(36)
(37)			MCWBR	5.5	5.5	5.2	4.8	4.5	4.3	4.6	4.9	5.7	6.0	6.0	6.2	(37)
(38)		5% WB	MCDBR	13.1	12.1	11.0	9.0	6.9	6.0	6.4	8.2	10.3	11.8	12.2	12.8	(38)
(39)			MCWBR	6.0	5.9	5.4	5.0	4.6	4.2	4.4	5.0	5.9	6.3	6.4	6.4	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.361	0.342	0.319	0.309	0.287	0.277	0.281	0.286	0.308	0.318	0.326	0.367	(40)	
(41)		taud	2.450	2.535	2.589	2.590	2.638	2.659	2.633	2.618	2.549	2.545	2.553	2.418	(41)	
(42)		Ebn at Noon	971	967	952	900	867	849	865	915	948	981	1001	970	(42)	
(43)		Edh at Noon	119	104	91	80	66	60	65	76	93	102	106	124	(43)	
(44)	All-Sky Solar Radiation	RadAvg	6.82	5.88	4.86	3.48	2.42	1.91	2.16	3.00	4.18	5.41	6.19	6.91	(44)	
(45)		RadStd	0.47	0.42	0.35	0.24	0.13	0.14	0.12	0.16	0.33	0.39	0.44	0.42	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (37 neighbors)		+0.46	N/A	N/A	+0.81	N/A	N/A	N/A	-114	+161	+61

Nomenclature: See separate page