

CABRAMURRA, Australia

WMO: 959160

Lat: 35.9372S

Lon: 148.3778E

Elev: 4864

StdP: 12.29

Time Zone: 10.00 (AUS)

Period: 98-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	25.1	26.7	7.0	9.4	40.1	14.4	13.7	40.1	35.9	35.8	31.2	35.1	8.7	270	0.690

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	16.5	78.3	57.9	75.0	57.1	72.0	56.1	62.0	70.2	60.5	68.6	59.0	67.1	12.1	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
59.6	91.3	63.3	57.9	85.8	62.7	56.1	80.4	61.6	30.3	70.1	29.1	68.5	28.0	67.2	70.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 31.5	27.1	23.7	DB	22.6	84.0	1.2	3.5	21.7	86.5	21.0	88.5	20.3	90.4	19.4	92.9	(4)
(5)			WB	21.2	64.8	1.2	1.9	20.3	66.2	19.6	67.2	18.9	68.3	18.0	69.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	47.2	61.0	59.3	55.2	48.5	41.7	37.0	34.4	35.9	40.9	46.1	51.6	56.0		
	DBStd	10.97	7.58	6.69	6.70	6.03	5.35	4.56	3.87	5.02	6.04	7.28	7.68	7.44		
	HDD50	2256	9	8	27	95	262	389	482	439	279	166	72	28		
	HDD65	6568	167	179	309	495	723	839	947	903	724	587	405	290		
	CDD50	1247	351	269	190	49	3	0	0	1	5	44	120	215		
	CDD65	85	44	20	6	0	0	0	0	0	0	0	3	12		
	CDH74	392	229	89	14	0	0	0	0	1	0	0	6	53		
	CDH80	53	35	13	0	0	0	0	0	1	0	0	0	4		
	WSAvg	11.2	11.4	11.5	11.6	10.1	10.6	11.0	10.5	11.2	11.9	11.8	11.6	11.5		
	PrecAvg	65.9	4.0	2.7	3.4	4.3	6.5	6.3	8.0	7.8	6.8	6.6	5.0	4.6		
(15) Precipitation	PrecMax	94.4	11.7	9.0	8.6	14.9	16.1	15.0	15.7	15.7	11.9	14.6	10.7	13.6		
	PrecMin	28.0	0.0	0.0	0.4	0.4	1.2	0.7	2.1	1.8	1.9	1.2	0.4	0.4		
	PrecStd	15.2	2.2	1.9	2.2	2.8	3.7	3.3	3.8	3.7	2.5	3.5	2.4	2.8		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	84.5	82.1	76.0	65.9	57.1	50.3	46.6	53.2	59.2	67.3	73.7	79.6		
		MCWB	59.1	59.7	56.1	52.6	47.6	40.1	40.7	42.1	46.7	50.7	54.7	56.8		
	2%	DB	79.7	76.5	71.7	61.8	53.5	47.5	44.1	48.4	55.6	63.6	70.1	74.8		
		MCWB	59.0	57.8	55.4	51.2	46.2	40.1	39.2	40.4	46.2	49.7	53.5	56.0		
	5%	DB	76.0	73.0	68.4	59.1	51.2	45.4	42.0	45.6	52.8	60.4	66.7	70.9		
		MCWB	57.6	57.3	54.0	49.8	44.7	40.4	37.7	39.4	45.1	48.8	52.4	54.8		
	10%	DB	72.8	69.9	65.3	56.7	49.0	43.5	40.1	43.0	50.1	57.3	63.5	67.8		
		MCWB	56.8	55.8	53.1	48.9	43.5	39.5	36.7	38.4	43.6	47.5	51.7	54.0		
	0.4%	WB	63.8	65.1	61.7	56.2	51.8	45.7	44.7	45.9	50.5	54.9	59.8	61.2		
		MCDB	74.2	72.0	66.6	60.6	52.8	46.4	44.9	49.3	54.2	60.6	65.9	67.5		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	62.1	62.1	58.9	53.2	48.0	43.7	41.2	43.0	48.5	52.7	57.5	59.0		
		MCDB	72.2	68.6	65.3	58.2	51.2	45.1	42.4	45.7	52.5	57.9	63.6	67.1		
	5%	WB	60.7	60.2	57.1	51.6	46.3	42.0	39.3	41.1	46.8	50.8	55.6	57.4		
		MCDB	70.3	67.3	63.7	56.5	49.4	43.7	40.7	44.0	50.8	56.8	62.0	66.1		
	10%	WB	59.2	58.4	55.6	50.1	44.8	40.6	37.7	39.1	44.9	49.1	53.6	55.8		
		MCDB	68.9	65.7	61.7	54.7	47.7	42.5	39.1	42.1	49.0	55.3	60.8	64.5		
	5% DB	MDBR	16.5	15.5	13.9	11.4	8.7	7.4	6.9	8.7	11.0	13.4	14.1	15.6		
		MCDBR	17.9	17.6	16.0	12.6	11.0	9.9	9.9	12.6	13.8	15.4	15.7	17.7		
		MCWBR	8.8	7.9	8.3	7.6	8.0	7.5	7.5	8.8	8.8	9.3	8.6	8.9		
		MCWBR	15.8	14.3	13.0	10.9	9.6	8.1	8.1	11.3	12.0	13.6	13.1	14.8		
(35) Mean Daily Temperature Range	5% WB	MCWBR	9.3	9.1	8.0	7.5	7.3	6.9	7.0	8.9	8.6	9.4	8.6	9.0		
	taub		0.338	0.301	0.277	0.268	0.259	0.245	0.243	0.250	0.273	0.285	0.295	0.298		
		taud	2.449	2.616	2.687	2.671	2.642	2.714	2.718	2.685	2.595	2.581	2.592	2.591		
(40) Clear-Sky Solar Irradiance	Ebn at Noon		316	322	319	304	290	288	295	307	315	323	328	331		
		Edh at Noon	38	31	26	23	21	18	19	23	29	31	33	33		
	RadAvg		2339	2000	1698	1253	889	677	743	1020	1450	1878	2121	2367		
(44) All-Sky Solar Radiation	RadStd		157	168	138	89	46	61	44	75	134	161	156	128		

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46) Station Only	DBAvg	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(47) Regional (30 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		+0.77	N/A	N/A	N/A	N/A	N/A	N/A	+209	+97

Nomenclature: See separate page