

CABRAMURRA, Australia

WMO: 959160

Lat: 35.9372S

Lon: 148.3778E

Elev: 1482

StdP: 84.74

Time Zone: 10.00 (AUS)

Period: 98-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	-3.8	-2.9	-13.9	1.3	4.5	-9.8	2.0	4.5	16.1	2.1	13.9	1.7	3.9	270	0.690

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	9.2	25.7	14.4	23.9	14.0	22.2	13.4	16.7	21.2	15.8	20.3	15.0	19.5	5.4	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
15.3	13.0	17.4	14.4	12.3	17.0	13.4	11.5	16.5	52.7	21.2	49.9	20.3	47.2	19.5	21.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 14.1	12.1	10.6	-5.2	28.9	0.7	1.9	-5.7	30.3	-6.1	31.4	-6.5	32.5	-7.0	33.9		
(5)			-6.0	18.2	0.7	1.0	-6.5	19.0	-6.9	19.6	-7.3	20.2	-7.8	20.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	8.5	16.1	15.2	12.9	9.2	5.4	2.8	1.4	2.1	4.9	7.8	10.9	13.4		
	DBStd	6.09	4.21	3.71	3.72	3.35	2.97	2.53	2.15	2.79	3.36	4.04	4.26	4.14		
	HDD10.0	1253	5	4	15	53	146	216	268	244	155	92	40	16		
	HDD18.3	3649	93	99	172	275	402	466	526	502	402	326	225	161		
	CDD10.0	693	195	149	106	27	2	0	0	1	3	24	67	119		
	CDD18.3	47	24	11	3	0	0	0	0	0	0	0	2	7		
	CDH23.3	218	127	49	8	0	0	0	0	1	0	0	3	29		
	CDH26.7	29	19	7	0	0	0	0	0	1	0	0	0	2		
(14) Wind	WSAvg	5.0	5.1	5.1	5.2	4.5	4.7	4.9	4.7	5.0	5.3	5.3	5.2	5.2		
(15) Precipitation	PrecAvg	1674	102	68	86	108	164	160	202	199	173	168	126	116		
	PrecMax	2398	297	229	219	379	408	382	400	398	302	372	273	345		
	PrecMin	712	0	1	9	10	30	19	53	46	48	30	9	10		
	PrecStd	385	57	49	55	70	94	84	96	93	63	89	62	71		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	29.2	27.8	24.4	18.8	13.9	10.2	8.1	11.8	15.1	19.6	23.2	26.4		
		MCWB	15.0	15.4	13.4	11.5	8.7	4.5	4.8	5.6	8.2	10.4	12.6	13.8		
	2%	DB	26.5	24.7	22.0	16.6	11.9	8.6	6.7	9.1	13.1	17.5	21.1	23.8		
		MCWB	15.0	14.3	13.0	10.7	7.9	4.5	4.0	4.6	7.9	9.9	12.0	13.3		
	5%	DB	24.5	22.8	20.2	15.1	10.6	7.5	5.6	7.5	11.6	15.8	19.3	21.6		
		MCWB	14.2	14.1	12.2	9.9	7.1	4.7	3.1	4.1	7.3	9.3	11.4	12.6		
	10%	DB	22.7	21.1	18.5	13.7	9.4	6.4	4.5	6.1	10.1	14.1	17.5	19.9		
		MCWB	13.8	13.2	11.7	9.4	6.4	4.2	2.6	3.6	6.5	8.6	10.9	12.2		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	17.7	18.4	16.5	13.5	11.0	7.6	7.1	7.7	10.3	12.7	15.5	16.2		
		MCDB	23.5	22.2	19.2	15.9	11.6	8.0	7.1	9.6	12.3	15.9	18.9	19.7		
	2%	WB	16.7	16.7	14.9	11.8	8.9	6.5	5.1	6.1	9.2	11.5	14.1	15.0		
		MCDB	22.4	20.3	18.5	14.6	10.7	7.3	5.8	7.6	11.4	14.4	17.6	19.5		
	5%	WB	16.0	15.7	14.0	10.9	7.9	5.6	4.0	5.0	8.2	10.5	13.1	14.1		
		MCDB	21.3	19.6	17.6	13.6	9.7	6.5	4.8	6.7	10.5	13.8	16.7	19.0		
	10%	WB	15.1	14.7	13.1	10.1	7.1	4.8	3.1	4.0	7.1	9.5	12.0	13.2		
		MCDB	20.5	18.7	16.5	12.6	8.7	5.8	3.9	5.6	9.5	12.9	16.0	18.1		
(35) Mean Daily Temperature Range	5% DB	MDBR	9.2	8.6	7.7	6.3	4.8	4.1	3.8	4.8	6.1	7.5	7.9	8.7		
		MCDBR	9.9	9.8	8.9	7.0	6.1	5.5	5.5	7.0	7.7	8.5	8.7	9.8		
	5% WB	MCWBR	4.9	4.4	4.6	4.2	4.5	4.2	4.2	4.9	4.9	5.2	4.8	5.0		
		MCWBR	8.8	8.0	7.2	6.0	5.3	4.5	4.5	6.3	6.6	7.5	7.3	8.2		
(40) Clear-Sky Solar Irradiance	taub	taub	0.338	0.301	0.277	0.268	0.259	0.245	0.243	0.250	0.273	0.285	0.295	0.298		
		taud	2.449	2.616	2.687	2.671	2.642	2.714	2.718	2.685	2.595	2.581	2.592	2.591		
	Ebn at Noon	Ebn at Noon	997	1015	1005	959	914	907	929	968	992	1019	1035	1042		
		Edh at Noon	119	97	83	74	66	58	61	72	90	99	103	104		
(44) All-Sky Solar Radiation	RadAvg	RadAvg	7.37	6.30	5.35	3.95	2.80	2.13	2.34	3.21	4.57	5.92	6.68	7.46		
	RadStd	RadStd	0.49	0.53	0.44	0.28	0.14	0.19	0.14	0.24	0.42	0.51	0.49	0.40		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (30 neighbors)	+0.43	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+116	+54

Nomenclature: See separate page