

MOUNT GININI, Australia

WMO: 959250

Lat: 35.5292S

Lon: 148.7722E

Elev: 1760

StdP: 81.89

Time Zone: 10.00 (AUS)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	-5.4	-4.5	-18.1	0.9	2.4	-14.4	1.3	3.0	14.1	0.7	11.6	1.5	5.0	250	0.681

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	9.7	25.1	14.7	23.0	13.8	21.1	13.1	16.7	21.1	15.5	19.8	14.6	18.7	4.4	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
15.2	13.4	17.5	14.2	12.5	16.6	13.2	11.8	15.7	54.0	21.6	50.2	19.6	47.2	18.9	22.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.8	9.4	8.4	-7.1	28.8	0.7	2.0	-7.5	30.2	-7.9	31.4	-8.3	32.5	-8.8	33.9		
(5)			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	7.3	15.0	13.5	11.1	8.1	3.9	1.5	0.0	0.7	3.9	7.5	10.0	12.4		
	DBStd	6.02	4.21	3.47	3.37	3.09	2.78	2.44	2.25	2.62	3.35	4.00	4.03	4.07		
	HDD10.0	1507	8	7	27	72	188	256	310	287	183	99	49	21		
	HDD18.3	4066	120	142	225	307	446	506	568	546	432	337	250	187		
	CDD10.0	509	162	103	61	14	0	0	0	0	1	20	50	97		
	CDD18.3	27	16	5	1	0	0	0	0	0	0	0	1	4		
	CDH23.3	147	89	27	1	0	0	0	0	0	0	0	4	26		
	CDH26.7	16	11	3	0	0	0	0	0	0	0	0	0	2		
(14) Wind	WSAvg	4.3	4.1	3.8	4.0	3.7	4.8	4.3	4.9	4.8	4.8	4.5	4.3	4.1		
(15) Precipitation	PrecAvg	908	75	82	62	45	55	96	79	78	90	77	83	75		
	PrecMax	1321	227	208	167	173	208	252	168	160	191	190	221	178		
	PrecMin	496	2	10	10	0	8	35	28	12	14	15	22	20		
	PrecStd	180	47	56	37	39	38	51	33	41	42	41	48	42		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	28.0	26.7	22.4	18.1	12.4	8.7	7.4	9.4	15.1	19.7	23.6	26.5		
		MCWB	15.6	14.9	13.4	10.6	7.2	2.8	4.9	4.6	7.2	9.7	13.4	14.1		
	2%	DB	25.8	23.1	20.0	15.8	10.3	7.2	5.9	7.2	12.8	17.4	20.2	23.2		
		MCWB	15.0	13.7	12.2	9.8	6.2	3.1	3.1	3.4	6.4	9.5	11.4	13.7		
	5%	DB	23.8	21.0	18.1	13.9	9.0	5.9	4.6	5.9	11.0	15.6	18.5	21.1		
		MCWB	14.3	13.6	11.7	9.5	5.4	2.5	2.3	3.0	5.5	8.5	11.0	12.5		
	10%	DB	21.8	19.1	16.3	12.5	7.9	4.8	3.4	4.6	9.0	13.8	16.5	19.1		
		MCWB	13.6	12.6	11.3	8.4	5.1	2.2	1.3	2.0	4.8	7.9	10.4	11.7		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	17.9	18.1	15.5	13.5	10.0	6.4	6.4	6.2	8.7	11.9	15.5	16.6		
		MCDB	23.4	21.7	18.6	15.5	10.7	6.9	6.7	7.1	12.1	15.8	18.4	21.6		
	2%	WB	16.9	16.3	14.4	11.7	8.0	5.1	4.8	4.9	7.6	10.8	13.6	15.0		
		MCDB	22.1	19.4	17.4	14.0	9.0	5.8	5.2	6.6	11.2	14.1	17.3	19.2		
	5%	WB	16.0	15.1	13.5	10.3	6.9	4.1	3.3	3.7	6.6	9.9	12.2	14.0		
		MCDB	20.9	18.9	16.3	12.7	8.5	4.8	3.8	5.2	9.5	13.0	16.8	18.5		
	10%	WB	14.9	14.0	12.6	9.3	5.8	3.4	2.0	2.6	5.6	8.9	11.1	13.0		
		MCDB	19.7	17.3	15.2	11.6	7.0	4.2	2.6	4.0	8.3	12.8	15.6	17.7		
(35) Mean Daily Temperature Range	5% DB	MDBR	9.7	9.1	7.9	6.8	5.5	4.4	4.2	5.4	7.7	9.1	9.4	9.8		
		MCDBR	11.4	10.5	9.7	8.0	6.8	5.9	5.6	7.1	10.2	10.5	10.6	11.6		
	5% WB	MCWBR	6.2	5.8	5.9	5.1	5.4	4.9	4.8	5.5	6.5	6.3	5.8	6.0		
		MCWBR	9.9	8.8	8.2	6.8	5.9	4.9	4.3	6.2	8.8	9.0	9.2	9.7		
(40) Clear-Sky Solar Irradiance	taub		0.326	0.292	0.270	0.258	0.251	0.239	0.235	0.243	0.263	0.279	0.286	0.288		
		taud	2.493	2.658	2.723	2.722	2.678	2.744	2.769	2.722	2.640	2.607	2.630	2.637		
	Ebn at Noon		1010	1025	1014	974	928	920	944	979	1005	1027	1045	1054		
		Edh at Noon	114	93	81	71	64	56	58	70	86	97	99	100		
(44) All-Sky Solar Radiation	RadAvg		7.30	6.25	5.32	4.00	2.90	2.21	2.46	3.33	4.68	5.96	6.65	7.41		
	RadStd		0.51	0.53	0.44	0.30	0.15	0.20	0.16	0.25	0.43	0.52	0.52	0.44		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (26 neighbors)	+0.42	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+115	N/A

Nomenclature: See separate page