

BEGA, Australia

WMO: 959310

Lat: 36.6722S

Lon: 149.8192E

Elev: 138

StdP: 14.62

Time Zone: 10.00 (AUS)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	31.0	32.9	24.0	18.2	53.9	27.9	22.0	49.0	26.7	55.6	23.4	55.7	1.1	210	0.453

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	19.4	89.0	70.6	84.8	69.4	81.4	68.4	73.6	83.0	71.9	80.3	70.4	78.0	11.2	50

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
70.9	114.5	77.1	69.3	108.2	75.4	67.9	102.9	73.7	37.3	83.2	35.8	80.3	34.4	78.2	81.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years						
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
22.3	19.5	17.0	DB	27.2	100.3	1.3	5.2	26.2	104.0	25.4	107.0	24.7	109.9	23.8	113.6	
			WB	26.8	77.7	1.5	2.0	25.7	79.1	24.8	80.3	24.0	81.4	22.9	82.8	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	59.0	69.1	68.5	65.5	59.9	54.2	50.2	48.7	50.4	54.8	58.7	62.6	65.7
	DBStd	8.40	5.25	4.86	4.56	4.47	4.03	3.82	3.72	4.24	4.82	5.24	5.21	5.10
	HDD50	177	0	0	0	1	8	43	70	46	8	1	0	0
	HDD65	2661	17	17	49	164	334	443	505	454	310	208	108	52
	CDD50	3447	591	519	479	296	140	50	30	57	151	271	377	486
	CDD65	454	143	115	63	10	0	0	0	0	2	13	35	73
	CDH74	3541	1076	747	396	94	8	0	0	4	63	215	330	608
	CDH80	1080	388	220	94	16	1	0	0	0	12	64	90	195
(14) Wind	WSAvg	5.8	6.9	6.1	5.6	4.8	4.7	4.7	5.0	5.7	6.5	6.6	6.9	6.7
(15) Precipitation	PrecAvg	33.0	2.7	3.2	4.4	2.9	2.3	2.6	1.9	1.9	2.3	2.6	3.3	2.9
	PrecMax	65.7	9.0	21.1	19.4	14.6	11.2	13.6	8.6	8.8	7.5	14.5	11.9	9.9
	PrecMin	16.9	0.1	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.5	0.2	0.0
	PrecStd	12.2	2.1	3.6	4.5	3.7	2.7	3.2	2.2	2.0	1.9	2.6	2.8	2.4
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	95.5	92.4	87.8	81.9	74.3	68.2	68.6	72.7	81.4	87.4	88.6	93.3
		MCWB	72.7	71.8	70.7	65.0	59.4	55.0	53.1	55.4	59.8	62.8	68.9	71.4
	2%	DB	88.9	85.9	82.1	76.3	70.1	64.3	64.2	67.7	74.4	79.7	81.7	85.2
		MCWB	72.2	70.7	68.6	63.8	59.1	54.3	52.1	53.8	58.1	62.5	67.1	69.6
	5%	DB	84.0	82.0	78.2	72.8	67.1	61.8	61.4	64.4	70.0	74.5	77.5	80.2
		MCWB	70.9	70.0	67.4	62.5	57.4	53.2	50.9	52.5	57.6	61.6	66.0	68.0
	10%	DB	79.8	78.5	74.8	69.8	64.4	59.5	59.0	61.5	66.2	70.1	73.3	76.4
		MCWB	68.7	68.5	65.7	61.1	56.0	52.2	49.8	51.3	55.2	59.7	63.2	66.5
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	76.2	76.2	73.5	68.8	64.2	59.5	57.5	59.3	63.7	67.8	72.1	74.2
		MCDB	88.5	86.1	81.5	76.9	68.9	63.1	62.1	67.2	73.5	76.7	82.2	85.3
	2%	WB	73.6	73.2	70.9	66.1	61.5	56.9	54.8	56.5	60.9	65.1	69.0	71.5
		MCDB	83.9	81.2	77.9	72.5	66.5	60.8	59.5	64.1	70.0	73.6	78.3	81.1
	5%	WB	71.8	71.4	69.1	64.3	59.3	55.2	52.9	54.5	58.8	63.0	66.9	69.4
		MCDB	80.2	79.0	75.4	70.2	64.6	59.2	58.3	61.5	66.4	71.5	74.9	77.2
	10%	WB	70.1	69.8	67.4	62.4	57.3	53.5	51.2	52.5	56.8	61.1	65.0	67.5
		MCDB	77.7	76.6	73.2	67.8	62.5	57.9	57.4	59.2	64.1	68.2	71.4	74.3
(35) Mean Daily Temperature Range	5% DB	MDBR	19.4	18.2	18.9	21.0	22.0	20.6	22.8	23.7	22.8	22.1	19.4	18.9
		MCDBR	27.9	24.7	25.1	25.6	26.2	24.9	27.7	28.2	28.9	30.7	28.0	27.2
		MCWBR	12.7	11.7	12.9	14.2	15.8	15.7	16.9	16.0	15.1	15.4	14.1	13.3
		MCDBR	23.3	21.5	21.5	22.2	22.5	20.0	23.2	25.5	25.2	25.9	24.2	23.0
	5% WB	MCWBR	11.8	11.1	11.9	13.3	15.0	13.9	15.6	16.2	14.9	14.4	13.2	12.5
(40) Clear-Sky Solar Irradiance	taub		0.420	0.381	0.347	0.325	0.311	0.299	0.289	0.301	0.328	0.345	0.367	0.374
	taud		2.337	2.491	2.568	2.603	2.588	2.616	2.638	2.600	2.525	2.506	2.480	2.477
	Ebn at Noon		290	295	293	282	267	263	273	286	295	303	305	306
	Edh at Noon		42	35	30	25	23	20	21	25	30	34	36	37
(44) All-Sky Solar Radiation	RadAvg		2076	1785	1516	1157	874	681	797	1068	1462	1788	1962	2127
(45)	RadStd		166	141	114	89	43	46	62	54	102	108	141	139

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (23 neighbors)	+0.70	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+198	+81