

BEGA, Australia

WMO: 959310

Lat: 36.6722S

Lon: 149.8192E

Elev: 42

StdP: 100.82

Time Zone: 10.00 (AUS)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	-0.5	0.5	-4.5	2.6	12.2	-2.3	3.1	9.5	11.9	13.1	10.5	13.2	0.5	210	0.453

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	10.8	31.7	21.5	29.3	20.8	27.4	20.2	23.1	28.3	22.2	26.8	21.3	25.6	5.0	50

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.6	16.4	25.1	20.7	15.5	24.1	19.9	14.7	23.2	68.8	28.4	65.3	26.9	62.2	25.7	27.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
10.0	8.7	7.6	DB	-2.7	37.9	0.7	2.9	-3.2	40.0	-3.6	41.7	-4.1	43.3	-4.6	45.4	(4)
			WB	-2.9	25.4	0.8	1.1	-3.5	26.2	-4.0	26.8	-4.5	27.4	-5.1	28.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	15.0	20.6	20.3	18.6	15.5	12.4	10.1	9.3	10.2	12.6	14.8	17.0	18.7	(6)
		DBStd	4.67	2.91	2.70	2.53	2.48	2.24	2.12	2.07	2.35	2.68	2.91	2.90	2.83	(7)
		HDD10.0	98	0	0	0	1	4	24	39	26	4	1	0	0	(8)
		HDD18.3	1478	9	9	27	91	186	246	281	252	172	116	60	29	(9)
		CDD10.0	1915	328	288	266	164	78	28	17	32	84	151	209	270	(10)
		CDD18.3	252	79	64	35	6	0	0	0	0	1	7	19	41	(11)
		CDH23.3	1967	598	415	220	52	4	0	0	2	35	119	183	338	(12)
(13)	Wind	CDH26.7	600	216	122	52	9	1	0	0	0	7	36	50	108	(13)
		WSAvg	2.6	3.1	2.7	2.5	2.1	2.1	2.3	2.5	2.9	3.0	3.1	3.0		(14)
		PrecAvg	839	69	82	111	74	59	67	47	49	59	67	84	74	(15)
		PrecMax	1668	229	535	493	371	284	345	219	224	191	369	301	251	(16)
		PrecMin	428	2	1	0	3	1	0	0	1	1	12	6	1	(17)
		PrecStd	309	53	92	115	94	69	81	57	50	48	67	71	60	(18)
(20)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	35.3	33.5	31.0	27.7	23.5	20.1	20.3	22.6	27.5	30.8	31.4	34.1	(19)
			MCWB	22.6	22.1	21.5	18.3	15.2	12.8	11.7	13.0	15.4	17.1	20.5	21.9	(20)
		2%	DB	31.6	29.9	27.8	24.6	21.1	17.9	17.9	19.9	23.6	26.5	27.6	29.5	(21)
			MCWB	22.3	21.5	20.3	17.7	15.1	12.4	11.2	12.1	14.5	16.9	19.5	20.9	(22)
		5%	DB	28.9	27.8	25.7	22.7	19.5	16.6	16.4	18.0	21.1	23.6	25.3	26.8	(23)
			MCWB	21.6	21.1	19.7	17.0	14.1	11.8	10.5	11.4	14.2	16.5	18.9	20.0	(24)
		10%	DB	26.5	25.8	23.8	21.0	18.0	15.3	15.0	16.4	19.0	21.2	22.9	24.6	(25)
			MCWB	20.4	20.3	18.7	16.2	13.3	11.2	9.9	10.7	12.9	15.4	17.3	19.1	(26)
		0.4%	WB	24.6	24.6	23.1	20.4	17.9	15.3	14.2	15.2	17.6	19.9	22.3	23.5	(27)
			MCDB	31.4	30.1	27.5	25.0	20.5	17.3	16.7	19.6	23.1	24.8	27.9	29.6	(28)
		2%	WB	23.1	22.9	21.6	18.9	16.4	13.8	12.6	13.6	16.0	18.4	20.6	21.9	(29)
			MCDB	28.9	27.3	25.5	22.5	19.2	16.0	15.3	17.8	21.1	23.1	25.7	27.3	(30)
(32)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	5%	WB	22.1	21.9	20.6	17.9	15.2	12.9	11.6	12.5	14.9	17.2	19.4	20.8	(31)
			MCDB	26.8	26.1	24.1	21.2	18.1	15.1	14.6	16.4	19.1	22.0	23.8	25.1	(32)
		10%	WB	21.2	21.0	19.6	16.9	14.1	11.9	10.6	11.4	13.8	16.2	18.3	19.7	(33)
			MCDB	25.4	24.8	22.9	19.9	17.0	14.4	14.1	15.1	17.8	20.1	21.9	23.5	(34)
		5% DB	MDBR	10.8	10.1	10.5	11.7	12.2	11.4	12.7	13.2	12.7	12.3	10.8	10.5	(35)
			MCDBR	15.5	13.7	13.9	14.2	14.6	13.8	15.4	15.6	16.1	17.0	15.5	15.1	(36)
(37)	Mean Daily Temperature Range	5% WB	MCWBR	7.0	6.5	7.2	7.9	8.8	8.7	9.4	8.9	8.4	8.5	7.8	7.4	(37)
			MCDBR	12.9	11.9	12.0	12.3	12.5	11.1	12.9	14.1	14.0	14.4	13.4	12.8	(38)
		5% WB	MCWBR	6.6	6.2	6.6	7.4	8.3	7.7	8.7	9.0	8.3	8.0	7.3	6.9	(39)
																(40)
		taub		0.420	0.381	0.347	0.325	0.311	0.299	0.289	0.301	0.328	0.345	0.367	0.374	(41)
			taud	2.337	2.491	2.568	2.603	2.588	2.616	2.638	2.600	2.525	2.506	2.480	2.477	(42)
(43)	Clear-Sky Solar Irradiance	Ebn at Noon		915	930	925	888	843	828	862	902	930	955	960	964	(43)
		Edh at Noon		133	110	94	80	71	64	66	78	96	107	115	117	(44)
(45)	All-Sky Solar Radiation	RadAvg		6.54	5.63	4.78	3.65	2.75	2.15	2.51	3.37	4.61	5.64	6.19	6.71	(45)
		RadStd		0.52	0.44	0.36	0.28	0.13	0.14	0.20	0.17	0.32	0.34	0.45	0.44	(46)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (23 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		+0.39	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+110	+45

Nomenclature: See separate page