

SCOTTS PEAK DAM, Australia

WMO: 959580

Lat: 43.042S

Lon: 146.272E

Elev: 408

StdP: 96.52

Time Zone: 10.00 (AUS)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	0.6	1.4	-0.6	3.8	2.7	0.1	4.0	2.7	23.1	6.8	21.4	7.4	4.4	290	0.802

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	10.1	27.8	17.4	25.2	16.5	22.9	15.5	18.1	25.5	17.1	23.6	16.1	21.6	6.3	330

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
15.7	11.7	19.2	14.7	10.9	18.7	13.7	10.3	17.9	52.7	25.4	49.5	23.7	46.6	21.7	22.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 20.8	18.1	15.5	DB	-0.6	33.3	0.7	2.3	-1.1	35.0	-1.5	36.4	-1.9	37.7	-2.4	39.4	(4)
(5)			WB	-0.8	20.4	0.6	1.2	-1.2	21.3	-1.6	22.0	-1.9	22.7	-2.4	23.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	10.0	14.2	14.2	12.9	10.6	8.2	6.7	6.1	6.4	7.7	9.4	11.4	12.7	(6)	
	DBStd	4.29	3.94	3.95	3.72	2.91	2.30	2.02	1.79	2.31	2.62	3.33	3.81	3.90	(7)	
	HDD10.0	619	6	5	11	26	64	99	123	115	79	52	25	15	(8)	
	HDD18.3	3068	139	125	173	233	313	348	381	370	319	277	211	179	(9)	
	CDD10.0	631	137	124	102	43	10	1	1	3	9	34	67	100	(10)	
	CDD18.3	38	12	11	6	0	0	0	0	0	0	1	4	6	(11)	
	CDH23.3	454	152	113	54	1	0	0	0	0	0	10	47	78	(12)	
	CDH26.7	129	49	33	15	0	0	0	0	0	0	1	12	19	(13)	
(14) Wind	WSAvg	6.9	7.1	6.3	6.3	6.2	7.2	6.4	6.9	7.2	7.6	7.6	7.2	7.3	(14)	
(15) Precipitation	PrecAvg	1893	104	97	127	146	190	176	205	233	195	179	122	143	(15)	
	PrecMax	2222	224	209	263	264	384	357	297	339	332	319	208	275	(16)	
	PrecMin	1681	12	17	39	63	88	84	91	105	76	78	19	64	(17)	
	PrecStd	148	51	44	46	50	83	66	48	64	67	56	45	43	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	31.6	30.8	28.2	21.7	16.5	13.4	12.5	15.8	19.2	24.7	28.1	29.6	(19)	
		MCWB	18.4	19.0	18.0	14.9	12.0	10.8	9.7	10.8	12.4	14.7	16.9	17.3	(20)	
	2%	DB	27.3	26.7	24.1	19.2	14.1	11.5	10.5	12.9	15.8	20.4	23.9	25.3	(21)	
		MCWB	17.3	17.3	16.7	13.9	11.1	9.6	8.5	9.3	10.7	12.9	15.1	16.1	(22)	
	5%	DB	24.1	23.6	21.3	16.8	12.6	10.3	9.5	11.1	13.4	17.7	20.8	22.5	(23)	
		MCWB	16.1	16.3	15.4	12.9	10.5	9.0	8.1	8.5	9.5	11.9	14.2	15.1	(24)	
	10%	DB	21.1	20.8	18.7	14.7	11.5	9.6	8.6	9.5	11.6	14.9	17.8	19.6	(25)	
		MCWB	15.1	15.0	14.5	12.1	10.1	8.5	7.6	7.9	9.1	10.9	12.9	14.0	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	19.3	19.4	18.8	15.6	12.9	11.5	10.1	11.2	12.8	15.7	17.8	18.4	(27)	
		MCDB	28.0	28.6	26.1	20.3	15.6	12.9	11.4	14.7	17.9	22.0	24.6	25.6	(28)	
	2%	WB	17.8	17.8	17.3	14.2	11.6	10.1	9.0	9.7	11.2	13.8	16.0	16.8	(29)	
		MCDB	25.4	25.5	22.9	17.8	13.0	11.0	9.8	12.0	14.4	18.8	21.4	23.8	(30)	
	5%	WB	16.6	16.7	16.0	13.3	10.9	9.3	8.3	8.9	10.1	12.3	14.6	15.6	(31)	
		MCDB	23.2	22.5	20.4	16.2	12.2	10.0	9.1	10.6	12.8	16.7	20.1	21.5	(32)	
	10%	WB	15.4	15.5	14.7	12.2	10.2	8.7	7.8	8.1	9.2	11.0	13.1	14.2	(33)	
		MCDB	20.6	20.1	18.5	14.5	11.4	9.4	8.5	9.3	11.2	14.8	17.5	19.2	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	10.1	10.2	8.5	6.8	4.9	4.3	4.6	5.5	6.8	8.4	9.4	9.5	(35)	
		MCDBR	16.6	16.0	13.9	10.5	6.7	5.3	5.6	8.2	10.7	14.1	15.5	16.1	(36)	
	5% WB	MCWBR	7.4	7.5	6.9	5.9	4.5	4.0	4.3	5.3	6.4	7.3	7.6	7.4	(37)	
		MCWBR	15.1	14.7	12.8	9.3	5.8	4.8	5.0	7.1	9.4	13.1	14.3	14.4	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.329	0.320	0.318	0.306	0.300	0.288	0.292	0.309	0.330	0.328	0.326	0.326	(40)	
		taud	2.549	2.588	2.593	2.607	2.602	2.616	2.607	2.563	2.486	2.506	2.532	2.548	(41)	
	Ebn at Noon		996	979	936	877	808	784	808	858	904	959	993	1005	(42)	
		Edh at Noon	105	96	87	73	61	55	60	75	95	103	107	107	(43)	
(44) All-Sky Solar Radiation	RadAvg		6.22	5.39	3.89	2.60	1.55	1.24	1.41	2.13	3.20	4.63	5.72	6.19	(44)	
	RadStd		0.45	0.42	0.25	0.16	0.12	0.11	0.10	0.16	0.17	0.27	0.44	0.40	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (25 neighbors)		+0.32	N/A	N/A	+0.65	N/A	N/A	N/A	-100	+105	+13

Nomenclature: See separate page