

DEVONPORT, Australia

WMO: 959600

Lat: 41.1700S

Lon: 146.4289E

Elev: 31

StdP: 14.68

Time Zone: 10.00 (AUS)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	34.5	36.2	27.4	21.4	45.6	29.3	23.4	44.7	37.4	52.4	32.7	53.8	7.7	180	0.634

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	13.9	73.9	64.3	72.0	63.3	70.3	62.4	67.2	71.4	65.9	70.1	64.5	68.7	14.5	40

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
65.6	94.6	69.4	64.1	89.7	68.8	62.6	85.1	67.6	31.7	71.4	30.7	70.1	29.7	68.7	77.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 30.2	26.9	24.1	31.3	80.1	1.2	3.3	30.4	82.5	29.8	84.4	29.1	86.3	28.2	88.7		
(5)			30.4	69.3	1.4	2.6	29.4	71.1	28.6	72.6	27.9	74.1	26.8	75.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	54.4	61.8	62.4	59.8	55.7	52.0	48.9	47.8	48.2	50.0	52.4	55.8	58.7	(6)
(7)		DBStd	6.40	4.12	3.95	4.36	4.17	4.00	3.81	3.56	3.49	3.40	3.63	4.02	3.91	(7)
(8)		HDD50	328	0	0	0	6	26	66	88	79	42	17	4	0	(8)
(9)		HDD65	3910	114	90	168	280	403	483	534	522	450	391	277	198	(9)
(10)		CDD50	1938	367	348	305	176	88	32	19	22	41	91	178	271	(10)
(11)		CDD65	46	16	18	8	0	0	0	0	0	0	0	1	3	(11)
(12)		CDH74	69	33	20	9	0	0	0	0	0	0	0	1	6	(12)
(13)		CDH80	3	2	1	0	0	0	0	0	0	0	0	0	0	(13)
(14)	Wind	WSAvg	11.9	12.0	11.6	11.4	11.1	11.8	11.4	12.2	12.0	12.3	12.1	12.4	12.6	(14)
(15)	Precipitation	PrecAvg	31.2	1.7	1.5	1.9	2.4	3.0	3.3	3.9	3.5	3.0	2.6	2.2	2.0	(15)
(16)		PrecMax	44.4	6.3	5.8	7.5	7.5	6.4	6.6	10.3	7.4	6.1	5.0	5.1	6.6	(16)
(17)		PrecMin	19.4	0.3	0.1	0.0	0.2	0.3	1.2	1.2	0.6	0.3	0.7	0.7	0.2	(17)
(18)		PrecStd	6.4	1.2	1.3	1.6	1.7	1.7	1.4	2.0	1.7	1.5	1.2	1.0	1.4	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	78.0	76.5	75.0	69.0	63.7	60.4	58.3	59.2	62.2	66.5	71.0	73.8	(19)
(20)			MCWB	64.5	65.4	65.1	60.8	57.2	55.3	52.2	51.8	53.9	56.5	60.6	61.7	(20)
(21)		2%	DB	73.7	73.8	71.8	66.6	62.0	58.4	56.6	56.9	59.7	63.1	67.6	70.8	(21)
(22)			MCWB	64.1	65.0	63.6	59.8	56.7	54.0	51.9	51.7	52.9	55.6	59.7	60.9	(22)
(23)		5%	DB	71.5	71.9	69.6	64.9	60.7	57.2	55.6	55.7	58.0	61.2	65.4	68.4	(23)
(24)			MCWB	63.0	64.1	62.4	58.7	56.0	53.5	51.7	51.2	52.5	54.6	58.3	59.9	(24)
(25)		10%	DB	69.7	70.1	67.9	63.5	59.4	56.1	54.5	54.6	56.6	59.6	63.4	66.6	(25)
(26)			MCWB	62.2	63.0	61.1	57.7	55.1	52.5	50.8	50.6	51.8	53.7	57.0	59.3	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	69.7	69.2	68.0	63.7	60.1	57.3	54.8	54.7	56.7	60.3	64.1	66.2	(27)
(28)			MCD B	73.6	72.1	72.7	66.8	61.7	58.6	56.5	56.8	59.3	63.3	68.2	70.3	(28)
(29)		2%	WB	66.8	67.5	66.0	62.1	58.5	55.7	53.5	53.4	55.1	58.0	61.9	64.2	(29)
(30)			MCD B	71.1	71.4	69.8	65.0	60.6	57.4	55.4	55.5	57.6	61.1	65.8	68.1	(30)
(31)		5%	WB	65.4	66.2	64.4	60.6	57.4	54.5	52.5	52.5	54.0	56.4	60.0	62.5	(31)
(32)			MCD B	69.7	70.5	67.9	63.8	59.9	56.5	54.8	54.8	56.6	59.8	63.8	66.6	(32)
(33)		10%	WB	63.8	64.7	62.7	58.8	56.0	53.1	51.4	51.5	52.8	54.9	58.2	60.8	(33)
(34)			MCD B	68.3	69.1	66.8	62.5	58.6	55.6	54.1	54.0	55.7	58.5	62.2	65.3	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	14.0	13.9	14.6	14.3	13.2	12.7	12.3	12.4	12.7	13.4	13.3	14.1	(35)
(36)			MCDBR	16.1	15.1	14.8	14.7	12.9	12.2	11.9	12.1	13.5	14.5	15.1	16.1	(36)
(37)			MCWBR	10.5	9.9	9.8	10.2	9.7	9.4	9.0	9.0	9.6	10.0	9.9	10.1	(37)
(38)		5% WB	MCD BR	13.2	12.4	12.1	12.6	10.8	10.3	9.8	10.1	11.4	12.4	12.5	13.0	(38)
(39)			MCWBR	10.2	9.6	9.7	10.1	9.5	8.8	8.4	8.6	9.2	9.8	9.2	9.7	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.345	0.341	0.328	0.319	0.306	0.303	0.298	0.314	0.334	0.333	0.337	0.335	(40)	
(41)		taud	2.525	2.550	2.585	2.587	2.597	2.586	2.608	2.562	2.498	2.514	2.527	2.548	(41)	
(42)		Ebn at Noon	312	305	295	276	259	248	259	274	288	304	312	317	(42)	
(43)		Edh at Noon	35	32	28	24	20	19	20	24	30	33	34	34	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2234	1911	1457	988	638	498	544	804	1183	1685	2018	2208	(44)	
(45)		RadStd	141	78	64	59	45	48	28	65	84	90	137	143	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.52	N/A	+1.71	+0.95	+0.92	+1.03	N/A	N/A	+130	+16
(47) Regional (25 neighbors)		+0.54	N/A	N/A	+1.22	+0.79	+0.85	N/A	-151	+175	+23

Nomenclature: See separate page