

DEVONPORT, Australia

WMO: 959600

Lat: 41.1700S

Lon: 146.4289E

Elev: 10

StdP: 101.21

Time Zone: 10.00 (AUS)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	1.4	2.3	-2.5	3.1	7.6	-1.5	3.3	7.1	16.7	11.3	14.6	12.1	3.4	180	0.634

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	7.7	23.3	17.9	22.2	17.4	21.3	16.9	19.6	21.9	18.8	21.1	18.1	20.4	6.5	40

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.7	13.5	20.8	17.8	12.8	20.4	17.0	12.2	19.8	55.9	21.9	53.6	21.2	51.2	20.4	25.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 13.5	12.0	10.8	-0.4	26.7	0.7	1.8	-0.9	28.0	-1.2	29.1	-1.6	30.2	-2.1	31.5		
(5)			-0.9	20.7	0.8	1.4	-1.4	21.7	-1.9	22.6	-2.3	23.4	-2.9	24.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	12.5	16.6	16.9	15.5	13.2	11.1	9.4	8.8	9.0	10.0	11.3	13.2	14.8	(6)
(7)		DBStd	3.56	2.29	2.20	2.42	2.32	2.22	2.11	1.98	1.94	1.89	2.01	2.23	2.17	(7)
(8)		HDD10.0	182	0	0	0	3	14	37	49	44	23	9	2	0	(8)
(9)		HDD18.3	2172	63	50	93	156	224	268	297	290	250	217	154	110	(9)
(10)		CDD10.0	1077	204	193	169	98	49	18	11	12	23	51	99	151	(10)
(11)		CDD18.3	26	9	10	4	0	0	0	0	0	0	0	1	2	(11)
(12)		CDH23.3	38	18	11	5	0	0	0	0	0	0	0	1	3	(12)
(13)		CDH26.7	2	1	1	0	0	0	0	0	0	0	0	0	0	(13)
(14)	Wind	WSAvg	5.3	5.4	5.2	5.1	5.0	5.3	5.1	5.4	5.4	5.5	5.4	5.5	5.6	(14)
(15)	Precipitation	PrecAvg	792	44	37	47	62	76	83	100	90	75	67	57	52	(15)
(16)		PrecMax	1128	161	147	191	191	163	168	262	187	155	126	130	167	(16)
(17)		PrecMin	492	8	2	0	5	8	30	30	16	8	19	17	6	(17)
(18)		PrecStd	162	31	32	41	44	42	35	50	44	38	31	26	36	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	25.5	24.7	23.9	20.5	17.6	15.8	14.6	15.1	16.8	19.2	21.6	23.2	(19)
(20)			MCWB	18.1	18.5	18.4	16.0	14.0	12.9	11.2	11.0	12.2	13.6	15.9	16.5	(20)
(21)		2%	DB	23.2	23.2	22.1	19.2	16.7	14.7	13.7	13.8	15.4	17.3	19.8	21.6	(21)
(22)			MCWB	17.8	18.3	17.5	15.4	13.7	12.2	11.1	11.0	11.6	13.1	15.4	16.0	(22)
(23)		5%	DB	22.0	22.2	20.9	18.3	16.0	14.0	13.1	13.2	14.4	16.2	18.6	20.2	(23)
(24)			MCWB	17.2	17.8	16.9	14.8	13.3	12.0	10.9	10.7	11.4	12.5	14.6	15.5	(24)
(25)		10%	DB	20.9	21.2	19.9	17.5	15.2	13.4	12.5	12.5	13.6	15.3	17.4	19.2	(25)
(26)			MCWB	16.8	17.2	16.1	14.3	12.8	11.4	10.5	10.3	11.0	12.0	13.9	15.2	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	20.9	20.7	20.0	17.6	15.6	14.1	12.7	12.6	13.7	15.7	17.8	19.0	(27)
(28)			MCDWB	23.1	22.3	22.6	19.3	16.5	14.8	13.6	13.8	15.2	17.4	20.1	21.3	(28)
(29)		2%	WB	19.3	19.7	18.9	16.7	14.7	13.1	11.9	11.9	12.9	14.5	16.6	17.9	(29)
(30)			MCDWB	21.7	21.9	21.0	18.4	15.9	14.1	13.0	13.1	14.2	16.2	18.8	20.0	(30)
(31)		5%	WB	18.5	19.0	18.0	15.9	14.1	12.5	11.4	11.4	12.2	13.6	15.6	17.0	(31)
(32)			MCDWB	20.9	21.4	19.9	17.7	15.5	13.6	12.7	12.7	13.7	15.5	17.6	19.2	(32)
(33)		10%	WB	17.7	18.2	17.1	14.9	13.3	11.7	10.8	10.8	11.6	12.7	14.6	16.0	(33)
(34)			MCDWB	20.2	20.6	19.3	17.0	14.8	13.1	12.3	12.2	13.1	14.7	16.8	18.5	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	7.8	7.7	8.1	7.9	7.3	7.1	6.9	6.9	7.1	7.5	7.4	7.9	(35)
(36)			MCDBR	8.9	8.4	8.2	8.1	7.1	6.8	6.6	6.7	7.5	8.1	8.4	9.0	(36)
(37)			MCWBR	5.8	5.5	5.5	5.7	5.4	5.2	5.0	5.0	5.3	5.6	5.5	5.6	(37)
(38)		5% WB	MCDBR	7.3	6.9	6.7	7.0	6.0	5.7	5.5	5.6	6.3	6.9	6.9	7.2	(38)
(39)			MCWBR	5.7	5.3	5.4	5.6	5.3	4.9	4.7	4.8	5.1	5.4	5.1	5.4	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.345	0.341	0.328	0.319	0.306	0.303	0.298	0.314	0.334	0.333	0.337	0.335	(40)	
(41)		taud	2.525	2.550	2.585	2.587	2.597	2.586	2.608	2.562	2.498	2.514	2.527	2.548	(41)	
(42)		Ebn at Noon	983	961	931	871	816	782	817	863	908	959	985	999	(42)	
(43)		Edh at Noon	109	101	89	77	64	60	63	77	95	104	108	108	(43)	
(44)	All-Sky Solar Radiation	RadAvg	7.04	6.02	4.59	3.11	2.01	1.57	1.72	2.54	3.73	5.31	6.36	6.96	(44)	
(45)		RadStd	0.44	0.25	0.20	0.19	0.14	0.15	0.09	0.20	0.27	0.28	0.43	0.45	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.29	N/A	+0.95	+0.53	+0.51	+0.57	N/A	N/A	+72	+9
(47) Regional (25 neighbors)		+0.30	N/A	N/A	+0.68	+0.44	+0.47	N/A	-84	+97	+13

Nomenclature: See separate page