

LOW ROCKY POINT, Australia

WMO: 959610

Lat: 42.985S

Lon: 145.502E

Elev: 35

StdP: 100.91

Time Zone: 10.00 (AUS)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	3.9	4.9	1.1	4.1	6.4	2.0	4.4	7.1	21.3	10.7	20.2	10.6	5.0	30	0.753

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	6.4	24.1	17.0	21.9	16.9	20.3	16.2	18.6	22.2	17.7	21.0	17.0	19.8	7.2	340

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
17.4	12.5	19.3	16.6	11.8	18.6	15.8	11.3	18.3	52.7	22.4	50.3	21.0	48.1	19.9	23.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
18.4	16.6	14.8	1.8	29.7	1.1	2.1	1.1	31.2	0.4	32.4	-0.2	33.6	-0.9	35.1		
			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	12.2	15.1	15.4	14.4	12.8	11.4	10.1	9.5	9.6	10.4	11.4	12.6	13.9
	DBStd	2.89	2.18	2.25	2.25	2.14	1.92	1.75	1.60	1.76	1.96	2.11	2.24	2.25
	HDD10.0	110	0	0	0	2	7	20	28	28	17	7	2	0
	HDD18.3	2256	103	88	124	167	215	248	273	269	238	217	173	140
	CDD10.0	913	159	151	138	86	51	22	13	17	28	49	79	121
	CDD18.3	18	5	5	3	1	0	0	0	0	0	1	1	3
	CDH23.3	101	25	27	19	3	0	0	0	0	1	3	8	16
	CDH26.7	17	4	6	3	0	0	0	0	0	0	0	1	3
Wind	WSAvg	7.3	6.6	6.3	6.5	7.2	8.0	7.4	8.0	8.2	8.1	7.6	6.8	7.1
Precipitation	PrecAvg	1883	97	93	127	150	190	178	208	222	198	171	123	139
	PrecMax	2260	227	223	182	275	344	351	324	354	338	280	258	289
	PrecMin	1572	18	14	74	46	85	59	112	98	52	53	13	61
	PrecStd	189	51	46	27	57	74	73	54	74	73	57	53	44
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	26.3	26.7	26.0	22.5	18.5	16.0	14.7	16.9	20.0	22.5	24.4	25.3
		MCWB	18.3	19.3	18.0	15.9	13.6	12.3	11.4	11.8	13.4	14.7	16.1	17.1
	2%	DB	22.9	22.8	21.6	19.3	16.6	14.4	13.6	15.0	16.9	18.9	20.5	21.6
		MCWB	17.4	17.9	17.4	15.3	13.2	12.2	11.3	11.5	11.8	13.5	15.7	17.3
	5%	DB	20.6	20.9	19.6	17.5	15.3	13.6	12.8	13.5	14.9	16.5	17.8	19.2
		MCWB	16.6	16.9	16.5	14.6	13.1	11.9	11.1	11.0	11.7	12.7	14.7	15.8
	10%	DB	19.0	19.4	18.1	16.2	14.4	12.9	12.2	12.4	13.5	14.8	16.3	17.7
		MCWB	15.7	15.9	15.5	14.1	12.7	11.5	10.6	10.5	11.3	12.0	13.4	14.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	20.3	19.5	19.5	17.4	15.2	13.7	12.7	12.6	14.0	15.7	18.4	18.8
		MCDB	23.1	23.8	23.3	21.0	16.7	14.2	13.2	14.4	18.4	21.3	21.8	21.4
	2%	WB	18.1	18.2	18.3	16.4	14.3	13.1	12.2	11.8	13.1	14.4	17.2	17.4
		MCDB	22.3	21.9	21.4	18.9	15.6	13.7	12.9	13.6	15.4	17.8	20.2	20.4
	5%	WB	17.0	17.3	17.4	15.5	13.7	12.5	11.6	11.3	12.3	13.3	15.4	16.2
		MCDB	20.3	20.0	19.9	17.5	14.9	13.2	12.5	12.6	14.2	15.9	18.7	19.1
	10%	WB	16.2	16.5	16.6	14.7	13.0	11.9	11.0	10.7	11.7	12.4	13.9	15.2
		MCDB	18.9	18.8	18.6	16.6	14.3	12.7	12.0	11.9	13.3	14.5	16.5	17.5
Mean Daily Temperature Range	5% DB	MDBR	6.5	6.4	5.9	5.4	4.4	4.4	4.5	4.7	5.3	5.7	6.0	6.2
		MCDBR	10.1	9.3	8.9	8.2	5.7	5.2	5.3	6.5	8.2	9.4	9.6	9.6
		MCWBR	6.2	6.2	5.5	5.2	4.4	3.9	4.2	4.8	4.6	5.9	6.0	6.2
	5% WB	MCDBR	9.0	7.9	7.5	7.1	4.8	3.3	4.4	5.3	6.2	8.5	9.4	8.5
		MCWBR	5.9	5.9	5.4	5.1	4.2	3.3	4.3	4.3	4.5	5.6	6.1	6.0
Clear-Sky Solar Irradiance	taub	0.346	0.337	0.334	0.321	0.318	0.314	0.308	0.334	0.349	0.343	0.338	0.337	
	taud	2.532	2.569	2.580	2.594	2.580	2.563	2.590	2.515	2.464	2.499	2.532	2.554	
	Ebn at Noon	979	961	918	858	785	747	787	827	883	943	981	994	
	Edh at Noon	107	98	88	74	63	59	62	79	97	104	107	106	
All-Sky Solar Radiation	RadAvg	6.21	5.44	3.88	2.61	1.54	1.22	1.40	2.11	3.18	4.65	5.82	6.26	
	RadStd	0.41	0.46	0.27	0.17	0.12	0.11	0.12	0.16	0.16	0.29	0.47	0.43	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	+0.40	+0.49	N/A	+0.55	N/A	N/A	N/A	-58	N/A	N/A
(47)	Regional (21 neighbors)	+0.33	N/A	N/A	N/A	N/A	N/A	N/A	-100	+108	+12

Nomenclature: See separate page