

LOW HEAD, Australia

WMO: 959640

Lat: 41.055S

Lon: 146.787E

Elev: 11

StdP: 14.69

Time Zone: 10.00 (AUS)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 7	(b) 38.7	(c) 40.3	(d) 30.6	(e) 24.8	(f) 47.8	(g) 32.7	(h) 27.1	(i) 47.7	(j) 41.3	(k) 52.0	(l) 39.0	(m) 52.6	(n) 10.6	(o) 160	(p) 0.709

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 2	(b) 10.0	(c) 72.5	(d) 66.2	(e) 70.9	(f) 65.0	(g) 69.5	(h) 63.8	(i) 67.6	(j) 71.0	(k) 66.4	(l) 69.8	(m) 65.2	(n) 68.7	(o) 13.3	(p) 50

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.3	96.8	70.0	65.0	92.4	69.0	63.6	88.2	68.0	32.1	71.4	31.1	69.9	30.2	68.7	72.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 39.9	(b) 34.3	(c) 31.2	(e) 35.9	(f) 75.6	(g) 1.2	(h) 1.7	(i) 35.1	(j) 76.8	(k) 34.4	(l) 77.8	(m) 33.7	(n) 78.8	(o) 32.8	(p) 80.1		
			DB	WB	DB	WB	DB	WB	DB	WB	DB	WB	DB	WB		
			34.5	68.7	0.9	1.3	33.8	69.7	33.3	70.4	32.8	71.2	32.1	72.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	56.3	63.1	63.9	61.9	58.2	54.4	51.0	49.9	50.3	51.8	54.1	57.3	60.2
	DBStd	5.83	3.20	3.21	3.44	3.28	3.55	3.48	3.31	3.01	2.65	2.79	3.14	2.96
	HDD50	132	0	0	0	0	6	30	44	36	13	3	0	0
	HDD65	3234	77	55	107	205	328	420	468	457	397	338	230	152
	CDD50	2427	405	389	369	246	143	60	41	44	66	129	220	315
	CDD65	53	17	23	11	0	0	0	0	0	0	0	0	2
	CDH74	14	4	8	2	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
(14) Wind	WSAvg	16.0	15.9	14.2	15.0	14.9	17.0	15.5	16.6	16.6	16.5	16.2	16.6	16.9
(15) Precipitation	PrecAvg	26.1	1.5	1.3	1.6	2.4	2.7	2.4	3.3	2.8	2.3	2.0	1.9	1.8
	PrecMax	37.6	4.8	6.6	6.6	7.4	7.3	5.2	6.9	6.2	6.2	3.3	3.4	5.6
	PrecMin	17.7	0.2	0.0	0.1	0.3	0.3	0.6	1.2	0.7	0.2	0.6	0.5	0.0
	PrecStd	4.4	0.9	1.3	1.4	1.7	1.5	1.1	1.4	1.3	1.3	0.8	0.7	1.3
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	74.2	75.3	73.6	68.3	63.6	60.0	57.8	58.1	60.2	64.3	69.1	70.9
		MCWB	67.2	67.7	67.2	62.0	58.9	55.8	53.8	53.3	54.1	57.5	62.3	63.6
	2%	DB	71.8	72.8	71.2	66.5	62.2	58.5	56.6	56.7	58.5	62.1	66.4	68.7
		MCWB	65.4	66.6	65.5	61.2	57.9	55.0	52.9	52.6	53.4	56.9	60.9	62.5
	5%	DB	70.2	71.3	69.3	65.2	61.1	57.6	55.8	55.8	57.4	60.5	64.5	67.2
		MCWB	64.4	65.6	63.9	60.3	57.1	54.2	52.4	52.1	52.9	55.5	59.2	61.5
	10%	DB	68.9	69.8	67.9	64.0	60.1	56.7	55.0	54.9	56.4	59.2	62.9	65.8
		MCWB	63.3	64.0	62.4	59.3	56.2	53.4	51.8	51.5	52.2	54.4	57.6	60.3
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	69.4	69.4	68.4	63.9	60.3	57.5	55.0	54.8	55.8	60.0	63.8	66.1
		MCDB	72.4	72.8	72.0	66.3	61.9	58.6	56.5	56.4	58.1	62.6	67.1	69.2
	2%	WB	67.1	68.0	66.8	62.8	59.2	56.2	54.0	53.7	54.8	58.1	61.9	64.2
		MCDB	70.3	71.4	70.2	65.5	61.4	57.8	55.7	55.5	57.3	60.8	65.3	67.2
	5%	WB	65.9	66.8	65.3	61.7	58.2	55.1	53.1	52.9	53.9	56.7	60.3	62.8
		MCDB	69.2	70.2	68.6	64.6	60.6	57.1	55.1	55.0	56.5	59.7	63.5	66.2
	10%	WB	64.5	65.5	63.7	60.2	57.0	53.9	52.4	52.2	53.0	55.4	58.7	61.2
		MCDB	68.1	69.1	67.1	63.4	59.6	56.4	54.7	54.5	55.7	58.6	62.1	65.0
(35) Mean Daily Temperature Range	5% DB	MDBR	9.4	10.0	10.1	9.8	9.0	8.8	8.3	8.4	8.5	9.1	9.2	9.1
		MCDBR	10.4	10.7	10.7	10.4	8.9	8.1	7.5	8.2	9.2	10.3	10.6	10.4
		MCWBR	7.6	7.8	7.7	7.8	7.1	6.7	6.2	6.5	7.0	7.4	7.4	7.4
	5% WB	MCDBR	9.3	9.4	9.4	9.1	7.3	7.0	6.7	7.2	7.9	9.3	9.2	8.8
		MCWBR	8.0	7.9	7.5	8.0	6.8	6.6	6.2	6.4	6.9	7.3	7.3	7.2
(40) Clear-Sky Solar Irradiance	taub		0.350	0.345	0.331	0.321	0.308	0.308	0.300	0.317	0.337	0.338	0.343	0.338
	taud		2.513	2.541	2.580	2.585	2.594	2.575	2.606	2.556	2.492	2.502	2.512	2.543
	Ebn at Noon		310	304	294	276	258	246	259	272	287	302	311	316
	Edh at Noon		35	32	29	24	21	19	20	25	30	33	35	34
(44) All-Sky Solar Radiation	RadAvg		2247	1922	1481	1004	655	511	564	830	1222	1711	2041	2246
	RadStd		141	77	67	52	42	46	26	65	84	85	132	137

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (25 neighbors)	+0.54	N/A	N/A	+1.22	+0.79	+0.85	N/A	-151	+175	+23

Nomenclature: See separate page