

CRESSY, Australia

WMO: 959690

Lat: 41.7256S

Lon: 147.0794E

Elev: 148

StdP: 99.56

Time Zone: 10.00 (AUS)

Period: 99-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	-2.6	-1.5	-3.6	2.8	0.3	-2.7	3.1	1.3	14.2	10.7	12.6	10.6	0.8	190	0.619

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	13.4	28.7	18.0	26.6	17.2	25.0	16.5	19.4	25.5	18.5	24.0	17.6	22.9	6.9	330

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.5	12.8	20.8	16.5	11.9	20.3	15.5	11.2	19.6	55.7	26.0	52.9	24.0	50.2	22.9	23.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12.4	10.9	9.7		-4.6	33.1	0.9	2.7	-5.2	35.0	-5.8	36.6	-6.3	38.1	-7.0	40.0
				-4.7	21.5	1.0	0.8	-5.4	22.1	-6.0	22.6	-6.6	23.0	-7.3	23.6
				DB											
				WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	11.8	17.4	17.3	15.3	11.8	9.2	7.2	6.9	7.6	9.1	10.9	13.4	15.3	(6)
(7)		DBStd	4.58	3.09	2.88	3.07	2.71	2.75	2.58	2.30	2.22	2.18	2.51	2.76	2.84	(7)
(8)		HDD10.0	395	0	0	1	12	49	90	99	79	42	18	4	1	(8)
(9)		HDD18.3	2462	55	49	102	195	284	335	354	332	277	230	148	99	(9)
(10)		CDD10.0	1039	229	204	167	68	24	5	2	5	16	47	107	166	(10)
(11)		CDD18.3	64	26	20	10	1	0	0	0	0	0	0	1	7	(11)
(12)		CDH23.3	778	330	196	96	2	0	0	0	0	0	2	39	113	(12)
(13)		CDH26.7	179	96	37	19	0	0	0	0	0	0	0	4	22	(13)
(14)	Wind	WSAvg	4.3	4.9	4.6	4.2	3.7	3.9	3.4	3.8	4.3	4.6	4.7	4.8	4.9	(14)
(15)	Precipitation	PrecAvg	644	48	34	39	44	53	64	69	75	67	50	54	47	(15)
(16)		PrecMax	923	147	95	107	102	120	154	146	176	126	98	131	89	(16)
(17)		PrecMin	418	10	1	9	6	0	4	29	15	12	11	10	6	(17)
(18)		PrecStd	121	33	20	24	24	34	35	28	46	29	24	28	23	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	33.1	30.3	29.2	22.7	17.9	15.0	14.1	15.5	18.5	23.0	27.0	29.9	(19)
(20)			MCWB	19.5	19.0	18.8	15.4	13.6	11.8	10.4	11.5	13.1	15.0	16.8	18.1	(20)
(21)		2%	DB	29.3	27.6	25.8	20.5	16.3	13.7	13.0	14.1	16.4	19.9	24.1	26.2	(21)
(22)			MCWB	18.2	18.0	17.2	14.9	12.6	11.1	10.2	10.6	11.9	14.0	16.2	16.7	(22)
(23)		5%	DB	26.8	25.7	23.6	18.8	15.1	12.7	12.1	13.0	15.1	18.1	21.7	24.1	(23)
(24)			MCWB	17.2	17.1	16.3	13.8	11.9	10.5	9.7	10.0	11.1	13.0	15.1	15.7	(24)
(25)		10%	DB	24.8	24.0	21.8	17.4	14.0	11.8	11.2	11.9	14.0	16.7	19.8	22.3	(25)
(26)			MCWB	16.3	16.2	15.1	13.0	11.5	9.9	9.2	9.2	10.3	12.2	14.2	14.9	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.1	20.5	19.6	17.2	14.9	13.2	11.9	12.5	14.1	16.4	18.4	19.5	(27)
(28)			MCDWB	29.7	26.5	26.3	20.4	16.2	13.9	13.0	14.4	16.9	19.6	23.3	25.4	(28)
(29)		2%	WB	19.4	19.2	18.2	15.8	13.6	11.8	11.0	11.3	12.8	15.0	17.1	18.2	(29)
(30)			MCDWB	26.1	25.0	23.4	18.8	15.3	12.9	12.1	13.1	15.3	18.7	22.2	23.5	(30)
(31)		5%	WB	18.3	18.3	17.3	14.9	12.8	11.0	10.2	10.5	11.9	13.8	15.9	17.0	(31)
(32)			MCDWB	24.2	23.6	22.1	17.6	14.4	12.3	11.5	12.3	14.2	17.2	20.8	22.5	(32)
(33)		10%	WB	17.2	17.3	16.2	13.9	11.9	10.1	9.5	9.8	10.9	12.7	14.8	15.8	(33)
(34)			MCDWB	23.1	22.3	20.4	16.4	13.6	11.5	10.9	11.5	13.2	15.9	19.0	20.9	(34)
(35)	Mean Daily Temperature Range	MDBR	13.4	12.7	12.3	11.2	9.7	9.0	8.6	9.0	9.8	11.0	11.9	12.8	(35)	
(36)		5% DB	MCDBR	16.8	15.0	14.6	13.2	10.1	9.2	8.9	9.8	11.2	13.3	15.3	16.0	(36)
(37)			MCWBR	7.4	6.9	7.0	7.8	7.0	6.9	6.7	6.9	7.4	8.2	8.3	7.6	(37)
(38)		5% WB	MCDWB	14.3	13.0	12.6	11.2	8.3	8.0	7.6	8.4	10.1	11.7	13.4	13.7	(38)
(39)			MCWBR	7.3	6.8	6.5	7.6	6.3	6.6	6.2	6.2	7.2	7.8	7.9	7.4	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.341	0.333	0.325	0.314	0.302	0.290	0.290	0.306	0.326	0.332	0.338	0.335	(40)	
(41)		taud	2.495	2.535	2.550	2.558	2.567	2.589	2.594	2.548	2.478	2.472	2.480	2.501	(41)	
(42)		Ebn at Noon	986	967	931	872	814	794	822	869	913	957	983	998	(42)	
(43)		Edh at Noon	112	102	92	78	65	58	62	77	97	108	113	112	(43)	
(44)	All-Sky Solar Radiation	RadAvg	6.89	5.82	4.46	3.02	1.93	1.50	1.67	2.46	3.66	5.13	6.16	6.80	(44)	
(45)		RadStd	0.49	0.25	0.20	0.17	0.12	0.13	0.08	0.19	0.24	0.28	0.46	0.45	(45)	

Historical Trends

		Heating		Cooling			Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+85	N/A	(46)
(47)	Regional (36 neighbors)	+0.32	N/A	N/A	+0.68	+0.35	+0.41	N/A	-98	+106	+13	(47)

Nomenclature: See separate page