

MOUNT WELLINGTON, Australia

WMO: 959790

Lat: 42.8950S

Lon: 147.2358E

Elev: 4135

StdP: 12.63

Time Zone: 10.00 (AUS)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	23.1	24.4	6.6	9.0	43.1	14.3	13.2	42.1	62.9	35.1	55.6	35.7	18.8	240	1.102

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	14.4	69.2	54.9	65.4	53.6	62.0	52.1	57.8	64.6	55.9	62.1	54.0	59.7	19.7	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
55.4	76.3	59.2	53.4	70.8	57.5	51.5	65.9	55.8	26.8	64.5	25.4	62.2	24.2	59.8	64.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 54.0	48.1	43.9	DB	21.4	78.0	1.5	3.8	20.4	80.7	19.5	82.9	18.7	85.0	17.6	87.7	(4)
(5)			WB	21.1	61.3	1.3	1.9	20.2	62.6	19.4	63.7	18.7	64.8	17.7	66.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	39.9	48.2	47.6	45.0	40.8	37.5	34.7	32.8	32.9	35.1	38.2	41.8	44.0
	DBStd	8.17	7.73	7.60	7.21	6.16	5.11	4.30	3.73	4.72	5.33	6.66	7.45	7.35
	HDD50	3938	128	124	189	282	390	459	533	530	446	373	267	217
	HDD65	9187	525	488	619	725	854	909	998	995	896	831	696	651
	CDD50	234	72	58	36	7	1	0	0	0	1	7	21	31
	CDD65	5	3	1	1	0	0	0	0	0	0	0	0	0
	CDH74	26	19	2	3	0	0	0	0	0	0	0	0	2
	CDH80	1	1	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	21.1	19.2	18.2	19.7	21.6	24.0	21.4	21.9	21.9	23.0	22.0	19.8	20.3
Precipitation	PrecAvg	25.2	1.9	1.7	1.7	1.9	1.7	2.2	2.4	2.7	2.5	2.3	2.2	2.1
	PrecMax	35.7	4.9	5.9	4.1	5.9	4.9	6.1	5.4	5.4	5.4	5.4	4.7	5.6
	PrecMin	15.3	0.2	0.2	0.3	0.4	0.2	0.4	0.4	0.2	0.6	0.8	0.0	0.1
	PrecStd	4.4	1.3	1.3	0.9	1.1	1.1	1.4	1.2	1.3	1.3	1.0	1.1	1.2
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	76.9	72.7	70.0	60.1	54.2	48.4	43.8	49.2	54.0	63.0	67.4	71.0
		MCWB	58.4	56.7	54.0	49.5	43.9	40.1	36.9	40.4	44.3	48.7	52.6	54.0
	2%	DB	69.8	67.3	63.5	55.8	50.0	45.0	41.4	44.8	49.0	57.1	62.6	64.8
		MCWB	56.0	56.0	52.8	47.2	43.9	39.8	37.8	39.1	42.7	46.4	50.4	52.5
	5%	DB	65.4	63.1	59.8	52.4	47.1	42.6	39.5	42.3	46.0	52.7	58.2	59.8
		MCWB	54.1	54.0	51.4	45.7	42.6	38.3	37.1	38.7	41.3	45.2	48.9	50.7
	10%	DB	61.0	59.4	55.8	49.8	44.9	40.6	38.0	39.8	43.3	48.9	54.1	55.8
		MCWB	52.3	52.5	50.3	44.9	41.5	37.7	36.4	37.3	39.9	43.6	47.2	49.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	60.9	60.7	57.6	52.3	48.5	46.2	41.3	43.7	47.7	51.6	55.5	57.5
		MCDB	70.3	66.4	63.6	56.6	50.5	46.5	41.8	45.6	50.7	55.9	62.5	64.3
	2%	WB	58.0	58.0	54.9	49.7	45.9	42.8	39.0	41.3	44.5	48.7	52.7	54.6
		MCDB	66.4	63.5	60.1	52.7	47.5	43.3	39.8	43.6	47.4	54.0	59.8	60.8
	5%	WB	55.5	55.9	53.1	47.7	44.2	40.3	37.8	39.3	42.0	46.4	50.3	52.4
		MCDB	63.1	61.2	57.8	50.7	45.7	41.1	38.5	41.3	44.4	51.9	56.3	58.2
	10%	WB	53.3	53.7	51.1	45.9	42.4	38.8	36.8	37.7	40.0	44.0	47.8	50.1
		MCDB	59.3	58.5	55.3	49.2	44.0	39.6	37.5	39.3	42.2	48.3	53.0	55.3
Mean Daily Temperature Range	5% DB	MDBR	14.4	12.9	11.3	9.4	7.5	6.4	6.0	7.0	9.1	11.5	12.6	13.4
		MCDBR	20.3	17.3	15.5	12.5	9.9	8.7	7.6	10.2	12.8	16.9	18.2	18.9
		MCWBR	12.3	11.4	10.7	8.7	7.6	6.9	6.5	7.9	9.9	11.4	12.0	12.7
	5% WB	MCDBR	18.1	15.2	13.7	11.1	8.4	7.1	6.9	9.2	11.7	15.0	16.0	16.3
		MCWBR	12.2	11.4	10.2	8.8	7.8	6.8	6.6	7.8	10.1	11.4	11.8	12.2
Clear-Sky Solar Irradiance	taub	0.286	0.278	0.277	0.264	0.259	0.250	0.251	0.259	0.272	0.275	0.278	0.282	
	taud	2.653	2.705	2.690	2.707	2.684	2.692	2.700	2.691	2.639	2.652	2.671	2.664	
	Ebn at Noon	331	326	312	296	275	268	276	293	309	323	331	334	
	Edh at Noon	30	27	25	21	18	16	17	21	26	28	30	30	
All-Sky Solar Radiation	RadAvg	2054	1753	1303	883	542	430	496	739	1113	1557	1856	2057	
	RadStd	155	99	73	51	35	34	23	50	55	87	144	120	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	+0.72	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (29 neighbors)	+0.58	N/A	N/A	+1.22	N/A	N/A	N/A	-180	+191	+25

Nomenclature: See separate page