

MOUNT WELLINGTON, Australia

WMO: 959790

Lat: 42.8950S

Lon: 147.2358E

Elev: 1261

StdP: 87.07

Time Zone: 10.00 (AUS)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	-4.9	-4.2	-14.1	1.3	6.2	-9.8	1.9	5.6	28.1	1.7	24.9	2.1	8.4	240	1.102

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	8.0	20.7	12.7	18.6	12.0	16.7	11.2	14.4	18.1	13.3	16.7	12.2	15.4	8.8	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
13.0	10.9	15.1	11.9	10.1	14.2	10.8	9.4	13.2	44.4	18.1	41.3	16.8	38.4	15.5	18.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 24.2	21.5	19.6	DB	-5.9	25.5	0.8	2.1	-6.5	27.0	-6.9	28.3	-7.4	29.4	-8.0	30.9	(4)
(5)			WB	-6.0	16.3	0.7	1.0	-6.6	17.0	-7.0	17.6	-7.4	18.2	-7.9	19.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	4.4	9.0	8.7	7.2	4.9	3.0	1.5	0.4	0.5	1.7	3.4	5.4	6.7
	DBStd	4.54	4.29	4.22	4.00	3.42	2.84	2.39	2.07	2.62	2.96	3.70	4.14	4.09
	HDD10.0	2188	71	69	105	157	217	255	296	294	248	207	148	121
	HDD18.3	5104	292	271	344	403	474	505	554	553	498	462	387	362
	CDD10.0	130	40	32	20	4	1	0	0	0	1	4	12	17
	CDD18.3	3	2	1	1	0	0	0	0	0	0	0	0	0
	CDH23.3	14	11	1	2	0	0	0	0	0	0	0	0	1
	CDH26.7	1	1	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	9.4	8.6	8.1	8.8	9.7	10.7	9.6	9.8	9.8	10.3	9.8	8.8	9.1
Precipitation	PrecAvg	641	49	43	42	48	43	56	60	68	63	59	57	54
	PrecMax	908	124	150	103	151	125	155	136	136	136	137	119	143
	PrecMin	389	4	5	8	9	5	11	11	6	15	20	1	2
	PrecStd	112	32	33	24	29	29	35	31	34	33	25	29	31
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	24.9	22.6	21.1	15.6	12.3	9.1	6.6	9.6	12.2	17.2	19.7	21.7
		MCWB	14.7	13.7	12.2	9.7	6.6	4.5	2.7	4.7	6.8	9.3	11.4	12.2
	2%	DB	21.0	19.6	17.5	13.2	10.0	7.2	5.2	7.1	9.4	13.9	17.0	18.2
		MCWB	13.3	13.3	11.5	8.4	6.6	4.3	3.2	4.0	5.9	8.0	10.2	11.4
	5%	DB	18.6	17.3	15.4	11.4	8.4	5.9	4.2	5.7	7.8	11.5	14.6	15.4
		MCWB	12.3	12.2	10.8	7.6	5.9	3.5	2.8	3.7	5.2	7.3	9.4	10.4
	10%	DB	16.1	15.2	13.2	9.9	7.2	4.8	3.4	4.3	6.3	9.4	12.3	13.2
		MCWB	11.3	11.4	10.2	7.2	5.3	3.2	2.5	2.9	4.4	6.4	8.4	9.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	16.1	16.0	14.2	11.3	9.2	7.9	5.1	6.5	8.7	10.9	13.1	14.2
		MCDB	21.3	19.1	17.6	13.7	10.3	8.1	5.4	7.5	10.4	13.3	16.9	18.0
	2%	WB	14.4	14.4	12.7	9.8	7.7	6.0	3.9	5.1	7.0	9.3	11.5	12.6
		MCDB	19.1	17.5	15.6	11.5	8.6	6.3	4.4	6.5	8.5	12.2	15.5	16.0
	5%	WB	13.1	13.3	11.7	8.7	6.8	4.6	3.2	4.1	5.6	8.0	10.2	11.3
		MCDB	17.3	16.2	14.3	10.4	7.6	5.1	3.6	5.2	6.9	11.1	13.5	14.5
	10%	WB	11.8	12.1	10.6	7.7	5.8	3.8	2.7	3.1	4.5	6.7	8.8	10.1
		MCDB	15.2	14.7	13.0	9.6	6.7	4.2	3.0	4.0	5.7	9.1	11.7	12.9
Mean Daily Temperature Range	5% DB	MDBR	8.0	7.2	6.3	5.2	4.2	3.6	3.3	3.9	5.1	6.4	7.0	7.4
		MCDBR	11.3	9.6	8.6	6.9	5.5	4.8	4.2	5.7	7.1	9.4	10.1	10.5
		MCWBR	6.8	6.3	5.9	4.8	4.2	3.8	3.6	4.4	5.5	6.3	6.7	7.0
	5% WB	MCDBR	10.0	8.4	7.6	6.2	4.7	3.9	3.9	5.1	6.5	8.3	8.9	9.1
		MCWBR	6.8	6.4	5.7	4.9	4.3	3.8	3.7	4.4	5.6	6.3	6.6	6.8
Clear-Sky Solar Irradiance	taub	0.286	0.278	0.277	0.264	0.259	0.250	0.251	0.259	0.272	0.275	0.278	0.282	
	taud	2.653	2.705	2.690	2.707	2.684	2.692	2.700	2.691	2.639	2.652	2.671	2.664	
	Ebn at Noon	1043	1027	985	932	868	845	870	925	973	1018	1045	1053	
	Edh at Noon	95	85	79	65	56	50	54	65	81	89	93	95	
All-Sky Solar Radiation	RadAvg	6.47	5.53	4.11	2.78	1.71	1.35	1.56	2.33	3.51	4.91	5.85	6.49	
	RadStd	0.49	0.31	0.23	0.16	0.11	0.11	0.07	0.16	0.17	0.27	0.45	0.38	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.40	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (29 neighbors)		+0.32	N/A	N/A	+0.68	N/A	N/A	N/A	-100	+106	+14

Nomenclature: See separate page