

TASMAN ISLAND, Australia

WMO: 959860

Lat: 43.2386S

Lon: 148.0030E

Elev: 791

StdP: 14.28

Time Zone: 10.00 (AUS)

Period: 03-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	39.2	40.5	30.2	25.0	45.1	31.8	26.9	44.4	40.8	48.9	36.9	49.6	16.8	210	0.726

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	8.6	73.2	59.8	69.1	59.6	65.9	58.9	63.8	67.2	62.4	65.5	61.1	64.3	17.0	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
62.9	88.4	64.0	61.4	83.6	63.1	59.7	78.9	62.1	29.5	67.5	28.5	65.5	27.5	64.3	70.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 38.8	33.5	29.7	DB	36.3	83.8	1.6	6.1	35.2	88.2	34.3	91.8	33.4	95.2	32.2	99.6	(4)
(5)			WB	34.6	66.6	0.9	2.3	33.9	68.2	33.4	69.5	32.9	70.8	32.3	72.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	52.5	57.8	57.9	57.1	54.2	51.3	48.7	47.5	47.5	49.1	50.6	52.8	55.2
	DBStd	5.55	4.38	4.30	4.53	4.38	3.82	3.19	3.17	3.72	3.92	4.44	4.59	4.31
	HDD50	417	1	1	2	10	29	61	89	96	62	43	18	5
	HDD65	4599	230	203	248	324	423	488	541	543	478	448	368	305
	CDD50	1312	242	223	224	136	71	23	12	18	34	61	101	167
	CDD65	19	6	5	5	0	0	0	0	0	0	1	1	1
	CDH74	113	32	30	20	0	0	0	0	0	0	7	11	13
	CDH80	26	7	8	4	0	0	0	0	0	0	2	2	3
Wind	WSAvg	13.7	14.0	14.2	12.9	13.3	13.3	12.7	13.5	14.0	14.3	14.1	13.6	14.1
Precipitation	PrecAvg	30.4	2.7	2.2	2.3	2.5	2.3	2.5	2.7	3.0	2.4	2.4	2.8	2.7
	PrecMax	40.0	6.5	5.4	7.6	6.7	5.7	7.1	5.9	5.7	6.0	5.2	5.7	8.0
	PrecMin	22.0	0.3	0.4	0.7	0.7	0.4	0.9	0.9	0.8	0.8	0.9	0.6	0.5
	PrecStd	4.8	1.7	1.2	1.3	1.3	1.1	1.3	1.1	1.3	1.2	0.9	1.2	1.5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	77.6	78.9	76.1	71.1	62.9	57.6	56.8	59.3	63.9	73.1	74.4	75.0
		MCWB	60.7	62.6	60.8	58.4	53.2	53.0	49.6	50.4	51.5	54.8	58.3	59.7
	2%	DB	71.0	70.0	69.6	65.7	60.8	56.1	54.8	56.9	60.0	64.8	66.9	67.1
		MCWB	61.2	62.0	60.7	56.2	53.0	51.6	48.7	49.3	51.0	53.1	56.9	58.6
	5%	DB	66.4	65.9	65.6	62.7	58.9	54.8	53.5	54.8	57.1	59.7	61.9	63.6
		MCWB	60.3	60.6	59.9	56.3	52.8	50.0	48.4	48.3	49.8	51.8	55.5	57.6
	10%	DB	63.9	63.7	63.3	60.3	57.1	53.5	52.2	53.1	54.8	56.8	58.9	61.2
		MCWB	58.9	59.9	59.5	55.4	52.3	49.1	47.7	47.8	49.1	51.5	54.4	56.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	66.4	65.5	64.8	61.1	57.5	56.5	53.3	53.0	54.7	57.8	61.4	63.2
		MCDB	71.5	70.1	67.6	64.8	58.3	56.7	54.0	54.7	58.3	62.5	67.2	67.9
	2%	WB	63.2	63.8	63.0	59.5	55.8	53.2	51.1	51.4	53.1	55.8	59.1	60.8
		MCDB	66.5	67.1	65.6	62.1	57.9	54.3	52.4	54.2	56.8	59.8	63.8	63.4
	5%	WB	61.8	62.3	61.6	57.8	54.4	51.2	49.4	50.0	51.5	54.1	57.0	59.0
		MCDB	65.1	65.4	64.6	61.1	57.4	53.3	52.0	53.5	54.8	57.9	60.6	61.8
	10%	WB	59.8	60.6	59.9	56.1	53.0	49.9	48.2	48.6	50.1	52.2	55.2	57.5
		MCDB	63.7	63.6	63.2	59.9	56.6	52.5	51.5	52.5	53.7	56.8	58.1	60.7
Mean Daily Temperature Range	5% DB	MDBR	9.6	8.6	8.4	7.5	6.5	5.6	5.8	7.0	8.1	8.9	9.0	9.2
		MCDBR	15.1	12.8	12.9	11.2	9.0	6.9	7.2	9.1	11.8	14.6	15.5	13.9
		MCWBR	9.1	8.3	7.7	6.7	6.7	5.3	5.9	6.2	7.8	8.4	8.5	8.6
	5% WB	MCDBR	12.9	10.9	10.7	9.1	7.2	5.2	6.0	7.8	9.5	11.5	13.0	11.4
	MCWBR	9.2	8.5	7.8	6.9	6.8	5.0	5.8	6.3	7.6	8.2	8.2	8.6	
Clear-Sky Solar Irradiance	taub	0.338	0.329	0.323	0.308	0.295	0.290	0.291	0.303	0.324	0.325	0.328	0.331	
	taud	2.557	2.598	2.614	2.630	2.636	2.621	2.625	2.606	2.540	2.554	2.566	2.570	
	Ebn at Noon	313	307	295	277	259	247	257	275	289	305	314	317	
	Edh at Noon	33	30	27	23	19	17	19	23	29	31	33	33	
All-Sky Solar Radiation	RadAvg	2024	1717	1281	870	535	428	497	744	1130	1582	1844	2080	
	RadStd	133	92	66	50	34	32	23	49	57	77	139	104	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (21 neighbors)	+0.59	N/A	N/A	+1.33	N/A	N/A	N/A	-200	+207	+34

Nomenclature: See separate page