

TASMAN ISLAND, Australia

WMO: 959860

Lat: 43.2386S

Lon: 148.0030E

Elev: 241

StdP: 98.46

Time Zone: 10.00 (AUS)

Period: 03-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	4.0	4.7	-1.0	3.6	7.3	-0.1	3.8	6.9	18.2	9.4	16.5	9.8	7.5	210	0.726

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	4.8	22.9	15.4	20.6	15.3	18.9	14.9	17.6	19.6	16.9	18.6	16.1	18.0	7.6	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.2	12.6	17.8	16.3	11.9	17.3	15.4	11.3	16.7	50.8	19.7	48.5	18.6	46.2	17.9	21.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 17.3	15.0	13.3	2.4	28.8	0.9	3.4	1.8	31.2	1.3	33.2	0.8	35.1	0.1	37.6		
(5)			1.4	19.2	0.5	1.3	1.1	20.1	0.8	20.8	0.5	21.6	0.1	22.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	11.4	14.3	14.4	14.0	12.3	10.7	9.3	8.6	8.6	9.5	10.3	11.5	12.9
	DBStd	3.09	2.43	2.39	2.52	2.44	2.12	1.77	1.76	2.07	2.18	2.47	2.55	2.39
	HDD10.0	232	1	1	1	6	16	34	49	53	34	24	10	3
	HDD18.3	2555	128	113	138	180	235	271	301	302	266	249	204	169
	CDD10.0	729	134	124	124	76	39	13	7	10	19	34	56	93
	CDD18.3	11	3	3	3	0	0	0	0	0	0	1	1	1
	CDH23.3	63	18	17	11	0	0	0	0	0	0	4	6	7
	CDH26.7	14	4	4	2	0	0	0	0	0	0	1	1	2
Wind	WSAvg	6.1	6.3	6.3	5.8	5.9	5.9	5.7	6.0	6.2	6.4	6.3	6.1	6.3
Precipitation	PrecAvg	772	68	55	59	64	58	63	69	75	61	61	71	69
	PrecMax	1017	165	136	194	170	146	181	150	144	153	133	144	203
	PrecMin	559	7	11	18	19	11	24	23	20	20	22	15	13
	PrecStd	122	44	31	33	34	27	34	27	33	30	22	31	39
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	25.3	26.0	24.5	21.7	17.2	14.2	13.8	15.2	17.7	22.8	23.5	23.9
		MCWB	16.0	17.0	16.0	14.7	11.8	11.7	9.8	10.2	10.8	12.7	14.6	15.4
	2%	DB	21.6	21.1	20.9	18.7	16.0	13.4	12.7	13.8	15.6	18.2	19.4	19.5
		MCWB	16.2	16.7	15.9	13.4	11.7	10.9	9.3	9.6	10.5	11.7	13.8	14.8
	5%	DB	19.1	18.8	18.7	17.1	14.9	12.6	11.9	12.7	13.9	15.4	16.6	17.6
		MCWB	15.7	15.9	15.5	13.5	11.6	10.0	9.1	9.1	9.9	11.0	13.1	14.2
	10%	DB	17.7	17.6	17.4	15.7	14.0	12.0	11.2	11.7	12.6	13.8	15.0	16.2
		MCWB	14.9	15.5	15.3	13.0	11.3	9.5	8.7	8.8	9.5	10.8	12.4	13.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	19.1	18.6	18.2	16.2	14.2	13.6	11.8	11.7	12.6	14.3	16.3	17.3
		MCDB	22.0	21.2	19.8	18.2	14.6	13.7	12.2	12.6	14.6	16.9	19.6	20.0
	2%	WB	17.3	17.7	17.2	15.3	13.2	11.8	10.6	10.8	11.7	13.2	15.0	16.0
		MCDB	19.2	19.5	18.7	16.7	14.4	12.4	11.4	12.3	13.8	15.5	17.6	17.5
	5%	WB	16.5	16.8	16.5	14.4	12.5	10.7	9.7	10.0	10.9	12.3	13.9	15.0
		MCDB	18.4	18.6	18.1	16.2	14.1	11.8	11.1	11.9	12.7	14.4	15.9	16.6
	10%	WB	15.4	15.9	15.5	13.4	11.7	10.0	9.0	9.2	10.1	11.2	12.9	14.2
		MCDB	17.6	17.5	17.3	15.5	13.7	11.4	10.8	11.4	12.1	13.8	14.5	15.9
Mean Daily Temperature Range	5% DB	MDBR	5.4	4.8	4.7	4.1	3.6	3.1	3.2	3.9	4.5	4.9	5.0	5.1
		MCDBR	8.4	7.1	7.1	6.2	5.0	3.9	4.0	5.1	6.5	8.1	8.6	7.7
		MCWBR	5.1	4.6	4.3	3.7	3.7	2.9	3.3	3.5	4.3	4.7	4.7	4.8
	5% WB	MCDBR	7.2	6.1	6.0	5.1	4.0	2.9	3.3	4.3	5.3	6.4	7.2	6.3
		MCWBR	5.1	4.7	4.3	3.8	3.8	2.8	3.2	3.5	4.2	4.5	4.6	4.8
Clear-Sky Solar Irradiance	taub	0.338	0.329	0.323	0.308	0.295	0.290	0.291	0.303	0.324	0.325	0.328	0.331	
	taud	2.557	2.598	2.614	2.630	2.636	2.621	2.625	2.606	2.540	2.554	2.566	2.570	
	Ebn at Noon	987	969	929	874	815	780	809	866	912	962	991	1000	
	Edh at Noon	105	95	85	71	59	55	59	71	90	98	103	105	
All-Sky Solar Radiation	RadAvg	6.38	5.41	4.04	2.74	1.69	1.35	1.57	2.35	3.56	4.99	5.81	6.56	
	RadStd	0.42	0.29	0.21	0.16	0.11	0.10	0.07	0.15	0.18	0.24	0.44	0.33	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (21 neighbors)		+0.33	N/A	N/A	+0.74	N/A	N/A	N/A	-111	+115	+19

Nomenclature: See separate page