

MARIA ISLAND, Australia

WMO: 959880

Lat: 42.6622S

Lon: 148.0178E

Elev: 93

StdP: 14.65

Time Zone: 10.00 (AUS)

Period: 04-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	41.5	42.7	31.2	25.5	46.2	32.6	27.2	46.6	42.0	51.7	38.1	53.8	13.9	290	0.715

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	11.7	75.9	63.7	72.7	62.4	70.6	61.5	66.2	72.3	64.8	69.9	63.6	68.6	18.7	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
64.3	90.5	67.9	62.9	86.1	67.4	61.4	81.5	66.4	31.0	72.4	30.0	69.9	29.0	68.7	72.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 36.9	32.4	29.2	39.1	85.2	1.1	4.0	38.4	88.1	37.7	90.5	37.1	92.7	36.4	95.6		
(5)			35.8	68.5	1.4	1.4	34.8	69.5	34.0	70.3	33.2	71.1	32.2	72.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	56.2	62.9	62.5	61.4	57.8	54.1	51.0	50.1	50.3	52.5	54.7	57.1	60.0
	DBStd	5.95	4.38	4.08	4.32	4.03	3.69	3.10	2.95	3.42	3.50	4.00	4.27	4.09
	HDD50	125	0	0	0	1	7	23	36	38	14	5	1	0
	HDD65	3301	93	91	129	216	338	419	463	454	375	321	239	163
	CDD50	2375	400	349	352	237	134	54	38	48	89	149	215	310
	CDD65	78	28	20	16	2	0	0	0	0	0	1	3	8
	CDH74	200	97	46	22	1	0	0	0	0	0	5	12	17
	CDH80	32	21	7	1	0	0	0	0	0	0	1	1	1
Wind	WSAvg	14.6	14.8	14.3	13.8	13.7	14.9	13.4	14.5	15.4	15.3	15.2	14.9	14.8
Precipitation	PrecAvg	21.0	2.2	1.5	1.6	1.8	1.2	1.9	1.7	1.8	1.8	1.5	2.3	2.1
	PrecMax	33.5	9.4	4.5	5.4	4.8	6.5	8.1	3.8	3.8	5.8	3.7	7.6	8.6
	PrecMin	13.4	0.1	0.3	0.2	0.1	0.0	0.3	0.0	0.3	0.5	0.4	0.1	0.0
	PrecStd	5.3	2.1	1.1	1.3	1.2	1.3	1.7	1.0	1.0	1.3	0.8	1.7	2.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	82.7	79.0	76.6	71.8	65.3	61.4	59.5	61.4	65.2	71.4	75.3	76.2
		MCWB	65.0	65.0	64.5	61.1	56.3	53.5	52.6	52.4	55.0	57.8	61.5	62.2
	2%	DB	76.1	74.1	72.7	68.4	63.2	59.0	57.5	59.3	62.4	66.6	69.6	72.0
		MCWB	63.5	64.7	63.0	59.7	55.4	53.0	51.3	52.0	53.5	55.8	59.7	60.8
	5%	DB	72.2	71.2	70.1	66.0	61.5	57.5	56.2	57.6	60.2	63.7	66.5	69.2
		MCWB	62.4	62.7	62.1	58.3	54.9	52.3	50.6	51.3	52.4	55.3	57.6	60.1
	10%	DB	69.8	68.9	68.0	64.1	60.1	56.1	55.0	56.0	58.4	61.3	63.9	66.8
		MCWB	61.4	61.9	60.9	57.6	54.2	51.3	49.9	50.5	51.6	54.1	56.7	58.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	68.6	67.7	67.1	63.3	58.5	56.5	54.7	54.8	57.0	60.2	63.5	65.1
		MCDB	75.6	73.3	71.7	67.9	61.9	57.9	57.7	57.9	62.0	64.8	70.3	71.7
	2%	WB	65.7	66.4	65.2	61.5	57.2	54.2	52.8	53.4	55.2	58.5	61.4	63.4
		MCDB	72.6	72.1	69.5	65.6	61.0	56.9	56.0	57.3	59.5	63.9	67.0	68.3
	5%	WB	64.4	64.9	63.8	60.1	56.0	53.0	51.4	52.2	53.8	56.8	59.8	61.9
		MCDB	70.0	69.4	68.6	64.2	60.3	56.3	55.1	56.6	58.6	62.2	64.6	66.9
	10%	WB	62.9	63.4	62.0	58.5	55.0	51.9	50.4	51.0	52.5	55.2	58.1	60.3
		MCDB	68.3	67.7	67.2	63.1	59.5	55.4	54.1	55.6	57.4	60.4	62.6	65.7
Mean Daily Temperature Range	5% DB	MDBR	11.7	10.8	10.4	9.6	8.3	7.4	7.6	8.7	10.1	11.0	10.7	11.0
		MCDBR	16.2	13.6	13.4	11.7	9.7	8.4	8.6	10.2	12.2	14.0	14.5	14.5
		MCWBR	8.8	7.8	7.6	6.8	6.6	5.8	6.2	6.7	7.6	8.2	8.0	8.6
	5% WB	MCDBR	14.6	12.0	11.8	10.5	8.3	7.3	7.7	9.0	10.9	12.6	12.6	12.5
		MCWBR	8.5	8.0	7.2	7.1	6.3	5.5	6.0	6.5	7.5	8.4	7.6	8.5
Clear-Sky Solar Irradiance	taub	0.351	0.340	0.335	0.320	0.305	0.297	0.293	0.309	0.331	0.338	0.342	0.341	
	taud	2.519	2.568	2.576	2.592	2.606	2.608	2.623	2.585	2.512	2.510	2.521	2.540	
	Ebn at Noon	309	304	291	273	255	246	257	273	287	301	310	314	
	Edh at Noon	35	31	28	24	20	18	19	23	30	33	34	34	
All-Sky Solar Radiation	RadAvg	2088	1769	1349	920	580	460	533	787	1192	1622	1876	2127	
	RadStd	152	77	67	59	35	36	25	49	66	87	145	111	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (26 neighbors)	+0.58	N/A	N/A	+1.35	N/A	N/A	N/A	-200	+207	+34

Nomenclature: See separate page