

MALIKUS SALEH, IndonesiaWMO: **960090**Lat: **5.2286N**Lon: **96.9475E**Elev: **285**StdP: **14.54**Time Zone: **7.00 (E07)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	71.6	72.5	68.4	105.6	76.2	69.6	109.9	76.8	14.5	83.5	12.9	84.0	3.3	210	0.298

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	13.2	91.0	79.1	90.1	79.0	89.4	78.9	81.0	87.9	80.6	87.7	80.1	87.0	7.1	40

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
79.1	152.5	85.2	78.4	149.3	84.7	78.1	147.5	84.3	45.0	88.6	44.4	88.0	43.9	87.5	87.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.8	10.0	9.1	DB	67.2	94.1	4.8	2.5	63.7	95.9	60.9	97.4	58.2	98.8	54.7	100.6	(4)
(5)			WB	64.7	83.4	4.4	2.1	61.5	84.9	59.0	86.1	56.5	87.3	53.3	88.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	80.8	79.4	79.6	80.8	81.5	82.5	82.4	81.7	81.4	80.7	80.2	79.7	79.4	(6)
(7)		DBStd	1.71	1.37	1.51	1.34	1.51	1.26	1.34	1.32	1.33	1.06	1.24	1.26	1.42	(7)
(8)		HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
(10)		CDD50	11232	912	829	954	946	1007	971	981	973	920	936	892	911	(10)
(11)		CDD65	5757	447	409	489	496	542	521	516	508	470	471	442	446	(11)
(12)		CDH74	57191	3976	3817	5043	5313	5969	5841	5498	5283	4562	4330	3811	3748	(12)
(13)	CDH80	19169	1015	1118	1793	1992	2315	2318	2068	1932	1501	1275	959	883	(13)	
(14)	Wind	WSAvg	3.5	4.0	4.1	3.7	3.4	3.5	3.4	3.5	3.6	3.2	3.1	3.1	3.8	(14)
(15)	Precipitation	PrecAvg	67.0	7.0	3.4	4.8	4.8	4.9	3.7	3.4	4.6	4.6	7.6	9.0	9.1	(15)
(16)		PrecMax	90.1	13.1	10.0	9.4	17.9	11.7	12.9	10.7	10.9	13.2	14.3	26.1	22.3	(16)
(17)		PrecMin	46.2	3.3	1.0	1.0	1.4	1.0	1.1	0.3	0.9	1.0	2.4	1.3	2.6	(17)
(18)		PrecStd	11.2	2.5	1.9	2.2	3.3	2.9	2.6	2.7	2.9	2.9	2.9	5.2	5.0	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	87.8	88.6	90.3	91.6	92.0	91.8	91.1	90.9	89.7	89.1	87.6	87.3	(19)
MCWB			78.4	78.3	79.5	80.5	79.6	77.9	78.3	78.1	78.0	78.0	78.6	78.0	(20)	
2%		DB	86.6	87.3	89.0	90.3	90.7	90.6	89.8	89.7	88.2	88.0	86.6	86.3	(21)	
		MCWB	78.0	77.9	79.4	80.1	79.5	78.6	78.4	78.3	78.2	78.1	78.4	77.9	(22)	
5%		DB	85.7	86.3	88.0	89.0	89.6	89.6	89.0	88.8	87.4	86.9	85.8	85.4	(23)	
		MCWB	77.7	77.7	79.0	79.6	79.3	79.0	78.3	78.3	78.2	78.1	78.3	77.7	(24)	
10%		DB	84.7	85.5	87.0	87.8	88.6	88.7	88.0	87.7	86.5	85.8	84.9	84.5	(25)	
		MCWB	77.3	77.5	78.7	79.1	79.2	78.8	78.2	78.2	78.1	78.1	78.1	77.4	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	80.0	79.9	81.0	81.6	81.7	81.2	80.8	80.6	80.5	80.4	80.0	79.9	(27)
MCD B			85.7	86.3	87.7	89.2	88.8	88.1	88.1	87.4	86.4	86.2	85.6	85.2	(28)	
2%		WB	79.1	79.1	80.1	80.8	80.9	80.5	79.9	79.7	79.6	79.2	79.2	79.0	(29)	
		MCD B	84.8	85.4	87.1	88.4	88.1	87.7	87.2	86.8	85.8	85.2	84.7	84.3	(30)	
5%		WB	78.4	78.4	79.6	80.1	80.3	80.0	79.3	79.1	79.0	78.9	78.8	78.4	(31)	
		MCD B	83.9	84.5	86.5	87.4	87.4	87.1	86.5	86.3	85.4	84.9	84.2	83.5	(32)	
10%		WB	77.9	78.0	79.0	79.6	79.8	79.4	78.8	78.6	78.4	78.3	78.3	77.9	(33)	
		MCD B	83.2	83.9	85.8	86.6	86.8	86.5	86.0	85.7	84.7	84.0	83.3	82.8	(34)	
(35)	Mean Daily Temperature Range	5% DB	MDBR	11.1	12.3	13.1	12.9	13.0	13.2	13.1	12.8	12.2	11.3	10.4	10.2	(35)
MCDBR			12.4	13.5	14.2	14.2	14.1	14.3	14.2	14.3	13.5	12.9	11.9	11.9	(36)	
MCWBR			5.7	6.3	6.9	6.6	5.6	5.6	5.6	5.6	5.8	5.8	5.4	5.2	(37)	
5% WB		MCD BR	11.5	12.8	13.5	13.4	13.0	13.2	13.5	13.2	12.5	11.8	11.1	11.0	(38)	
		MCWBR	5.7	6.3	7.0	6.6	5.8	5.8	6.0	5.7	6.0	5.8	5.4	5.2	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.458	0.481	0.474	0.453	0.431	0.427	0.424	0.429	0.426	0.435	0.431	0.446	(40)	
taud		2.330	2.236	2.277	2.349	2.433	2.451	2.453	2.421	2.425	2.411	2.427	2.383	(41)		
Ebn at Noon		274	270	272	272	272	270	272	275	281	280	280	275	(42)		
Edh at Noon		41	46	45	41	36	35	36	37	38	38	37	39	(43)		
(44)	All-Sky Solar Radiation	RadAvg	1439	1638	1697	1616	1596	1583	1568	1569	1541	1442	1288	1268	(44)	
(45)		RadStd	107	101	111	91	72	100	88	87	100	109	80	101	(45)	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page