

MALIKUS SALEH, Indonesia

WMO: 960090

Lat: 5.2286N

Lon: 96.9475E

Elev: 87

StdP: 100.28

Time Zone: 7.00 (E07)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	22.0	22.5	20.2	15.1	24.6	20.9	15.7	24.9	6.5	28.6	5.8	28.9	1.5	210	0.298

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	7.3	32.8	26.1	32.3	26.1	31.9	26.1	27.2	31.1	27.0	30.9	26.7	30.5	3.2	40

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.2	21.8	29.6	25.8	21.3	29.3	25.6	21.1	29.1	86.7	31.4	85.4	31.1	84.3	30.8	30.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 5.3	4.5	4.1	19.5	34.5	2.7	1.4	17.6	35.5	16.1	36.3	14.6	37.1	12.6	38.1		
(5)			18.2	28.5	2.4	1.2	16.4	29.4	15.0	30.1	13.6	30.7	11.9	31.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	27.1	26.3	26.4	27.1	27.5	28.1	28.0	27.6	27.4	27.0	26.8	26.5	26.3	(6)
(7)		DBStd	0.95	0.76	0.84	0.74	0.84	0.70	0.74	0.73	0.74	0.59	0.69	0.70	0.79	(7)
(8)		HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
(10)		CDD10.0	6240	507	461	530	526	559	539	545	541	511	520	496	506	(10)
(11)		CDD18.3	3198	248	227	272	276	301	289	287	282	261	262	246	248	(11)
(12)		CDH23.3	31773	2209	2121	2802	2952	3316	3245	3054	2935	2534	2406	2117	2082	(12)
(13)		CDH26.7	10649	564	621	996	1107	1286	1288	1149	1073	834	708	533	491	(13)
(14)	Wind	WSAvg	1.6	1.8	1.8	1.6	1.5	1.6	1.5	1.6	1.6	1.4	1.4	1.4	1.7	(14)
(15)	Precipitation	PrecAvg	1702	179	87	121	123	124	93	87	116	117	193	229	232	(15)
(16)		PrecMax	2289	333	253	240	455	298	328	273	276	335	363	664	566	(16)
(17)		PrecMin	1174	84	25	26	35	25	27	8	23	26	60	34	66	(17)
(18)		PrecStd	284	63	47	57	84	74	65	68	69	73	73	133	127	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	31.0	31.4	32.4	33.1	33.4	33.2	32.8	32.7	32.1	31.7	30.9	30.7	(19)
(20)			MCWB	25.8	25.7	26.4	26.9	26.4	25.5	25.7	25.6	25.5	25.6	25.9	25.5	(20)
(21)		2%	DB	30.3	30.7	31.7	32.4	32.6	32.5	32.1	32.1	31.2	31.1	30.3	30.2	(21)
(22)			MCWB	25.6	25.5	26.3	26.7	26.4	25.9	25.8	25.7	25.7	25.6	25.8	25.5	(22)
(23)		5%	DB	29.8	30.2	31.1	31.7	32.0	32.0	31.6	31.5	30.8	30.5	29.9	29.7	(23)
(24)			MCWB	25.4	25.4	26.1	26.4	26.3	26.1	25.7	25.7	25.7	25.6	25.7	25.4	(24)
(25)		10%	DB	29.3	29.7	30.6	31.0	31.4	31.5	31.1	30.9	30.3	29.9	29.4	29.1	(25)
(26)			MCWB	25.2	25.3	25.9	26.2	26.2	26.0	25.7	25.7	25.6	25.6	25.6	25.2	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.7	26.6	27.2	27.5	27.6	27.3	27.1	27.0	26.9	26.9	26.7	26.6	(27)
(28)			MADB	29.8	30.2	31.0	31.8	31.5	31.2	31.2	30.8	30.2	30.1	29.8	29.6	(28)
(29)		2%	WB	26.2	26.1	26.7	27.1	27.2	27.0	26.6	26.5	26.5	26.2	26.2	26.1	(29)
(30)			MADB	29.3	29.6	30.6	31.3	31.1	30.9	30.7	30.4	29.9	29.5	29.3	29.1	(30)
(31)		5%	WB	25.8	25.8	26.5	26.7	26.8	26.6	26.3	26.2	26.1	26.1	26.0	25.8	(31)
(32)			MADB	28.8	29.2	30.3	30.8	30.8	30.6	30.3	30.1	29.6	29.4	29.0	28.6	(32)
(33)		10%	WB	25.5	25.5	26.1	26.4	26.5	26.3	26.0	25.9	25.8	25.7	25.7	25.5	(33)
(34)			MADB	28.4	28.8	29.9	30.3	30.4	30.3	30.0	29.8	29.3	28.9	28.5	28.2	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	6.2	6.8	7.3	7.2	7.2	7.3	7.3	7.1	6.8	6.3	5.8	5.7	(35)
(36)			MCDBR	6.9	7.5	7.9	7.9	7.8	7.9	7.9	8.0	7.5	7.2	6.6	6.6	(36)
(37)			MCWBR	3.2	3.5	3.8	3.6	3.1	3.1	3.1	3.1	3.2	3.2	3.0	2.9	(37)
(38)		5% WB	MCDBR	6.4	7.1	7.5	7.4	7.2	7.3	7.5	7.3	6.9	6.6	6.2	6.1	(38)
(39)			MCWBR	3.2	3.5	3.9	3.7	3.2	3.2	3.3	3.2	3.3	3.2	3.0	2.9	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.458	0.481	0.474	0.453	0.431	0.427	0.424	0.429	0.426	0.435	0.431	0.446	(40)	
(41)		taud	2.330	2.236	2.277	2.349	2.433	2.451	2.453	2.421	2.425	2.411	2.427	2.383	(41)	
(42)		Ebn at Noon	864	851	857	859	859	851	857	868	885	882	883	868	(42)	
(43)		Edh at Noon	130	146	141	129	115	111	112	118	120	121	117	122	(43)	
(44)	All-Sky Solar Radiation	RadAvg	4.54	5.16	5.35	5.09	5.03	4.99	4.94	4.95	4.86	4.55	4.06	4.00	(44)	
(45)		RadStd	0.34	0.32	0.35	0.29	0.23	0.32	0.28	0.27	0.32	0.34	0.25	0.32	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(47) Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Nomenclature: See separate page