

BANDA ACEH BLANG BINTANG, IndonesiaWMO: **960110**Lat: **5.5225N**Lon: **95.4169E**Elev: **69**StdP: **14.66**Time Zone: **7.00 (E07)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	71.3	72.3	64.8	92.1	88.6	66.2	96.7	87.5	20.6	83.7	16.8	84.6	3.3	150	0.320

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	15.3	94.3	76.2	93.1	76.5	92.1	76.9	81.2	88.0	80.3	87.8	79.7	87.2	9.2	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
79.5	153.3	84.6	78.3	147.2	84.0	77.5	143.6	83.4	45.0	88.4	44.0	88.2	43.3	87.7	91.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.9	13.9	11.9	DB	68.2	97.2	3.4	2.2	65.7	98.7	63.7	100.0	61.7	101.2	59.2	102.7	(4)
(5)			WB	65.2	84.3	3.0	2.9	63.1	86.4	61.4	88.1	59.7	89.7	57.5	91.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	81.8	80.2	80.6	81.5	82.3	83.1	83.4	83.0	82.6	82.2	81.1	80.7	80.2	(6)	
	DBStd	2.05	1.59	1.44	1.48	1.65	1.54	1.87	2.12	1.95	1.90	1.70	1.57	1.63	(7)	
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)	
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)	
	CDD50	11588	937	858	977	968	1025	1003	1023	1011	965	964	922	935	(10)	
	CDD65	6113	472	438	512	518	560	553	558	546	515	499	472	470	(11)	
	CDH74	61723	4233	4146	5135	5365	6106	6350	6263	5895	5260	4644	4203	4123	(12)	
(13)	CDH80	23216	1280	1404	1890	2062	2456	2804	2770	2494	2093	1587	1230	1146	(13)	
(14)	Wind	WSAvg	4.5	5.2	5.1	4.6	3.9	4.1	4.6	4.7	4.2	4.0	4.2	5.0	(14)	
(15) Precipitation	PrecAvg	58.4	5.4	3.9	4.2	5.0	5.6	2.2	2.7	2.7	5.2	6.8	6.6	8.8	(15)	
	PrecMax	75.3	20.0	13.8	9.3	9.2	20.2	5.3	11.2	7.4	12.0	17.8	13.3	20.7	(16)	
	PrecMin	40.1	0.7	0.0	1.2	1.7	0.6	0.2	0.0	0.2	1.0	1.5	0.5	2.0	(17)	
	PrecStd	7.4	3.7	3.0	2.0	2.3	4.3	1.5	2.5	2.0	2.7	3.6	2.8	4.6	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	90.0	90.8	91.6	92.9	94.2	95.2	95.4	95.3	94.4	92.6	90.7	89.6	(19)	
		MCWB	77.6	77.7	78.7	79.5	77.7	76.2	75.7	75.7	75.7	76.1	77.2	77.9	(20)	
	2%	DB	88.5	89.4	90.4	91.5	92.5	93.6	93.9	93.3	92.5	90.6	88.9	88.1	(21)	
		MCWB	77.4	77.6	78.6	79.4	78.1	76.3	75.8	75.9	76.0	76.3	77.5	77.5	(22)	
	5%	DB	87.3	88.2	89.4	90.3	91.2	92.4	92.5	91.8	91.0	89.1	87.6	87.0	(23)	
		MCWB	77.2	77.5	78.4	79.0	78.3	76.6	76.0	76.1	76.3	76.6	77.5	77.4	(24)	
	10%	DB	86.1	87.1	88.1	88.9	89.7	90.9	90.9	90.2	89.4	87.2	86.2	85.8	(25)	
		MCWB	76.9	77.3	78.1	78.6	78.3	76.8	76.1	76.2	76.4	76.8	77.4	77.2	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	79.7	80.2	82.2	84.8	84.4	81.5	80.2	79.5	80.0	79.8	79.9	79.9	(27)	
		MCDB	86.5	87.1	86.8	87.1	86.7	89.2	88.9	88.6	88.7	87.0	86.6	86.6	(28)	
	2%	WB	78.8	79.2	80.2	80.9	81.0	79.7	78.8	78.5	78.9	78.9	79.0	78.9	(29)	
		MCDB	85.9	86.3	87.5	88.1	88.0	88.2	87.8	88.0	87.2	85.9	85.7	85.6	(30)	
	5%	WB	78.1	78.6	79.4	80.0	80.0	78.8	78.0	77.8	78.1	78.2	78.3	78.2	(31)	
		MCDB	84.8	85.6	86.8	87.5	87.5	87.4	87.2	87.0	86.2	84.9	84.7	84.5	(32)	
	10%	WB	77.5	78.0	78.7	79.2	79.2	78.0	77.2	77.1	77.4	77.5	77.8	77.5	(33)	
		MCDB	83.9	84.7	86.0	86.5	86.6	86.4	86.5	86.1	85.1	84.0	83.9	83.4	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	12.8	13.8	14.0	14.2	14.4	15.3	15.8	15.4	14.8	13.2	11.7	11.6	(35)	
		MCDBR	14.3	15.4	15.5	15.7	16.1	17.6	18.3	18.1	17.2	15.8	13.8	13.5	(36)	
	5% WB	MCWBR	5.3	5.9	6.1	5.8	5.1	5.2	5.3	5.1	5.1	5.1	4.9	5.1	(37)	
		MCWBR	12.8	13.6	14.0	14.3	14.1	15.6	15.9	15.7	14.9	13.0	12.3	11.8	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.464	0.485	0.482	0.454	0.434	0.433	0.433	0.425	0.418	0.433	0.433	0.457	(40)	
		taud	2.322	2.234	2.272	2.360	2.450	2.462	2.448	2.457	2.466	2.431	2.429	2.353	(41)	
	Ebn at Noon		272	269	270	272	272	268	270	277	283	280	279	272	(42)	
		Edh at Noon	42	46	45	41	36	35	36	36	36	38	37	40	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1526	1725	1751	1701	1605	1599	1566	1611	1592	1485	1372	1365	(44)	
(45)		RadStd	96	92	99	90	92	104	67	76	62	108	80	86	(45)	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page