

MEULABOH CUT NYAK DHLEN, Indonesia

WMO: 960150

Lat: 4.0492N

Lon: 96.2481E

Elev: 10

StdP: 14.69

Time Zone: 7.00 (E07)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11	71.5	72.3	69.4	108.1	73.9	70.4	112.1	74.4	18.7	78.5	12.4	82.5	2.9	90	0.292

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	12.1	89.9	81.5	89.1	81.2	88.6	81.0	83.5	88.2	82.8	87.6	82.4	87.3	6.3	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
81.9	166.1	87.4	81.4	163.4	87.0	80.9	160.4	86.5	47.4	88.4	46.8	88.0	46.2	87.5	86.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.3	10.4	9.4	68.5	92.0	3.3	1.5	66.1	93.1	64.2	94.0	62.4	94.8	60.0	95.9		
(5)			66.1	84.9	3.3	1.3	63.7	85.9	61.8	86.6	59.9	87.3	57.5	88.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	80.4	80.4	80.5	81.1	81.1	81.4	80.9	80.1	79.9	80.1	79.8	79.8	80.1	(6)
(7)		DBStd	1.56	1.28	1.57	1.51	1.44	1.35	1.53	1.59	1.57	1.57	1.41	1.27	1.40	(7)
(8)		HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
(10)		CDD50	11109	944	854	965	934	972	928	932	927	902	925	893	933	(10)
(11)		CDD65	5634	479	434	500	484	507	478	467	462	452	460	443	468	(11)
(12)		CDH74	53939	4673	4274	5104	4824	5285	4907	4494	4262	4145	3986	3764	4221	(12)
(13)	CDH80	17812	1541	1473	1830	1644	1862	1799	1541	1380	1322	1177	1011	1232	(13)	
(14)	Wind	WSAvg	3.5	3.7	3.8	3.6	3.3	3.6	3.7	3.8	3.6	3.2	3.2	3.4	3.5	(14)
(15)	Precipitation	PrecAvg	151.8	10.8	9.2	13.4	15.4	12.2	9.6	9.8	11.6	13.4	15.5	17.7	12.6	(15)
(16)		PrecMax	194.5	23.5	17.2	26.7	23.1	30.2	19.4	17.6	27.9	27.2	27.9	26.4	28.8	(16)
(17)		PrecMin	124.8	5.0	3.9	3.4	7.0	4.2	2.0	3.8	5.0	4.6	4.1	9.0	5.7	(17)
(18)		PrecStd	18.7	4.8	3.6	6.1	4.0	6.3	3.9	3.7	5.7	5.9	5.2	4.8	4.8	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	89.1	89.7	90.4	89.9	90.0	90.6	90.0	89.8	89.7	89.0	88.0	88.6	(19)
MCWB			81.8	81.9	82.2	82.1	82.5	81.0	80.8	80.4	79.4	80.6	80.8	81.0	(20)	
2%		DB	88.0	88.5	89.1	88.9	89.0	89.4	88.8	88.1	88.2	87.9	86.7	87.3	(21)	
		MCWB	80.9	81.2	82.0	81.7	81.7	81.0	80.3	80.3	79.8	80.4	80.2	80.6	(22)	
5%		DB	87.2	87.7	88.2	87.9	88.1	88.4	87.8	87.2	87.2	86.9	85.9	86.6	(23)	
		MCWB	80.4	80.7	81.5	81.2	81.2	80.5	79.9	79.9	79.7	80.1	79.9	80.1	(24)	
10%		DB	86.4	86.8	87.3	87.0	87.3	87.4	86.8	86.2	86.1	85.8	85.0	85.7	(25)	
		MCWB	79.9	80.2	80.9	80.7	80.8	80.0	79.5	79.5	79.4	79.7	79.5	79.7	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	83.5	83.6	83.7	83.7	84.2	83.6	82.8	82.7	82.6	82.6	82.4	82.8	(27)
MCD B			87.8	88.4	88.8	88.2	88.9	88.5	88.0	87.4	87.0	87.1	86.4	86.8	(28)	
2%		WB	82.3	82.5	82.9	82.7	83.1	82.6	81.9	81.8	81.6	81.7	81.5	81.7	(29)	
		MCD B	86.9	87.4	88.2	87.6	87.8	87.9	87.3	86.7	86.4	86.4	85.7	86.1	(30)	
5%		WB	81.4	81.7	82.2	81.9	82.3	81.7	80.8	80.8	80.6	80.9	80.7	80.9	(31)	
		MCD B	86.1	86.7	87.5	86.9	87.1	87.1	86.4	85.9	85.8	85.9	85.0	85.5	(32)	
10%		WB	80.5	80.8	81.4	81.1	81.5	80.7	79.9	79.8	79.8	80.0	79.9	80.1	(33)	
		MCD B	85.4	85.8	86.6	86.1	86.3	86.3	85.5	85.1	85.0	84.9	84.1	84.7	(34)	
(35)	Mean Daily Temperature Range	5% DB	MDBR	12.3	12.6	12.5	11.7	12.1	13.1	13.2	12.4	12.2	11.3	10.7	11.4	(35)
MCDBR			13.3	13.8	13.6	12.8	13.2	14.4	14.9	14.1	13.7	13.4	11.9	12.7	(36)	
MCWBR			7.2	7.8	7.5	7.1	7.4	7.9	8.2	7.8	7.1	7.4	6.7	6.9	(37)	
5% WB		MCDBR	12.5	13.1	13.1	12.2	12.4	13.9	14.4	13.4	12.9	12.6	11.4	11.8	(38)	
		MCWBR	7.7	8.1	7.8	7.4	7.5	8.5	8.7	8.2	7.6	7.6	7.0	7.1	(39)	
(40)	Clear-Sky Solar Irradiance	taub		0.428	0.458	0.463	0.434	0.418	0.420	0.418	0.424	0.418	0.431	0.414	0.411	(40)
taud		2.429	2.321	2.328	2.423	2.482	2.483	2.484	2.450	2.457	2.422	2.480	2.489	(41)		
Ebn at Noon		284	277	275	278	276	271	273	277	283	281	286	287	(42)		
Edh at Noon		38	43	43	38	35	34	34	36	37	38	36	35	(43)		
(44)	All-Sky Solar Radiation	RadAvg		1586	1710	1740	1643	1639	1583	1558	1589	1571	1521	1438	1463	(44)
(45)		RadStd		70	104	83	87	80	105	69	94	81	125	72	75	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page