

GUNUNG SITOLI BINAKA, Indonesia

WMO: 960750

Lat: 1.1650N

Lon: 97.7036E

Elev: 23

StdP: 14.68

Time Zone: 7.00 (E07)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 10	(b) 71.3	(c) 72.1	(d) 70.3	(e) 111.7	(f) 73.4	(g) 71.2	(h) 115.0	(i) 73.7	(j) 16.0	(k) 83.4	(l) 12.5	(m) 82.7	(n) 0.8	(o) N/A	(p) 0.264

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	12.2	90.5	81.4	89.5	81.2	88.7	80.9	83.5	88.2	82.7	87.5	82.2	87.0	7.3	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
82.1	167.2	86.9	81.4	163.5	86.4	80.8	160.1	85.9	47.5	88.3	46.7	87.8	46.1	87.2	89.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 12.5	(b) 10.6	(c) 9.3	(e) 69.2	(f) 93.2	(g) 1.2	(h) 1.7	(i) 68.4	(j) 94.4	(k) 67.6	(l) 95.4	(m) 66.9	(n) 96.3	(o) 66.0	(p) 97.6		
(a) 12.5	(b) 10.6	(c) 9.3	(e) 68.3	(f) 85.1	(g) 1.5	(h) 2.1	(i) 67.2	(j) 86.6	(k) 66.3	(l) 87.8	(m) 65.5	(n) 89.0	(o) 64.4	(p) 90.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	80.3	80.3	80.8	81.1	80.8	81.2	80.9	79.8	79.9	79.9	79.4	79.5	79.8
	DBStd	1.70	1.50	1.76	1.63	1.65	1.54	1.46	1.61	1.65	1.53	1.60	1.60	1.52
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	11049	939	862	965	923	966	926	925	926	897	911	886	923
	CDD65	5574	474	442	500	473	501	476	460	461	447	446	436	458
	CDH74	48918	4205	4224	4801	4356	4809	4435	3877	3845	3709	3516	3387	3754
(13) Wind	CDH80	14888	1288	1443	1589	1312	1604	1524	1234	1167	1050	896	793	988
	WSAvg	2.3	2.2	2.5	2.5	2.1	2.4	2.4	2.4	2.6	2.3	2.3	2.3	2.1
(15) Precipitation	PrecAvg	116.9	8.7	6.1	8.7	10.1	8.5	7.2	9.1	9.6	10.4	13.1	13.6	11.7
	PrecMax	146.5	20.3	15.9	16.7	21.0	16.2	13.9	15.3	15.0	17.0	22.4	19.4	17.9
	PrecMin	79.8	1.8	0.0	0.1	4.0	2.7	0.0	4.9	5.7	4.7	7.2	5.1	6.5
	PrecStd	14.4	4.0	3.3	3.1	4.1	3.6	2.9	2.9	2.3	3.0	4.1	3.7	3.0
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	91.1	91.7	91.3	90.8	90.7	90.5	89.8	89.8	89.9	88.7	89.1	89.5
		MCWB	80.8	80.9	80.9	82.5	82.3	81.8	80.8	81.2	81.7	80.8	80.6	80.0
	2%	DB	88.6	89.6	89.4	89.0	89.2	89.1	88.3	88.2	88.0	87.3	87.2	87.5
		MCWB	80.4	80.9	81.1	81.6	81.6	81.3	80.3	80.7	80.9	80.2	80.3	80.1
	5%	DB	87.3	88.2	88.3	87.7	88.2	88.3	87.3	87.3	86.8	86.2	85.8	86.3
		MCWB	80.2	80.5	80.9	81.0	81.1	81.0	80.0	80.4	80.2	80.0	79.9	79.8
	10%	DB	86.1	86.9	87.1	86.3	87.1	87.3	86.2	86.0	85.5	84.9	84.5	85.1
		MCWB	79.9	80.1	80.6	80.4	80.8	80.6	79.7	80.0	79.7	79.5	79.4	79.5
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	83.0	83.6	83.7	84.0	84.0	84.0	82.8	83.0	83.4	82.8	82.3	82.5
		MCDB	88.1	88.9	88.3	88.9	88.6	88.7	87.5	87.2	88.4	86.8	86.7	86.6
	2%	WB	81.8	82.4	82.6	82.6	82.8	82.7	81.9	81.9	82.0	81.6	81.3	81.3
		MCDB	86.7	87.7	87.7	87.5	87.5	87.5	86.6	86.5	86.6	85.8	85.7	85.5
	5%	WB	81.0	81.4	81.7	81.6	82.0	81.8	80.9	81.0	81.0	80.6	80.4	80.5
		MCDB	85.7	86.7	86.8	86.4	86.8	86.7	85.7	85.8	85.5	84.8	84.8	84.8
	10%	WB	80.1	80.5	80.8	80.7	81.0	81.0	79.9	80.2	80.1	79.7	79.6	79.7
		MCDB	84.7	85.6	85.7	85.3	85.9	86.0	84.9	85.1	84.4	83.8	83.7	84.0
(35) Mean Daily Temperature Range	5% DB	MDBR	12.0	12.7	12.3	11.3	12.2	12.6	12.8	12.0	11.6	10.8	10.2	11.0
		MCDBR	13.8	14.6	14.0	13.3	13.7	14.3	14.8	14.2	13.5	13.0	12.4	13.0
		MCWBR	7.0	7.4	7.0	6.8	7.2	7.7	7.8	7.4	7.0	6.4	6.7	6.7
	5% WB	MCDBR	12.8	13.6	13.0	12.5	12.7	13.5	13.7	13.4	12.6	12.0	11.6	11.9
		MCWBR	7.4	7.8	7.5	7.1	7.5	7.9	8.1	8.0	7.7	7.2	6.6	6.9
(40) Clear-Sky Solar Irradiance	taub		0.420	0.461	0.472	0.416	0.413	0.423	0.419	0.438	0.444	0.480	0.425	0.400
	taud		2.464	2.325	2.311	2.489	2.507	2.490	2.491	2.421	2.397	2.288	2.453	2.528
	Ebn at Noon		288	278	272	282	276	269	272	272	276	269	285	293
	Edh at Noon		37	43	43	36	34	34	34	37	39	44	37	34
(44) All-Sky Solar Radiation	RadAvg		1578	1680	1657	1554	1591	1520	1495	1501	1466	1461	1372	1460
	RadStd		58	120	84	83	95	72	78	76	97	174	92	75

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)	N/A	N/A	N/A	+0.68	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page