

TAREMPA, Indonesia

WMO: 961450

Lat: 3.215N

Lon: 106.220E

Elev: 10

StdP: 14.69

Time Zone: 7.00 (E07)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	74.3	75.2	69.4	108.1	78.0	70.4	112.0	78.5	19.7	80.1	17.6	81.4	4.2	160	0.364

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	10.4	92.2	80.1	91.4	79.9	90.6	79.7	81.6	89.2	80.9	88.6	80.5	88.1	7.6	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
79.3	151.9	85.5	78.8	149.8	85.1	78.3	147.0	84.7	45.2	89.6	44.6	89.3	44.1	88.6	87.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.1	13.9	12.2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			68.8	83.3	2.7	1.8	66.8	84.6	65.3	85.7	63.8	86.7	61.8	88.0
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	82.6	80.6	80.4	81.8	83.0	84.3	84.4	84.2	84.1	83.4	82.4	81.8	81.0
	DBStd	2.25	1.75	1.53	1.64	1.54	1.72	1.94	1.82	1.94	1.83	1.78	1.55	1.72
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	11901	947	851	984	989	1062	1031	1060	1056	1002	1005	953	961
	CDD65	6426	482	431	519	539	597	581	595	591	552	540	503	496
	CDH74	69951	4658	4086	5503	6027	6989	6841	6985	6852	6230	5718	5077	4985
	CDH80	22643	815	693	1573	2083	2769	2733	2762	2660	2276	1826	1367	1086
(14) Wind	WSAvg	5.1	6.7	6.2	4.5	4.5	4.6	4.9	5.3	5.5	5.3	4.8	3.8	5.2
(15) Precipitation	PrecAvg	100.7	8.6	5.0	6.3	5.3	6.9	7.4	6.6	5.4	6.9	10.8	14.9	16.1
	PrecMax	125.7	23.2	19.6	14.4	15.6	13.5	18.5	15.3	15.2	13.4	23.7	31.1	35.7
	PrecMin	63.9	0.6	0.0	0.2	1.3	2.3	1.1	0.9	2.1	0.2	2.0	1.9	6.8
	PrecStd	15.9	5.2	5.0	4.0	3.0	3.1	4.7	4.0	3.1	3.4	6.2	7.1	7.4
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	87.2	86.7	89.4	91.8	93.3	92.8	92.6	92.4	91.8	91.4	90.0	88.1
		MCWB	78.7	77.9	79.1	79.9	81.0	80.4	79.9	79.6	79.4	79.9	79.3	79.1
	2%	DB	85.9	85.4	87.9	90.0	91.8	91.8	91.3	91.3	90.6	90.0	88.4	86.6
		MCWB	78.4	77.6	78.5	79.8	80.7	80.2	79.6	79.3	79.2	79.5	79.2	79.0
	5%	DB	84.6	84.4	86.8	88.8	90.7	90.9	90.2	90.4	89.7	88.7	87.2	85.5
		MCWB	77.8	77.3	78.2	79.6	80.5	80.0	79.3	79.1	79.0	79.2	79.0	78.8
	10%	DB	83.5	83.5	85.9	87.6	89.4	89.7	89.2	89.3	88.6	87.3	85.9	84.5
		MCWB	77.4	77.0	78.0	79.4	80.2	79.9	79.0	78.9	78.7	78.9	78.8	78.5
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	80.0	79.2	80.3	81.5	82.7	81.9	81.0	81.0	80.9	81.0	80.5	80.2
		MCDB	84.5	83.3	86.7	88.5	90.2	90.2	89.6	88.9	89.0	88.6	86.9	85.2
	2%	WB	79.1	78.5	79.7	80.8	81.7	81.0	80.4	80.1	80.1	80.1	79.9	79.8
		MCDB	83.7	83.1	85.7	87.6	89.3	89.2	88.9	88.5	88.1	87.4	86.0	84.7
	5%	WB	78.5	78.1	79.1	80.1	81.0	80.5	79.9	79.8	79.7	79.8	79.5	79.2
		MCDB	83.0	82.7	84.9	86.7	88.5	88.6	88.0	87.9	87.4	86.8	85.4	84.0
	10%	WB	78.1	77.6	78.7	79.7	80.5	80.0	79.4	79.2	79.1	79.2	79.0	78.8
		MCDB	82.4	82.1	84.2	86.1	87.9	87.5	87.1	87.0	86.4	85.8	84.7	83.5
(35) Mean Daily Temperature Range	5% DB	MDBR	5.3	6.0	8.0	9.7	10.7	10.4	10.2	10.4	10.3	9.6	8.8	6.4
		MCDBR	6.7	7.3	9.7	11.0	12.0	11.8	11.4	11.4	11.5	11.5	10.7	8.4
	5% WB	MCWBR	2.7	2.9	3.7	4.4	4.3	3.9	3.7	3.7	3.9	4.4	4.2	3.6
		MCWBR	6.1	6.4	8.4	10.0	10.9	10.7	10.7	11.0	10.8	10.2	9.3	7.6
(40) Clear-Sky Solar Irradiance	taub	taub	0.461	0.449	0.442	0.419	0.425	0.449	0.447	0.483	0.494	0.502	0.433	0.471
		taud	2.362	2.388	2.414	2.480	2.473	2.417	2.416	2.288	2.248	2.227	2.442	2.338
	Ebn at Noon	Ebn at Noon	275	280	281	282	273	263	265	261	263	262	281	270
		Edh at Noon	40	40	39	36	35	36	37	43	45	46	37	41
(44) All-Sky Solar Radiation	RadAvg	RadAvg	1500	1781	1926	1971	1781	1573	1587	1640	1601	1534	1491	1383
	RadStd	RadStd	145	161	157	93	85	89	134	106	97	124	105	156

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page