

TAREMPA, Indonesia

WMO: 961450

Lat: 3.215N

Lon: 106.220E

Elev: 3

StdP: 101.29

Time Zone: 7.00 (E07)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	23.5	24.0	20.8	15.4	25.5	21.3	16.0	25.8	8.8	26.7	7.9	27.5	1.9	160	0.364

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	5.8	33.4	26.7	33.0	26.6	32.6	26.5	27.5	31.8	27.2	31.4	27.0	31.2	3.4	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.3	21.7	29.7	26.0	21.4	29.5	25.7	21.0	29.3	87.3	32.0	85.9	31.8	84.8	31.5	30.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7.2	6.2	5.5	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			20.4	28.5	1.5	1.0	19.4	29.2	18.5	29.8	17.7	30.4	16.6	31.1
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	28.1	27.0	26.9	27.6	28.3	29.0	29.1	29.0	28.9	28.6	28.0	27.6	27.2
	DBStd	1.25	0.97	0.85	0.91	0.86	0.96	1.08	1.01	1.08	1.02	0.99	0.86	0.96
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	6612	526	473	547	549	590	573	589	587	557	558	529	534
	CDD18.3	3570	268	239	288	299	332	323	331	328	307	300	279	276
	CDH23.3	38862	2588	2270	3057	3348	3883	3801	3881	3807	3461	3177	2821	2769
	CDH26.7	12579	453	385	874	1157	1538	1518	1534	1478	1264	1014	759	603
(14) Wind	WSAvg	2.3	3.0	2.8	2.0	2.0	2.1	2.2	2.4	2.4	2.4	2.2	1.7	2.3
(15) Precipitation	PrecAvg	2558	219	128	159	135	176	187	167	137	175	275	378	408
	PrecMax	3193	590	498	365	396	343	470	389	386	341	601	791	906
	PrecMin	1623	15	1	6	34	59	27	23	54	5	50	48	172
	PrecStd	404	133	126	102	76	78	120	102	79	87	157	181	188
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	30.7	30.4	31.9	33.2	34.1	33.8	33.7	33.6	33.2	33.0	32.2	31.2
		MCWB	26.0	25.5	26.2	26.6	27.2	26.9	26.6	26.4	26.3	26.6	26.3	26.2
	2%	DB	29.9	29.6	31.0	32.2	33.2	33.2	33.0	32.9	32.6	32.2	31.3	30.3
		MCWB	25.8	25.3	25.8	26.5	27.1	26.8	26.4	26.3	26.2	26.4	26.2	26.1
	5%	DB	29.2	29.1	30.5	31.6	32.6	32.7	32.3	32.4	32.0	31.5	30.7	29.7
		MCWB	25.5	25.1	25.7	26.4	26.9	26.7	26.3	26.2	26.1	26.2	26.1	26.0
	10%	DB	28.6	28.6	29.9	30.9	31.9	32.1	31.8	31.8	31.4	30.7	30.0	29.2
		MCWB	25.2	25.0	25.6	26.3	26.8	26.6	26.1	26.1	26.0	26.0	26.0	25.8
	0.4%	WB	26.7	26.2	26.8	27.5	28.2	27.7	27.2	27.2	27.2	27.2	27.0	26.8
		MCDB	29.2	28.5	30.4	31.4	32.3	32.3	32.0	31.6	31.7	31.4	30.5	29.6
	2%	WB	26.2	25.8	26.5	27.1	27.6	27.2	26.9	26.7	26.7	26.7	26.6	26.6
		MCDB	28.7	28.4	29.9	30.9	31.8	31.8	31.6	31.4	31.1	30.8	30.0	29.3
(30) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	5%	WB	25.9	25.6	26.2	26.7	27.2	27.0	26.6	26.6	26.5	26.5	26.4	26.2
		MCDB	28.3	28.2	29.4	30.4	31.4	31.5	31.1	31.1	30.8	30.4	29.7	28.9
	10%	WB	25.6	25.3	25.9	26.5	27.0	26.7	26.3	26.2	26.2	26.2	26.1	26.0
		MCDB	28.0	27.9	29.0	30.1	31.1	30.8	30.6	30.6	30.2	29.9	29.3	28.6
(35) Mean Daily Temperature Range	5% DB	MDBR	3.0	3.3	4.5	5.4	5.9	5.8	5.7	5.8	5.7	5.3	4.9	3.5
		MCDBR	3.7	4.1	5.4	6.1	6.7	6.6	6.3	6.4	6.4	6.4	5.9	4.6
		MCWBR	1.5	1.6	2.1	2.4	2.4	2.2	2.1	2.1	2.2	2.5	2.3	2.0
	5% WB	MCDBR	3.4	3.6	4.7	5.6	6.1	6.0	6.0	6.1	6.0	5.7	5.2	4.2
		MCWBR	1.6	1.6	2.0	2.4	2.6	2.2	2.2	2.3	2.5	2.5	2.3	1.9
(40) Clear-Sky Solar Irradiance	taub		0.461	0.449	0.442	0.419	0.425	0.449	0.447	0.483	0.494	0.502	0.433	0.471
	taud		2.362	2.388	2.414	2.480	2.473	2.417	2.416	2.288	2.248	2.227	2.442	2.338
	Ebn at Noon		866	883	886	888	862	829	835	822	828	826	886	850
	Edh at Noon		127	126	123	113	110	114	116	135	143	146	117	129
(44) All-Sky Solar Radiation	RadAvg		4.73	5.62	6.07	6.21	5.61	4.96	5.00	5.17	5.05	4.83	4.70	4.36
	RadStd		0.46	0.51	0.49	0.29	0.27	0.28	0.42	0.33	0.31	0.39	0.33	0.49

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page