

MIA PADANG, Indonesia

WMO: 961630

Lat: 0.7936S

Lon: 100.2892E

Elev: 10

StdP: 14.69

Time Zone: 7.00 (E07)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 11	(b) 71.1	(c) 72.1	(d) 67.2	(e) 99.9	(f) 76.8	(g) 68.6	(h) 105.0	(i) 76.5	(j) 18.4	(k) 83.1	(l) 14.3	(m) 83.7	(n) 0.5	(o) 0	(p) 0.287

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 5	(b) 12.3	(c) 90.0	(d) 79.0	(e) 89.5	(f) 79.0	(g) 88.9	(h) 78.8	(i) 81.6	(j) 87.4	(k) 80.9	(l) 86.9	(m) 80.4	(n) 86.5	(o) 7.7	(p) 270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
80.0	155.5	85.4	79.2	151.5	84.8	78.7	148.8	84.4	45.3	87.6	44.6	87.2	44.0	86.7	87.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 14.0	(b) 11.6	(c) 9.8	(e) 67.6	(f) 92.7	(g) 2.2	(h) 2.4	(i) 66.0	(j) 94.5	(k) 64.7	(l) 95.9	(m) 63.5	(n) 97.3	(o) 61.9	(p) 99.0		
			DB	WB	65.8	83.2	1.8	1.5	64.5	84.3	63.4	85.2	62.4	86.0	61.0	87.1

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	80.7	80.6	81.0	81.2	81.5	81.8	81.1	80.2	80.2	80.0	80.1	80.1	80.4		
	DBStd	1.51	1.54	1.45	1.47	1.34	1.31	1.35	1.29	1.32	1.45	1.42	1.40	1.41		
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0		
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDD50	11194	949	867	966	945	985	932	935	935	901	935	903	941		
	CDD65	5719	484	447	501	495	520	482	470	470	451	470	453	476		
	CDH74	54825	4639	4489	5050	5042	5481	4842	4456	4400	4056	4182	3871	4317		
(13)	CDH80	18336	1563	1633	1762	1763	1997	1764	1562	1447	1207	1225	1083	1330		
(14)	Wind	WSAvg	2.5	2.4	2.5	2.6	2.4	2.4	2.4	2.8	2.7	2.5	2.5	2.5		
(15) Precipitation	PrecAvg	167.9	13.0	11.8	13.9	13.7	10.4	12.8	11.6	12.1	14.7	15.7	20.0	18.1		
	PrecMax	205.2	29.4	19.7	29.9	19.9	21.5	26.0	19.5	31.1	26.4	37.9	32.8	27.3		
	PrecMin	70.7	4.1	1.9	3.1	5.4	0.6	2.8	5.0	1.1	0.7	0.2	5.1	7.4		
	PrecStd	28.2	5.2	4.4	6.9	4.2	5.4	5.1	4.4	6.6	5.7	7.8	7.4	5.4		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	90.7	90.8	90.5	90.5	90.8	90.2	89.3	89.4	89.1	89.5	89.1	89.2		
		MCWB	77.4	76.9	78.7	80.2	80.2	79.1	78.4	78.4	78.4	78.6	79.1	78.8		
	2%	DB	88.9	89.2	89.1	89.3	89.7	89.1	88.4	88.2	87.9	88.1	87.8	88.0		
		MCWB	78.2	78.3	79.0	79.7	79.6	78.7	78.2	78.1	78.2	78.2	78.7	78.5		
	5%	DB	87.8	88.3	88.2	88.4	88.8	88.3	87.6	87.3	86.9	87.1	86.7	87.1		
		MCWB	78.0	78.4	78.9	79.5	79.3	78.5	78.0	77.9	78.1	78.1	78.4	78.2		
	10%	DB	86.8	87.4	87.3	87.5	87.9	87.5	86.8	86.3	85.8	86.0	85.5	86.1		
		MCWB	78.0	78.3	78.8	79.2	79.1	78.3	77.7	77.7	77.9	78.1	78.1	78.0		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	80.8	81.7	81.9	82.7	82.3	81.4	80.7	80.6	80.4	80.9	80.9	80.7		
		MCDB	86.8	87.4	87.1	87.5	88.5	87.7	86.9	86.9	86.0	86.0	86.4	86.3		
	2%	WB	80.0	80.6	80.7	81.4	81.1	80.5	79.6	79.6	79.5	79.8	79.9	79.8		
		MCDB	86.1	86.7	86.8	87.1	87.4	86.7	86.2	86.0	85.4	85.4	85.6	85.7		
	5%	WB	79.2	79.8	79.9	80.6	80.5	79.8	78.9	78.9	78.9	79.1	79.1	79.1		
		MCDB	85.6	86.2	86.2	86.6	86.7	86.2	85.8	85.4	85.0	85.0	84.9	85.2		
	10%	WB	78.6	79.1	79.2	79.8	79.9	79.1	78.3	78.3	78.3	78.5	78.4	78.6		
		MCDB	85.1	85.6	85.6	85.8	86.0	85.7	85.1	84.6	84.2	84.3	84.0	84.6		
(35) Mean Daily Temperature Range	5% DB	MDBR	12.4	13.0	12.4	12.1	12.3	13.0	13.3	12.5	11.6	11.1	10.9	11.6		
		MCDBR	14.1	14.4	13.8	13.5	13.8	14.3	14.6	14.0	13.2	13.3	12.7	13.1		
		MCWBR	6.3	6.8	6.3	6.2	6.2	6.4	6.8	6.3	6.0	5.8	5.6	5.8		
	5% WB	MCDBR	12.6	12.9	12.4	12.4	12.2	12.9	13.6	12.6	12.1	11.8	11.5	11.9		
		MCWBR	6.2	6.6	6.2	6.2	6.0	6.3	6.8	6.1	5.9	5.6	5.5	5.7		
(40) Clear-Sky Solar Irradiance	taub		0.448	0.517	0.495	0.446	0.443	0.451	0.446	0.501	0.553	0.581	0.469	0.424		
	taud		2.364	2.148	2.228	2.380	2.397	2.376	2.388	2.211	2.051	1.955	2.310	2.444		
	Ebn at Noon		281	263	266	273	266	260	263	255	248	243	273	286		
	Edh at Noon		41	51	47	39	37	37	37	46	56	62	43	37		
(44) All-Sky Solar Radiation	RadAvg		1516	1577	1625	1615	1613	1562	1529	1519	1488	1476	1483	1468		
	RadStd		74	78	98	50	74	56	73	81	126	179	65	76		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page