

MIA PADANG, Indonesia

WMO: 961630

Lat: 0.7936S

Lon: 100.2892E

Elev: 3

StdP: 101.29

Time Zone: 7.00 (E07)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 11	(b) 21.7	(c) 22.3	(d) 19.5	(e) 14.3	(f) 24.9	(g) 20.3	(h) 15.0	(i) 24.7	(j) 8.2	(k) 28.4	(l) 6.4	(m) 28.7	(n) 0.2	(o) 0	(p) 0.287

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 5	(b) 6.8	(c) 32.2	(d) 26.1	(e) 31.9	(f) 26.1	(g) 31.6	(h) 26.0	(i) 27.6	(j) 30.8	(k) 27.2	(l) 30.5	(m) 26.9	(n) 30.3	(o) 3.4	(p) 270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) 26.6	(b) 22.2	(c) 29.7	(d) 26.2	(e) 21.6	(f) 29.3	(g) 25.9	(h) 21.3	(i) 29.1	(j) 87.5	(k) 30.9	(l) 85.9	(m) 30.7	(n) 84.5	(o) 30.4	(p) 31.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 6.3	(b) 5.2	(c) 4.4	(e) 19.8	(f) 33.7	(g) 1.2	(h) 1.4	(i) 18.9	(j) 34.7	(k) 18.2	(l) 35.5	(m) 17.5	(n) 36.3	(o) 16.6	(p) 37.2		
			DB	WB	DB	WB	DB	WB	DB	WB	DB	WB	DB	WB		
			18.8	28.4	1.0	0.8	18.0	29.0	17.4	29.5	16.9	30.0	16.1	30.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	27.0	27.0	27.2	27.3	27.5	27.6	27.3	26.8	26.8	26.7	26.7	26.7	26.9
	DBStd	0.84	0.86	0.81	0.81	0.74	0.73	0.75	0.71	0.73	0.81	0.79	0.78	0.79
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	6219	527	482	537	525	547	518	519	519	501	519	502	523
	CDD18.3	3177	269	248	278	275	289	268	261	261	251	261	252	264
	CDH23.3	30458	2577	2494	2806	2801	3045	2690	2476	2444	2253	2323	2151	2398
	CDH26.7	10187	868	907	979	979	1109	980	868	804	671	681	602	739
Wind	WSAvg	1.1	1.1	1.1	1.2	1.1	1.1	1.1	1.1	1.3	1.2	1.1	1.1	1.1
Precipitation	PrecAvg	4264	330	299	354	349	264	326	294	307	373	399	509	460
	PrecMax	5212	747	501	760	506	546	660	496	789	671	962	832	693
	PrecMin	1797	103	48	79	138	15	70	127	28	17	4	129	189
	PrecStd	717	132	111	176	106	137	130	111	167	144	198	189	136
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.6	32.6	32.5	32.5	32.7	32.3	31.8	31.9	31.7	31.9	31.7	31.8
		MCWB	25.2	25.0	25.9	26.8	26.8	26.2	25.8	25.8	25.8	25.9	26.2	26.0
	2%	DB	31.6	31.8	31.7	31.8	32.1	31.7	31.3	31.2	31.0	31.2	31.0	31.1
		MCWB	25.7	25.7	26.1	26.5	26.5	25.9	25.6	25.6	25.7	25.7	25.9	25.8
	5%	DB	31.0	31.3	31.2	31.4	31.6	31.3	30.9	30.7	30.5	30.6	30.4	30.6
		MCWB	25.6	25.8	26.1	26.4	26.3	25.8	25.5	25.5	25.6	25.6	25.8	25.7
	10%	DB	30.5	30.8	30.7	30.9	31.0	30.8	30.4	30.2	29.9	30.0	29.7	30.1
		MCWB	25.5	25.7	26.0	26.2	26.2	25.7	25.4	25.4	25.5	25.6	25.6	25.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.1	27.6	27.7	28.1	28.0	27.4	27.1	27.0	26.9	27.1	27.2	27.1
		MCDB	30.4	30.8	30.6	30.8	31.4	30.9	30.5	30.5	30.0	30.0	30.2	30.2
	2%	WB	26.7	27.0	27.1	27.5	27.3	26.9	26.5	26.4	26.4	26.6	26.6	26.6
		MCDB	30.1	30.4	30.4	30.6	30.8	30.4	30.1	30.0	29.7	29.6	29.8	29.8
	5%	WB	26.2	26.6	26.6	27.0	27.0	26.5	26.1	26.1	26.1	26.2	26.2	26.2
		MCDB	29.8	30.1	30.1	30.3	30.4	30.1	29.9	29.6	29.4	29.4	29.4	29.5
	10%	WB	25.9	26.2	26.2	26.6	26.6	26.1	25.7	25.7	25.7	25.8	25.8	25.9
		MCDB	29.5	29.8	29.8	29.9	30.0	29.8	29.5	29.2	29.0	29.1	28.9	29.2
Mean Daily Temperature Range	5% DB	MDBR	6.9	7.2	6.9	6.7	6.8	7.2	7.4	7.0	6.4	6.2	6.0	6.4
		MCDBR	7.8	8.0	7.7	7.5	7.7	8.0	8.1	7.8	7.3	7.4	7.0	7.3
		MCWBR	3.5	3.8	3.5	3.4	3.4	3.6	3.8	3.5	3.3	3.2	3.1	3.2
	5% WB	MCDBR	7.0	7.2	6.9	6.9	6.8	7.2	7.5	7.0	6.7	6.5	6.4	6.6
		MCWBR	3.5	3.7	3.4	3.5	3.3	3.5	3.8	3.4	3.3	3.1	3.1	3.2
Clear-Sky Solar Irradiance	taub	0.448	0.517	0.495	0.446	0.443	0.451	0.446	0.501	0.553	0.581	0.469	0.424	
	taud	2.364	2.148	2.228	2.380	2.397	2.376	2.388	2.211	2.051	1.955	2.310	2.444	
	Ebn at Noon	885	828	840	861	840	819	830	803	781	766	860	903	
	Edh at Noon	129	162	148	124	117	117	117	145	175	194	135	118	
All-Sky Solar Radiation	RadAvg	4.78	4.97	5.12	5.09	5.08	4.92	4.82	4.79	4.69	4.65	4.67	4.63	
	RadStd	0.23	0.25	0.31	0.16	0.23	0.17	0.23	0.26	0.40	0.56	0.20	0.24	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page