

RENGAT JAPURA, Indonesia

WMO: 961710

Lat: 0.3494S

Lon: 102.3339E

Elev: 46

StdP: 100.77

Time Zone: 7.00 (E07)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 21.8	(c) 22.3	(d) 20.4	(e) 15.2	(f) 27.3	(g) 21.1	(h) 15.8	(i) 26.5	(j) 5.3	(k) 28.3	(l) 4.6	(m) 28.5	(n) 0.2	(o) N/A	(p) 0.279

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	8.0	33.7	26.0	33.2	25.9	32.8	25.9	27.4	31.3	27.1	31.1	26.8	30.8	1.4	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.4	22.0	29.6	26.1	21.6	29.4	25.7	21.1	29.1	87.3	31.6	86.0	31.3	84.7	31.0	30.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4.7	4.1	3.5	20.3	34.9	1.5	0.5	19.2	35.3	18.3	35.5	17.5	35.8	16.4	36.1
			19.3	28.4	1.9	0.7	17.9	28.9	16.8	29.3	15.8	29.7	14.4	30.2
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	27.5	26.9	27.2	27.6	27.8	28.1	27.9	27.5	27.5	27.5	27.5	27.4	27.1	(6)
	DBStd	1.03	1.07	0.98	0.98	0.95	1.03	1.02	1.00	0.98	0.99	0.91	0.88	0.95	(7)
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
	CDD10.0	6382	523	481	545	535	560	536	542	543	524	542	522	530	(10)
	CDD18.3	3341	264	248	287	285	302	286	283	284	274	284	272	272	(11)
	CDH23.3	31459	2271	2274	2718	2761	3107	2911	2737	2736	2540	2578	2432	2393	(12)
(13) Wind	CDH26.7	11583	707	763	1011	1048	1228	1159	1058	1054	979	963	856	756	(13)
	WSAvg	0.6	0.7	0.7	0.6	0.5	0.6	0.6	0.7	0.8	0.7	0.5	0.6	0.6	(14)
	PrecAvg	2230	196	196	201	240	182	119	115	122	175	193	264	216	(15)
	PrecMax	3299	499	390	460	526	514	285	291	250	550	402	715	412	(16)
	PrecMin	1201	39	25	10	45	33	4	8	18	10	10	69	54	(17)
	PrecStd	555	113	92	117	99	95	68	72	57	131	96	126	95	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	33.0	33.0	33.7	34.0	34.2	34.2	33.7	33.6	33.8	33.7	33.4	32.9	(19)
		MCWB	25.8	25.8	26.0	26.6	26.8	26.0	25.6	25.2	24.9	25.5	25.7	25.9	(20)
	2%	DB	32.0	32.1	32.9	33.1	33.4	33.2	32.9	32.9	32.9	32.9	32.5	32.0	(21)
		MCWB	25.7	25.7	26.1	26.5	26.7	26.1	25.5	25.2	25.3	25.7	25.9	25.9	(22)
	5%	DB	31.1	31.4	32.1	32.3	32.7	32.6	32.2	32.2	32.2	32.1	31.7	31.2	(23)
		MCWB	25.5	25.6	26.0	26.4	26.6	26.1	25.6	25.3	25.4	25.8	25.9	25.8	(24)
	10%	DB	30.2	30.7	31.3	31.5	31.9	31.8	31.4	31.4	31.4	31.2	30.9	30.3	(25)
		MCWB	25.4	25.5	25.9	26.4	26.5	26.1	25.6	25.4	25.4	25.8	25.8	25.7	(26)
	0.4%	WB	26.7	27.1	27.5	27.7	28.0	27.6	27.0	27.0	26.9	27.0	27.1	26.9	(27)
		MCDB	30.5	30.8	31.5	31.6	32.0	31.2	30.7	30.7	30.7	30.9	30.9	30.8	(28)
(29) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	26.3	26.6	26.8	27.2	27.5	27.1	26.5	26.4	26.5	26.6	26.6	26.5	(29)
		MCDB	30.1	30.3	30.9	31.2	31.5	31.0	30.5	30.4	30.5	30.6	30.5	30.3	(30)
	5%	WB	26.0	26.2	26.5	26.9	27.1	26.7	26.2	26.1	26.1	26.2	26.3	26.2	(31)
		MCDB	29.8	29.9	30.5	30.9	31.2	30.7	30.3	30.2	30.3	30.3	30.2	29.9	(32)
	10%	WB	25.7	25.8	26.2	26.6	26.7	26.4	25.9	25.7	25.8	26.0	26.0	25.9	(33)
		MCDB	29.1	29.4	30.2	30.4	30.6	30.4	30.0	29.8	29.9	30.2	29.9	29.4	(34)
	5% DB	MDBR	7.0	7.4	8.0	8.0	8.0	8.2	8.2	8.2	8.2	8.1	7.7	7.0	(35)
		MCDBR	8.3	8.4	9.0	9.1	9.0	9.2	9.3	9.3	9.4	9.1	8.8	8.2	(36)
		MCWBR	3.0	3.0	3.3	3.5	3.4	3.2	3.2	3.1	3.2	3.2	3.1	3.1	(37)
		MCWBR	7.5	7.6	8.1	8.3	8.2	8.4	8.3	8.3	8.5	8.3	7.9	7.3	(38)
(43) Clear-Sky Solar Irradiance	taub		0.479	0.575	0.537	0.466	0.463	0.478	0.486	0.563	0.625	0.640	0.482	0.448	(40)
		taud	2.228	1.934	2.056	2.274	2.286	2.233	2.209	1.974	1.816	1.768	2.225	2.341	(41)
	Ebn at Noon		856	780	806	844	823	796	796	754	727	721	847	879	(42)
		Edh at Noon	147	200	176	138	131	136	141	183	221	233	147	130	(43)
(44) All-Sky Solar Radiation	RadAvg		4.27	4.52	4.79	4.84	4.73	4.64	4.55	4.63	4.52	4.53	4.56	4.28	(44)
	RadStd		0.31	0.22	0.31	0.15	0.15	0.21	0.23	0.25	0.39	0.51	0.18	0.32	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	+0.32	+0.34	N/A	+0.32	N/A	N/A	N/A	N/A	N/A	N/A
Regional (1 neighbor)	+0.32	+0.34	N/A	+0.32	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page