

SINGKEP DABO, Indonesia

WMO: 961790

Lat: 0.4789S

Lon: 104.5778E

Elev: 102

StdP: 14.64

Time Zone: 7.00 (E07)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	73.3	74.1	70.3	111.8	79.7	71.2	115.4	79.3	16.5	83.9	15.0	84.1	2.4	270	0.336

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	9.6	90.9	80.7	90.0	80.5	89.6	80.3	82.7	88.7	82.0	88.2	81.5	87.7	8.4	20

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
80.9	161.3	87.1	80.2	157.1	86.4	79.7	154.6	85.8	46.6	89.1	45.9	88.6	45.3	88.0	92.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.1	13.9	12.1	69.8	92.5	3.8	1.3	67.0	93.5	64.8	94.2	62.6	95.0	59.9	96.0		
(5)			69.0	85.3	3.9	2.5	66.1	87.1	63.8	88.5	61.6	89.9	58.8	91.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	81.9	81.7	82.0	82.4	82.0	82.4	82.3	82.0	82.4	82.2	81.7	81.1	80.9		
	DBStd	2.04	1.81	1.84	2.02	1.76	1.89	2.07	2.26	2.22	2.11	2.05	1.69	1.99		
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0		
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDD50	11653	982	897	1004	961	1005	969	993	1004	965	982	933	958		
	CDD65	6178	517	477	539	511	540	519	528	539	515	517	483	493		
	CDH74	63594	5143	4786	5605	5222	5833	5628	5660	5869	5473	5224	4556	4595		
	CDH80	20169	1518	1471	1838	1642	1984	1928	1869	1958	1824	1648	1282	1207		
(14) Wind	WSAvg	4.2	6.6	7.6	5.0	2.8	3.0	3.5	4.1	4.8	4.2	2.9	2.5	3.7		
(15) Precipitation	PrecAvg	97.3	7.2	4.4	7.6	9.0	10.1	8.2	7.8	8.1	7.2	7.8	9.6	10.1		
	PrecMax	153.4	25.6	17.1	18.2	15.1	20.9	16.2	15.4	19.9	16.0	18.4	19.8	20.9		
	PrecMin	38.2	0.5	0.9	2.4	3.1	4.3	2.0	0.7	0.9	0.0	0.4	3.2	2.3		
	PrecStd	23.0	5.9	3.3	4.0	2.9	3.9	4.1	3.7	4.6	4.2	4.4	3.9	4.3		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	90.3	90.8	91.8	91.1	91.7	91.1	90.1	90.0	90.3	90.8	90.7	89.9		
		MCWB	79.6	79.7	80.6	81.2	81.8	81.3	80.9	80.2	80.0	80.7	80.1	79.5		
	2%	DB	89.1	89.5	90.2	89.9	90.3	89.8	89.2	89.3	89.4	89.6	89.1	88.6		
		MCWB	79.3	79.7	79.9	80.8	81.5	81.2	80.4	80.0	79.8	80.4	80.0	79.3		
	5%	DB	88.0	88.5	89.1	88.8	89.0	88.9	88.3	88.5	88.5	88.6	87.7	87.3		
		MCWB	79.1	79.2	79.6	80.5	81.1	80.9	80.1	79.7	79.6	80.0	79.6	79.1		
	10%	DB	86.8	87.3	87.9	87.4	87.8	87.8	87.3	87.6	87.5	87.2	86.3	86.0		
		MCWB	78.7	78.6	79.3	80.1	80.6	80.5	79.8	79.4	79.3	79.5	79.2	78.8		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	81.7	81.9	82.7	83.1	83.5	83.2	82.5	82.5	82.2	82.4	82.3	81.5		
		MCDB	88.1	88.3	89.4	88.9	89.3	89.0	88.5	88.3	88.4	89.1	87.9	86.7		
	2%	WB	80.6	80.6	81.0	81.8	82.4	82.2	81.6	81.3	81.0	81.3	80.9	80.5		
		MCDB	87.1	87.9	88.1	87.8	88.9	88.3	87.6	87.7	87.7	88.0	87.0	86.2		
	5%	WB	79.8	79.8	80.3	81.0	81.6	81.5	80.8	80.4	80.1	80.4	80.1	79.8		
		MCDB	86.0	86.7	87.1	86.9	87.7	87.4	86.9	87.0	86.8	87.1	85.9	85.2		
	10%	WB	79.1	79.0	79.6	80.3	80.9	80.8	80.1	79.7	79.5	79.7	79.5	79.2		
		MCDB	84.9	85.7	86.1	85.9	86.6	86.5	85.8	85.8	85.9	85.8	84.8	84.3		
(35) Mean Daily Temperature Range	5% DB	MDBR	10.4	11.0	11.2	10.9	10.5	10.1	9.6	9.6	10.3	10.6	10.6	10.0		
		MCDBR	12.0	12.2	12.5	12.7	12.2	11.6	10.6	10.5	11.4	12.4	12.8	11.9		
	5% WB	MCWBR	4.8	4.9	5.0	5.5	5.7	5.6	4.8	4.6	4.9	5.3	5.5	4.8		
		MCWBR	11.2	11.8	11.6	11.6	11.5	11.1	10.6	10.3	10.9	11.6	11.8	11.1		
(40) Clear-Sky Solar Irradiance	taub	taub	0.463	0.482	0.471	0.437	0.439	0.449	0.452	0.497	0.558	0.573	0.462	0.451		
		taud	2.347	2.270	2.315	2.408	2.421	2.402	2.386	2.231	2.041	1.989	2.322	2.388		
	Ebn at Noon	Ebn at Noon	276	272	273	276	268	261	262	256	246	245	274	278		
		Edh at Noon	42	45	43	38	36	36	37	45	56	59	42	39		
(44) All-Sky Solar Radiation	RadAvg	RadAvg	1455	1664	1630	1544	1438	1397	1425	1499	1487	1360	1290	1247		
	RadStd	RadStd	121	134	134	89	62	113	121	133	100	75	65	93		

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page