

SINGKEP DABO, Indonesia

WMO: 961790

Lat: 0.4789S

Lon: 104.5778E

Elev: 31

StdP: 100.95

Time Zone: 7.00 (E07)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	22.9	23.4	21.3	16.0	26.5	21.8	16.5	26.3	7.4	28.8	6.7	28.9	1.1	270	0.336

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.3	32.7	27.1	32.2	26.9	32.0	26.8	28.2	31.5	27.8	31.2	27.5	31.0	3.8	20

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
27.2	23.0	30.6	26.8	22.4	30.2	26.5	22.1	29.9	90.6	31.7	89.0	31.4	87.5	31.1	33.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.2	6.2	5.4	DB	21.0	33.6	2.1	0.7	19.5	34.1	18.2	34.6	17.0	35.0	15.5	35.5 (4)	
(5)			WB	20.5	29.6	2.2	1.4	19.0	30.6	17.7	31.4	16.5	32.2	14.9	33.2 (5)	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	27.7	27.6	27.8	28.0	27.8	28.0	27.9	27.8	28.0	27.9	27.6	27.3	27.2	(6)
(7)		DBStd	1.13	1.01	1.02	1.12	0.98	1.05	1.15	1.26	1.23	1.17	1.14	0.94	1.11	(7)
(8)		HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
(10)		CDD10.0	6474	546	498	558	534	558	538	552	558	536	546	518	532	(10)
(11)		CDD18.3	3432	287	265	299	284	300	288	293	299	286	287	268	274	(11)
(12)		CDH23.3	35330	2857	2659	3114	2901	3241	3127	3144	3261	3041	2902	2531	2553	(12)
(13)		CDH26.7	11205	843	817	1021	912	1102	1071	1038	1088	1013	916	712	671	(13)
(14)	Wind	WSAvg	1.9	2.9	3.4	2.3	1.3	1.6	1.8	2.2	1.9	1.3	1.1	1.7	(14)	
(15)	Precipitation	PrecAvg	2471	184	112	194	228	257	208	199	205	183	199	245	256	(15)
(16)		PrecMax	3896	650	435	462	383	531	412	392	506	406	467	504	531	(16)
(17)		PrecMin	970	13	23	61	80	108	52	17	22	0	10	81	59	(17)
(18)		PrecStd	584	149	85	102	73	100	103	95	117	107	113	98	110	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.4	32.6	33.2	32.9	33.2	32.9	32.3	32.2	32.4	32.7	32.6	32.2	(19)
(20)			MCWB	26.4	26.5	27.0	27.3	27.7	27.4	27.2	26.8	26.7	27.1	26.7	26.4	(20)
(21)		2%	DB	31.7	31.9	32.3	32.2	32.4	32.1	31.8	31.8	31.9	32.0	31.7	31.4	(21)
(22)			MCWB	26.3	26.5	26.6	27.1	27.5	27.3	26.9	26.6	26.6	26.9	26.7	26.3	(22)
(23)		5%	DB	31.1	31.4	31.7	31.6	31.7	31.6	31.3	31.4	31.4	31.4	31.0	30.7	(23)
(24)			MCWB	26.1	26.2	26.5	27.0	27.3	27.2	26.7	26.5	26.5	26.7	26.5	26.2	(24)
(25)		10%	DB	30.4	30.7	31.0	30.8	31.0	31.0	30.7	30.9	30.8	30.7	30.1	30.0	(25)
(26)			MCWB	25.9	25.9	26.3	26.7	27.0	27.0	26.5	26.3	26.3	26.4	26.2	26.0	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.6	27.7	28.2	28.4	28.6	28.4	28.1	28.1	27.9	28.0	28.0	27.5	(27)
(28)			MADB	31.1	31.3	31.9	31.6	31.8	31.7	31.4	31.3	31.3	31.7	31.1	30.4	(28)
(29)		2%	WB	27.0	27.0	27.2	27.7	28.0	27.9	27.5	27.4	27.2	27.4	27.2	27.0	(29)
(30)			MADB	30.6	31.1	31.1	31.0	31.6	31.3	30.9	31.0	30.9	31.1	30.5	30.1	(30)
(31)		5%	WB	26.6	26.5	26.8	27.2	27.6	27.5	27.1	26.9	26.7	26.9	26.7	26.6	(31)
(32)			MADB	30.0	30.4	30.6	30.5	30.9	30.8	30.5	30.6	30.4	30.6	29.9	29.6	(32)
(33)		10%	WB	26.2	26.1	26.5	26.8	27.1	27.1	26.7	26.5	26.4	26.5	26.4	26.2	(33)
(34)			MADB	29.4	29.8	30.0	29.9	30.3	30.3	29.9	29.9	29.9	29.9	29.4	29.0	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	5.8	6.1	6.2	6.1	5.8	5.6	5.3	5.3	5.7	5.9	5.9	5.6	(35)
(36)			MCDBR	6.7	6.8	7.0	7.1	6.8	6.4	5.9	5.8	6.3	6.9	7.1	6.6	(36)
(37)			MCWBR	2.7	2.7	2.8	3.0	3.1	3.1	2.7	2.6	2.7	3.0	3.1	2.7	(37)
(38)		5% WB	MCDBR	6.2	6.5	6.5	6.5	6.4	6.2	5.9	5.7	6.1	6.4	6.6	6.2	(38)
(39)			MCWBR	2.8	3.0	2.9	3.2	3.3	3.3	2.9	2.8	2.9	3.0	3.2	2.8	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.463	0.482	0.471	0.437	0.439	0.449	0.452	0.497	0.558	0.573	0.462	0.451	(40)	
(41)		taud	2.347	2.270	2.315	2.408	2.421	2.402	2.386	2.231	2.041	1.989	2.322	2.388	(41)	
(42)		Ebn at Noon	871	858	860	870	844	822	825	806	777	772	865	877	(42)	
(43)		Edh at Noon	131	143	136	121	115	115	118	142	176	187	133	124	(43)	
(44)	All-Sky Solar Radiation	RadAvg	4.59	5.25	5.14	4.87	4.53	4.41	4.49	4.72	4.69	4.29	4.07	3.93	(44)	
(45)		RadStd	0.38	0.42	0.42	0.28	0.20	0.35	0.38	0.42	0.32	0.23	0.20	0.29	(45)	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page