

JAMBI SULTAN TAHA, Indonesia

WMO: 961950

Lat: 1.638S

Lon: 103.644E

Elev: 82

StdP: 14.65

Time Zone: 7.00 (E07)

Period: 04-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	72.2	73.0	68.6	105.4	85.6	69.7	109.5	83.8	16.5	82.6	13.0	81.7	2.6	160	0.308

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	13.1	92.0	77.8	91.3	78.0	90.5	78.0	80.9	87.5	80.2	86.9	79.9	86.5	6.3	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
79.2	151.8	84.2	78.5	148.5	83.5	78.1	146.3	83.1	44.7	87.8	44.0	87.3	43.5	86.9	87.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 13.0	11.4	9.9	68.3	93.7	4.7	0.9	65.0	94.3	62.3	94.9	59.7	95.4	56.3	96.1		
(5)			66.9	83.9	4.6	1.7	63.6	85.1	60.9	86.1	58.4	87.1	55.0	88.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	81.6	81.0	81.0	81.5	82.1	82.5	82.1	81.5	81.7	81.8	81.5	80.9	(6)	
(7)		DBStd	1.77	1.71	1.77	1.81	1.64	1.63	1.65	1.71	1.60	1.78	1.80	1.54	1.85	(7)
(8)		HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
(10)		CDD50	11543	960	868	977	963	1007	963	977	983	955	985	946	959	(10)
(11)		CDD65	6068	495	448	512	513	542	513	512	518	505	520	496	494	(11)
(12)		CDH74	59157	4661	4173	4864	4996	5546	5264	5136	5238	5095	4998	4560	4626	(12)
(13)		CDH80	20409	1338	1227	1627	1742	2045	1954	1881	2026	1986	1755	1462	1366	(13)
(14)	Wind	WSAvg	3.4	4.1	3.4	3.1	2.7	3.1	3.4	3.8	4.2	3.9	3.1	2.9	3.6	(14)
(15)	Precipitation	PrecAvg	80.8	7.6	6.8	9.2	10.0	6.6	4.7	3.8	4.2	5.2	6.4	9.6	9.3	(15)
(16)		PrecMax	102.8	14.9	14.1	16.0	21.3	11.5	9.1	8.4	8.9	12.9	14.6	19.5	15.1	(16)
(17)		PrecMin	58.9	1.1	1.5	3.9	3.5	1.1	0.6	0.2	0.1	0.0	0.7	3.7	3.6	(17)
(18)		PrecStd	13.1	3.5	2.9	3.2	4.2	2.5	2.6	2.4	2.5	2.7	3.4	3.8	3.1	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	90.6	90.7	91.8	92.3	92.3	91.8	91.7	92.3	93.2	92.5	91.5	90.9	(19)
(20)			MCWB	77.0	77.9	78.0	79.5	79.4	78.3	77.4	76.7	76.1	77.2	78.2	77.4	(20)
(21)		2%	DB	89.0	89.3	90.4	90.8	90.9	90.6	90.5	90.9	91.2	91.1	90.0	89.2	(21)
(22)			MCWB	77.4	77.5	78.1	79.4	79.3	78.5	77.4	77.2	77.0	77.5	78.3	77.8	(22)
(23)		5%	DB	87.6	87.9	89.0	89.6	89.9	89.6	89.4	89.8	90.2	89.7	88.7	87.8	(23)
(24)			MCWB	77.4	77.3	78.1	79.1	79.2	78.4	77.4	77.1	77.1	77.7	78.3	77.8	(24)
(25)		10%	DB	86.1	86.3	87.6	88.1	88.6	88.4	88.2	88.6	89.0	88.0	87.1	86.3	(25)
(26)			MCWB	77.2	77.2	78.1	79.1	79.1	78.4	77.5	77.0	77.2	77.8	78.2	77.7	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	79.8	80.0	80.5	82.3	81.8	80.9	80.1	80.7	80.3	80.3	80.1	80.1	(27)
(28)			MCD B	84.7	86.5	87.1	88.6	88.6	87.3	86.4	88.0	86.8	87.1	86.8	85.2	(28)
(29)		2%	WB	79.0	79.1	79.7	80.8	80.8	80.1	79.2	79.4	79.2	79.5	79.5	79.2	(29)
(30)			MCD B	84.4	85.2	86.2	87.5	87.7	86.8	86.2	86.5	86.6	86.5	86.3	84.9	(30)
(31)		5%	WB	78.3	78.5	79.1	80.0	80.1	79.6	78.7	78.6	78.7	78.9	79.0	78.7	(31)
(32)			MCD B	83.8	84.4	85.6	86.5	86.8	86.3	85.9	85.7	86.4	86.1	85.9	84.6	(32)
(33)		10%	WB	77.9	78.0	78.6	79.3	79.6	79.0	78.2	78.0	78.1	78.3	78.5	78.2	(33)
(34)			MCD B	83.3	83.7	85.0	85.7	86.2	85.8	85.1	85.1	85.6	85.1	85.0	83.8	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	10.8	11.4	12.8	13.1	13.1	13.2	13.6	14.3	14.1	13.2	12.6	11.2	(35)
(36)			MCDBR	12.9	13.5	14.8	15.1	14.4	14.5	15.3	16.0	16.1	15.3	14.2	13.3	(36)
(37)			MCWBR	3.8	3.9	4.8	5.3	4.8	4.5	4.6	4.6	4.8	4.5	4.7	4.4	(37)
(38)		5% WB	MCDBR	11.4	12.0	13.4	13.8	13.3	13.5	13.6	13.8	14.3	13.6	12.7	12.0	(38)
(39)			MCWBR	4.0	4.4	5.1	5.4	5.1	5.0	4.8	5.0	5.2	5.0	4.9	4.6	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.481	0.525	0.496	0.451	0.460	0.464	0.478	0.546	0.658	0.668	0.506	0.451	(40)	
(41)		taud	2.228	2.090	2.185	2.320	2.293	2.281	2.236	2.023	1.730	1.702	2.149	2.329	(41)	
(42)		Ebn at Noon	272	261	266	272	261	256	254	243	223	223	263	279	(42)	
(43)		Edh at Noon	47	55	49	42	41	41	43	55	76	79	50	42	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1339	1413	1483	1508	1489	1466	1459	1521	1497	1428	1414	1331	(44)	
(45)		RadStd	92	72	74	54	40	65	73	67	101	135	63	79	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page