

KERINCI DEPATI PARBO, Indonesia

WMO: 962070

Lat: 2.0911S

Lon: 101.4620E

Elev: 2566

StdP: 13.38

Time Zone: 7.00 (E07)

Period: 07-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	62.0	63.5	58.2	79.6	68.9	59.8	84.4	68.9	21.0	74.6	17.8	75.8	0.3	N/A	0.199

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	15.3	85.3	72.5	84.4	72.3	83.6	72.1	75.0	82.2	74.3	81.5	73.7	80.9	6.6	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
72.8	133.7	78.8	72.0	130.2	78.0	71.5	128.0	77.5	40.3	82.4	39.6	81.7	39.0	81.1	85.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
(4) 16.5	13.5	11.5	DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(5)			WB	54.7	79.6	3.0	3.2	52.5	81.9	50.8	83.8	49.1	85.5	47.0	87.8	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	74.1	73.4	73.7	74.5	75.1	75.0	74.4	73.5	73.6	73.7	74.0	74.1	74.0
	DBStd	1.71	1.71	1.91	1.47	1.79	1.70	1.51	1.61	1.56	1.56	1.42	1.54	1.69
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	8792	727	663	760	752	776	733	727	732	710	745	724	743
	CDD65	3317	262	243	295	302	311	283	262	267	260	280	274	278
	CDH74	15084	1032	990	1369	1412	1572	1401	1249	1241	1258	1365	1099	1096
	CDH80	2211	107	144	215	247	282	218	175	176	189	207	125	126
(14) Wind	WSAvg	3.0	3.6	3.0	3.1	2.7	2.8	2.7	2.6	2.8	2.7	3.2	2.8	3.5
(15) Precipitation	PrecAvg	76.1	8.0	7.6	6.7	9.0	4.8	4.3	3.7	4.2	5.5	7.0	9.4	8.1
	PrecMax	99.8	15.0	15.0	25.0	18.2	8.3	8.2	13.0	14.8	9.3	13.4	18.4	16.2
	PrecMin	43.1	4.0	1.9	0.8	2.6	0.9	0.7	1.0	1.2	2.0	3.5	4.5	4.4
	PrecStd	15.0	3.0	3.5	4.7	3.4	2.1	1.9	2.4	2.9	1.9	2.6	3.5	3.0
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	84.0	85.9	85.3	85.5	85.8	85.4	84.7	84.9	85.2	85.3	84.8	84.5
		MCWB	71.9	72.8	72.9	73.6	73.2	72.4	72.0	71.4	71.8	71.1	72.0	72.3
	2%	DB	82.5	83.5	83.9	84.3	84.4	83.8	83.4	83.4	83.6	83.7	83.0	82.8
		MCWB	71.8	72.4	72.6	73.4	73.2	72.5	71.5	71.2	71.1	70.9	72.2	72.0
	5%	DB	81.1	81.8	82.5	82.8	83.1	82.7	82.1	82.1	82.3	82.4	81.5	81.3
		MCWB	71.4	72.0	72.4	73.0	72.8	72.2	71.2	71.0	70.9	70.8	72.1	71.7
	10%	DB	79.5	79.8	80.9	81.2	81.6	81.2	80.4	80.5	80.7	80.8	79.9	79.7
		MCWB	71.0	71.5	71.9	72.5	72.5	71.8	71.0	70.8	70.7	70.8	71.8	71.2
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	74.7	74.7	75.5	75.6	75.6	75.0	74.1	73.8	73.7	73.8	74.5	74.3
		MCDB	81.5	82.9	82.6	82.6	82.8	82.3	81.2	81.5	82.2	81.3	81.7	81.5
	2%	WB	73.5	73.5	74.1	74.6	74.6	73.7	72.9	72.8	72.7	72.7	73.5	73.2
		MCDB	80.2	80.8	81.3	81.6	81.6	81.1	80.4	80.4	80.7	80.3	80.6	80.3
	5%	WB	72.4	72.7	73.2	73.7	73.7	73.0	72.2	72.0	71.9	72.0	72.8	72.5
		MCDB	78.7	79.5	80.1	80.6	80.7	80.3	79.6	79.4	79.5	79.4	79.5	79.1
	10%	WB	71.5	72.0	72.4	72.9	72.9	72.4	71.6	71.3	71.3	71.4	72.1	71.8
		MCDB	77.4	78.1	78.9	79.4	79.5	79.2	78.7	78.5	78.4	78.6	78.4	77.9
(35) Mean Daily Temperature Range	5% DB	MDBR	13.7	14.3	15.6	15.4	15.3	15.4	16.0	15.4	15.7	15.7	14.2	13.8
		MCDBR	16.0	17.2	17.2	16.8	16.9	16.9	18.2	17.7	18.2	17.7	15.8	15.8
	5% WB	MCWBR	7.1	7.9	7.8	7.3	7.5	7.6	8.3	7.6	7.7	7.4	6.9	6.7
		MCDWR	14.5	15.1	16.0	15.8	15.7	15.7	16.4	16.0	16.1	15.8	14.7	14.5
(40) Clear-Sky Solar Irradiance	taub		0.421	0.475	0.462	0.417	0.429	0.435	0.446	0.507	0.585	0.611	0.455	0.396
		taud	2.372	2.200	2.249	2.392	2.360	2.347	2.312	2.105	1.878	1.803	2.274	2.457
	Ebn at Noon		290	274	275	281	270	263	262	252	240	236	277	296
		Edn at Noon	41	49	46	39	38	38	40	51	66	72	44	37
(44) All-Sky Solar Radiation	RadAvg		1451	1494	1596	1575	1554	1499	1477	1486	1482	1457	1481	1433
	RadStd		102	78	99	44	59	67	71	87	101	141	62	78

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page