

PANGKAL PINANG, Indonesia

WMO: 962370

Lat: 2.1631S

Lon: 106.1370E

Elev: 108

StdP: 14.64

Time Zone: 7.00 (E07)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	73.2	73.9	68.8	106.3	84.6	69.9	110.6	82.7	17.7	84.9	14.7	84.4	2.1	270	0.316

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9	11.9	90.8	78.0	90.0	78.3	89.3	78.5	80.9	87.5	80.4	87.0	80.0	86.5	9.3	80

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
79.0	151.3	84.2	78.5	148.5	83.8	78.2	146.8	83.5	44.5	87.9	44.1	87.5	43.6	86.9	90.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 15.8	13.8	12.0	70.8	93.0	1.4	1.7	69.8	94.2	69.0	95.2	68.3	96.2	67.3	97.4		
(5)			70.0	82.9	1.1	2.4	69.1	84.6	68.5	86.0	67.9	87.3	67.1	89.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	81.6	80.3	80.4	81.1	81.8	82.5	82.2	81.7	82.1	82.4	82.4	81.6	80.5
	DBStd	1.81	1.57	1.47	1.57	1.53	1.75	1.72	1.72	1.47	1.50	1.74	1.71	1.84
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	11528	939	852	964	954	1007	965	982	994	971	1005	948	947
	CDD65	6053	474	432	499	504	542	515	517	529	521	540	498	482
	CDH74	58191	3991	3667	4425	4708	5595	5287	5219	5529	5490	5599	4632	4049
CDH80	17799	933	937	1255	1409	1829	1707	1652	1864	1963	1939	1375	936	
Wind	WSAvg	4.2	3.7	4.0	3.3	2.8	3.7	4.4	5.6	6.5	6.0	4.2	2.7	2.9
Precipitation	PrecAvg	106.7	12.4	10.2	9.7	9.9	9.3	7.0	5.6	4.7	5.2	7.0	10.7	14.1
	PrecMax	151.7	34.8	28.5	14.7	22.8	19.9	22.2	16.9	18.9	15.4	17.4	20.6	27.6
	PrecMin	63.4	2.1	1.7	0.7	1.7	1.7	2.2	0.1	0.0	0.0	0.4	5.2	4.4
	PrecStd	25.5	7.5	6.8	3.5	4.8	4.3	4.4	4.1	4.3	3.8	4.8	3.6	5.2
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	89.0	89.5	90.7	90.8	90.9	90.5	89.7	90.2	91.7	92.0	91.2	89.9
		MCWB	78.2	78.5	79.3	78.7	79.7	79.1	78.5	77.7	76.2	76.9	77.6	79.0
	2%	DB	87.5	87.8	88.8	89.3	89.8	89.4	88.7	89.1	90.3	90.4	89.8	88.1
		MCWB	78.0	78.4	79.0	79.4	79.8	79.4	78.4	77.7	76.8	77.6	78.2	78.7
	5%	DB	86.1	86.5	87.6	88.1	88.9	88.5	87.9	88.2	89.1	89.2	88.4	86.4
		MCWB	78.0	78.0	78.8	79.2	79.7	79.1	78.2	77.6	77.0	77.7	78.3	78.4
	10%	DB	84.7	85.3	86.4	86.9	87.9	87.5	87.0	87.4	88.1	88.1	87.0	85.0
		MCWB	77.6	77.7	78.5	79.0	79.5	78.9	78.0	77.5	77.1	77.6	78.2	78.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	80.1	80.3	81.0	81.0	81.7	81.0	80.5	80.1	80.1	80.1	80.2	80.1
		MCDB	85.4	86.4	87.9	87.1	88.4	87.7	87.7	87.3	87.0	87.4	87.2	86.3
	2%	WB	79.3	79.5	80.1	80.2	80.8	80.5	79.7	79.3	79.2	79.5	79.6	79.4
		MCDB	84.6	85.5	86.6	86.5	87.5	87.2	86.8	86.6	86.6	86.8	86.5	85.4
	5%	WB	78.8	78.9	79.6	79.8	80.2	79.9	79.1	78.8	78.6	79.0	79.0	78.9
		MCDB	84.1	84.7	85.8	85.9	86.6	86.4	86.1	86.0	86.2	86.3	85.8	84.7
	10%	WB	78.2	78.2	78.9	79.3	79.8	79.3	78.5	78.1	78.0	78.3	78.5	78.3
		MCDB	83.0	83.5	84.8	85.0	85.8	85.6	85.2	85.1	85.3	85.3	84.8	83.5
Mean Daily Temperature Range	5% DB	MDBR	9.9	10.5	11.3	11.3	10.9	10.7	10.6	11.1	11.9	11.8	11.3	9.8
		MCDBR	11.5	12.0	12.8	12.5	12.0	11.8	11.3	12.0	13.2	13.2	13.3	11.9
		MCWBR	4.3	4.3	5.0	4.8	4.5	4.4	4.2	4.1	4.3	4.2	4.6	4.6
	5% WB	MCDBR	10.2	10.8	11.6	11.5	11.2	11.1	10.8	11.2	11.8	11.8	11.7	10.7
	MCWBR	4.4	4.5	5.0	5.0	4.6	4.7	4.5	4.3	4.7	4.4	4.7	4.7	
Clear-Sky Solar Irradiance	taub	0.445	0.466	0.455	0.426	0.431	0.437	0.442	0.476	0.534	0.556	0.473	0.431	
	taud	2.391	2.309	2.341	2.427	2.422	2.416	2.394	2.272	2.082	2.024	2.282	2.424	
	Ebn at Noon	283	277	277	278	269	263	264	261	252	250	272	285	
	Edh at Noon	40	44	42	37	36	36	37	43	54	57	44	38	
All-Sky Solar Radiation	RadAvg	1407	1561	1614	1536	1486	1437	1508	1636	1621	1473	1349	1247	
	RadStd	83	110	86	72	74	115	102	103	109	97	70	82	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page